



Alternative 5:
Approximately 2,640 LF
of 2-12" Force Mains

Alternative 5:
Approximately 2,543 LF
of 12" PVC Gravity Sewer

Alternative 5:
Approximately 1,995 LF
of 12" PVC Gravity Sewer

Proposed Regional Pump Station
Approximately 3,200 gpm capacity

Alternative 5:
Approximately 16,477 LF
of 18" PVC Gravity Sewer

Total sewer replacement in the park area is approximately 16,052 LF of 8" Gravity Sewer.

Alternate 5	
	3,200 gpm Pump Station
	16,500 LF 18" Gravity Sewer
	4,600 LF 12" Gravity Sewer
	2,700 LF 12" Force Main
	Abandon Etterwood PS
	Abandon Bradford 1 PS
	Abandon Bradford 2 PS

	Proposed PS
	Upgrade PS
	Proposed Force Main
	Proposed Gravity Sewer
	Proposed Park Sewer
	Eliminated Pump Station
	Ex. Pump Station
	Ex. Force Main
	State Roads
	Railroad
	USGS 10' Contours
	Parcel

Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community