## PROJECT CHANGE NOTICE

CR Date:	December 15, 2015
CR#	LXP-002
Project Name:	Lexington PSOC
Purchase Order #:	LF00131163
Originator:	Robert Stack
Project Manager:	Greg Senter
	CR # Project Name: Purchase Order #: Originator:

## **DESCRIPTION OF CHANGE**

Addition of Ice Shield over the Isolation Transformer

## **NEED & NECESSITY**

Mission Critical Partners has identified the need to place an ice shield over the Isolation Transformer to be deployed at the PSOC site to mitigate the potential of damage caused by ice falling from the tower.

## **IMPACTS**

Technical Impact to Specifications, Performance or Operational Requirements:

Custom Ice Shield to be installed including associated materials and installation:

- One (1) 4'W x 4' L x 4' H Ice Shield/Bridge
- Four (4) fully adjustable posts with support angles, grip strut ice shield, and connection hardware
- Hot Dipped Galvanized materials shall be used
- Includes all necessary MTR's on material as well as all CWI shop certifications, where applicable

Impact on Project Schedule and Potential Mitigation Steps:

No impact

Impact on Project Cost and Potential Mitigation Steps:

\$3,485 cost impact to the LFUCG

Customer Acceptance Signature Approval:	Airbus DS Communications Signature Approval
Authorized by:	Authorized by:
Printed name:	Printed name: Derek R. Gamble
Date:	Date: 120/16

PROJECT CHANGE NOTICE Page 1

© 2016 Airbus DS Communications, Inc. This document is protected by copyright law and international treaties, and is the CONFIDENTIAL AND PROPRIETARY information of Airbus DS Communications, Inc. Unauthorized reproduction, use, or distribution of this document, or any portion of it, may result in severe civil and criminal penalties, and will be prosecuted to the maximum extent possible under the law. All trademarks, service marks, product names, brands, company names and logos appearing in this proposal are the property of their respective owners.