


MAYOR LINDA GORTON



LEXINGTON

CHARLES H. MARTIN, P.E.
DIRECTOR
WATER QUALITY

To: Mayor Linda Gorton
Urban County Council

From: 
Charles H. Martin, P.E., Director
Division of Water Quality

Date: April 9, 2019

Subject: Sole Source Replacement of CL2 & SO2 Regulators at Town Branch WWTP

Request

The purpose of this memorandum is to request approval to purchase De Nora Water Technologies regulators for the Town Branch WWTP from JAGS Environmental, Inc., (formerly Delaney & Assoc. Inc.).

Purpose of Request

The housing of existing “regulators” is disintegrating and replacement of the chlorine gas feed (regulator) is needed. The regulators play an important role during chlorination and dechlorination process at the Town Branch WWTP.

Replace/Repair Cost in FY19

The quote from JAGS Environmental, Inc., (formerly Delaney & Assoc. Inc.), for new De Nora Chlorine gas & Sulfur Dioxide gas regulators, is \$19,884.00. Freight charges will be calculated separately.

Are Fund Budgeted

Funds are budgeted in: 4002 -- 303402 -- 0001 - 91017

Martin/Albright

