



Mayor Jim Newberry

**LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT**  
Division of Water Quality

To: Hillard Newman, P.E., Engineering Section Manager, Division of Engineering  
Ron St.Clair, Stephen Parker, Lee Rice, and Barry Brock

From: Carol Schoaff, Engineering Technician Principal, WWC&CS, Division of Water Quality

Cc: Rodney Chervus, P.E., WWC&CS Manager, Division of Water Quality

Date: December 18, 2008  
**REVIEW DATE: MARCH 17, 2021**

Re: New Development 3 Year Re-Inspect  
Subdivision: Bluegrass Aspendale  
Unit/Phase: Phase 2 (Housing Authority) #2  
Parcel 2  
Design Engineer: Sherman Carter Barnhart  
Contractor:

The Division of Water Quality (DWQ) has completed a review of the above referenced project. We are providing the following list of items, for sanitary sewer systems only, that need to be addressed. We request that you include this list of items with comments from the Division of Engineering.

Material Reviewed: CCTV and Manhole Inspection performed by LFUCG

***This property is depicted on ArcView as 551 East 6<sup>th</sup> Street***

Manhole A-1 (CR6\_203)

- The casting is off center
  - Realign the casting, re-vacuum test and submit the test sheets to my attention at DWQ
- The steps are not located over the downstream (outlet) pipe as required by LFUCG Standard Drawings
  - Realign the steps, re-vacuum test and submit the test sheets to my attention at DWQ

**NO WORK COMPLETED BY LFUCG, DEVELOPER RESPONSIBILITY TO FIELD VERIFY EXISTING CONDITIONS AND CORRECT AS NEEDED.**

**HORSE CAPITAL OF THE WORLD**