

<b>LEXINGTON-FAYETTE URBAN COUNTY          GOVERNMENT CONTRACT CHANGE ORDER</b> Page 1 of 2	Date:	April 11, 2018	
	Project:	Evoqua Sole Source Agreement for Scrubber Maintenance @ West Hickman and Town Branch	
	Location:	West Hickman	
To (Contactor): Evoqua Water Technologies, LLC 2650 Tallevast Road Sarasota, FL 34243	Contract No.	Res # 422-2017	
	Original Contract Amt.	\$136,115.00	
	Cumulative Amount of Previous Change Orders	\$0.00	
	Percent Change - Previous Change Orders		0.00%
	Total Contract Amount Prior to this Change Order	\$136,115.00	
	Change Order No.	1	

You are hereby requested to comply with the following changes from the contract plans and specification;

**Current Change Order**

Item No.	Description of changes-quantities, unit prices, change in completion date, etc.	Decrease in contract price	Increase in contract price	
1	Purchase of new Chemical Pump for Solids Building Odor Scrubber.		\$10,867.00	
	<b>Total decrease</b>	<b>\$0.00</b>		
	<b>Total increase</b>		<b>\$10,867.00</b>	
	<b>Net Amount of this Change Order</b>	<b>\$10,867.00</b>		
	<b>New Contract Amount Including this Change Order</b>	<b>\$146,982.00</b>		
	<b>Percent Change - This Change Order</b>			7.98%
	<b>Percent Change - All Change Orders</b>			7.98%

The time provided for the completion in the contract and all provisions of the contract will apply hereto.

Recommended by [Signature] (Proj. Engr.) Date 4/11/2018  
 Accepted by [Signature] (Contractor) Date 4/17/2018  
 Approved by [Signature] (Director) Date 4-19-18  
 Approved by [Signature] (Commissioner) Date 4-23-18  
 Approved by [Signature] (Mayor or CAO) Date 3-May-2018

4/11/18  
Hickman


**JUSTIFICATION FOR CHANGE**

PROJECT: Evoqua Sole Source Agreement for Scrubber Maintenance @ West Hickman and Town Branch

CONTRACT NO. 422-2017

CHANGE ORDER: 1

- 1. Necessity for change: Chemical pump not working needs to be replaced.
  
- 2. Is proposed change an alternate bid? \_\_\_Yes XNo
  
- 3. Will proposed change alter the physical size of the project? \_\_\_ Yes XNo  
If "Yes", explain.
  
- 4. Effect of this change on other prime contractors: N/A
  
- 5. Has consent of surety been obtained? \_\_\_Yes XNot Necessary
  
- 6. Will this change affect expiration or extent of insurance coverage? \_\_\_Yes XNo  
If "Yes", will the policies be extended? \_\_\_Yes \_\_\_No
  
- 7. Effect on operation and maintenance costs: N/A
  
- 8. Effect on contract completion date: None

  
\_\_\_\_\_  
Mayor

3-May-2018  
Date


MAYOR JIM GRAY



**LEXINGTON**

CHARLES H. MARTIN, P.E.  
DIRECTOR  
WATER QUALITY

To: Mayor Jim Gray  
Urban County Council

From:   
Charles H. Martin, P.E., Director  
Division of Water Quality

Date: April 11, 2018

Subject: Change Order #1 (Final) Resolution # 422-2017  
Sole Source Agreement with Evoqua - Repair of a LoPro Scrubber at West Hickman

---

Request

The Division of Water Quality requests authorization to execute Change Order #1 (Final) with Evoqua Water Technologies LLC for the repair of the LoPro Scrubber Systems at the West Hickman WWTP, increasing the contract price by \$10,867.00 from \$136,115.00 to \$146,982.00.

Purpose of Request

The manufacturer, Evoqua Water Technologies LLC, is the only factory trained and authorized provider of service contracts for this equipment. Resolution # 422-2017 approved the use of Evoqua for this work but limited the scope at a cost "not to exceed" 136,115.00. After Evoqua serviced the existing LoPro Scrubber System (Solids Building) at West Hickman it was determined that one chemical pump was not operational and could not be repaired. The replacement of the chemical pump, at a cost of \$10,867.00, is necessary to ensure the unit is operating properly and in accordance with manufacturer's recommendations.

Project Cost in FY18 and in Future Budget Years

The cost for FY18 is \$10,867.00. No additional capital costs are expected for the life cycle of the pump.

Are Funds Budgeted?

Funds are budgeted in: 4002-303403-0001-76101

Martin/Hoskins-Squier

