



Lexington-Fayette Urban County Government  
DEPARTMENT OF ENVIRONMENTAL QUALITY

Jim Gray  
Mayor

Richard Moloney  
Acting Commissioner

To: Mayor Jim Gray  
Urban County Council

From:   
Charles H. Martin, P.E., Director  
Division of Water Quality

Date: February 8, 2012

Subject: Change Order # 1 (Final) Griffin Gate #2 Pump Station Replacement

The Division of Water Quality requests approval of Change Order #1 (final) with Grant's Excavating Inc. for the Griffin Gate Pump Station Replacement project. The original amount of this project was \$173,000.00. Change Order #1 is for \$5,105.00. Change Order #1 gives a revised total contract amount of \$178,105.00. The sum of this Change Order amounts to 3% of the original contract amount.

**Description of Change Order**

1. Upgrade transducer to meet current pump station maintenance requirements.  
Add \$1,000.00
2. Locating existing force main and lay additional 80LF of new 6" DIP force main.  
Add \$4,105.00

Total Cost of Change Order #1: \$ 5,105.00