


MAYOR JIM GRAY



LEXINGTON

CHARLES H. MARTIN, P.E.
DIRECTOR
WATER QUALITY

To: Mayor Jim Gray
Urban County Council

From: 
Charles H. Martin, P.E., Director
Division of Water Quality

Date: April 11, 2018

Subject: Change Order #1 (Final) Resolution # 422-2017
Sole Source Agreement with Evoqua - Repair of a LoPro Scrubber at West Hickman

Request

The Division of Water Quality requests authorization to execute Change Order #1 (Final) with Evoqua Water Technologies LLC for the repair of the LoPro Scrubber Systems at the West Hickman WWTP, increasing the contract price by \$10,867.00 from \$136,115.00 to \$146,982.00.

Purpose of Request

The manufacturer, Evoqua Water Technologies LLC, is the only factory trained and authorized provider of service contracts for this equipment. Resolution # 422-2017 approved the use of Evoqua for this work but limited the scope at a cost "not to exceed" 136,115.00. After Evoqua serviced the existing LoPro Scrubber System (Solids Building) at West Hickman it was determined that one chemical pump was not operational and could not be repaired. The replacement of the chemical pump, at a cost of \$10,867.00, is necessary to ensure the unit is operating properly and in accordance with manufacturer's recommendations.

Project Cost in FY18 and in Future Budget Years

The cost for FY18 is \$10,867.00. No additional capital costs are expected for the life cycle of the pump.

Are Funds Budgeted?

Funds are budgeted in: 4002-303403-0001-76101

Martin/Hoskins-Squier

