

ADDENDUM No. 4

Bid Number: #132-2020

Date: January 28, 2021

Subject: \

Wolf Run Trunk Sewers D & E

Wastewater System Improvements

Remedial Measures Plan ID No. WR-04, WR-05

Address inquiries to: Q&A Module on Ion Wave

Brian Marcum

brianm@lexingtonky.gov

(859) 258-3325

TO ALL PROSPECTIVE SUBMITTERS:

Please be advised of the following clarifications to the above referenced Bid:

	Questions	Answers
1	Can you email myself the attendee list for the LFUCG - Wolf Run Trunk Sewers D & E - Pre-Bid Meeting?	The attendee list was sent out as part of Addendum #3.
2.	Sheet C-05: Will the contractor be reimbursed for gas line location?	No, the Contractor's costs to field verify the gas line location, within the first 30-days of the NTP, will be incidental to the project cost.
3.	Sheet C-06: Will the contractor be reimbursed for gas line location?	No, the Contractor's costs to field verify the gas line location, within the first 30-days of the NTP, will be incidental to the project cost.
4,	Can the bid date be extended for the project? There are several other projects out to bid around the 2/4/21 bid date. A one or two week extension would allow us more time to put a competitive number on this project.	No, due to EPA consent judgement deadlines the bid date will not be extended.
5.	Where do we install sanitary markers?	Sanitary markers are not required for gravity sewer projects.





6.	manholes on the project?	There will be one (1) internal drop manhole as part of this project. MH #E-24, on SHT C-13 has an 18" internal drop to allow room for the 24" sewer stub-out. The internal manhole drop connection detail can be found on SHT SD4.
7.	Is there an engineer's estimate?	LFUCG does not release the engineer's estimate prior to bid opening.
8.	For this amount of pipe in rock, can the schedule of 365 days be extended if needed?	No, due to the EPA consent judgement schedule the construction time will not be extended.
9.	Will settlement monitoring be on this project per spec 2222-8?	Specification Section 2222 applies to bore-pits. Settlement monitoring, as outlined in this specification, will not be necessary for this project. However, the Contractor is responsible for any construction settlement on the project.
10.	Unit 67 & 70 conflict with each other. Which one do we use for sod?	Line item #70 (Sod) in the Bid Schedule is redundant and will be removed. See updated Bid Schedule.
11,	Will 1037 Cross Key Rd dumpster pad & fence be by units or is this incidental to contract?	Dumpster pads and fences being disturbed as part of this project are incidental to the contract as listed in the MOU conditions. These items shall be replaced per LFUCG's current dumpster pad guidelines.
12.	Will chain link fence for personal properties be per unit prices 4 & 6' ft fence?	Chain link fencing associated with personal properties that are outlined in the MOU conditions will be incidental to the contract. Refer to the attached updated Bid Schedule for all fencing outside of personal properties.
13.	(The entry of mobile equipment into stream channel shall be prohibited) Can you clarify on what this means? No equipment at all in the creek?	The entry of mobile equipment into a stream channel shall be prohibited, based off the General Floodplain Permit. If the entirety of construction cannot be accomplished from the stream bank, the Contractor will have to obtain an individual permit.
14,	Will tree removal for specific addresses be part of clear & grub unit price or will this be incidental?	All tree removal is incidental to the contract either by line item #89 (Clearing and Grubbing) in the Bid Schedule or through the MOU conditions.
15.	What unit will the temporary stone parking lot area be in?	It is Incidental to the contract.





16.	Is full depth stone backfill required under all pavements?	Yes.
17.	Will creek crossing detail be provided?	Creek crossing specifics are located on the "Streambank Restoration" details which can be seen on SHT SD5
18.	Can sanitary sewer maps be provided in vicinity of new construction to facilitate bypass pumping planning?	Sanitary sewer maps will be provided to the successful bidder.
19.	Is it okay to close Appomattox road, Normandy road, Furlong drive, and Beacon Hill road as needed?	Access to all private driveways will remain open at all times. Any lane and/or road closures are the Contractor's responsibility to be coordinate with and submitted for approval to LFUCG's traffic engineering.
20.	Maximum flow expected thru the existing 21" RCP at 0.16% slope is approximately 3,000 GPM. Is it necessary to size pumps and piping for 8.3 MGD (5,764 GPM)?	Yes, the pump rate listed was established by LFUCG's Consent Decree modeling results for a 2-year 24-hour storm.
21.	Will blasting be allowed during this project?	There is no blasting allowed for the project. Specification Section 02225 is a standard specification.
22.	Will steam be allowed for the CIPP alternative?	Yes.

1. CLARIFICATIONS

A. None at this time.

2. DRAWINGS

- A. Drawing C-02
 - Revise profile note for MH # D-4 to read:
 INV. IN EL. = 899.79 (4" SEWER) (N) (EXTERNAL DROP)

3. SPECIFICATIONS

- A. Specification Section 00410 Bid Form
 - Replace Section 00410, in its entirety, with attached revised Bid Schedule





B. Specification Section 01025 - Measurement and Payment

All other terms and conditions of the Bid and specifications are unchanged.

Delete paragraph 2.38 in its entirety and replace with the following:
 2.38 Not Used

Todd Slatin, Director Division of Central Purchasing

Lodd St

This letter should be signed, attached to and become a part of your Bid.

COMPANY NAME: Tribute Contracting; Consultants, LLC

ADDRESS: 2175 CO Rd I, South Point, OH 45680

SIGNATURE OF BIDDER:

Todd Harrah, Manager/member

Attachments:

Drawings	
Specifications 00410 – Bid Form	
Plan Holders List	





TODD SLATIN
DIRECTOR
CENTRAL PURCHASING

ADDENDUM No. 3

Bid Number: #132-2020 Date: January 26, 2021

Subject: Wolf Run Trunk Sewers D & E

Wastewater System Improvements

Remedial Measures Plan ID No. WR-04, WR-05

Address inquiries to: Q&A Module on Ion Wave

Brian Marcum

brianm@lexingtonky.gov

(859) 258-3325

TO ALL PROSPECTIVE SUBMITTERS:

Please be advised of the following clarifications to the above referenced Bid:

1. CLARIFICATIONS

A. Please see attached Pre-Bid Meeting Minutes

2. DRAWINGS

A. None at this time.

3. SPECIFICATIONS

A. None at this time.

Todd Slatin, Director
Division of Central Purchasing

Irdd Ste

All other terms and conditions of the Bid and specifications are unchanged. This letter should be signed, attached to and become a part of your Bid.





TODD SLATIN
DIRECTOR
CENTRAL PURCHASING

COMPANY NAME: Tribute Contracting & Consultants, LLC

ADDRESS: Z175 County Rd 1, South Point, OH 45680

SIGNATURE OF BIDDER:

Todd Harrah, Manager/Member

Attachments:

Pre-Bid Meeting Minutes
Attendee Log (Sign-in Sheet)
PIE Procedures for DWQ Projects
DWQ Policy for Storing Materials in the Floodway





ADDENDUM No. 2

Bid Number: #132-2020 Date: January 19, 2021

Subject: Wolf Run Trunk Sewers D & E

Remedial Measures Plan ID No. WR-04, WR-05

Address inquiries to:

Q&A Module on Ion Wave

Brian Marcum

brianm@lexingtonky.gov

(859) 258-3325

TO ALL PROSPECTIVE SUBMITTERS:

Please be advised of the following clarifications to the above referenced Bid:

The Microsoft Teams Meeting link has been revised. A new meeting link and a call in number are provided below, as shown in the specification revision.

- A. Specification Section 00100 Advertisement for Bids
 - Revise Section 00100, Part 1.12, Page 00100-3, to read:

A <u>mandatory</u> pre-Bid meeting will be held at <u>9:00 am local time</u>, <u>January 20, 2021</u> via teleconference. A direct link to the Microsoft Teams Meeting is as follows:

Microsoft Teams meeting

Join on your computer or mobile app

https://teams.microsoft.com/l/meetup-

join/19%3ameeting MWZkNzEzZjktMDZhMC00YTM3LTg4NTgtN2I0Y2NiOTQ1NjBj%4

Othread.v2/0?context=%7b%22Tid%22%3a%22083fc4d2-72ad-412b-ae7d-

6b81b83916dd%22%2c%22Oid%22%3a%22148017a5-c42e-4f7e-864e-

3de5bb20c0bc%22%7d

Or https://tinylink.net/1gUsg

Or scan QR Code Below



Or call in (audio only) +1 502-208-2565, ID No.: 348 543 571# United States, Louisville





TODD SLATIN
DIRECTOR
CENTRAL PURCHASING

Todd Slatin, Director Division of Central Purchasing

Told Set

All other terms and conditions of the Bid and specifications are unchanged. This letter should be signed, attached to and become a part of your Bid.

ADDRESS: 2125 County Rd 1, South Point OH 45680

SIGNATURE OF BIDDER:					
Toold Harrat	, Manager/Member				
Attachments:					
Drawings					
Specifications					



TODD SLATIN
DIRECTOR
CENTRAL PURCHASING

ADDENDUM No. 1

Bid Number: #132-2020 Date: January 19, 2021

Subject: Wolf Run Trunk Sewers D & E

Wastewater System Improvements

Remedial Measures Plan ID No. WR-04, WR-05

Address inquiries to: Q&A Module on Ion Wave

Brian Marcum

brianm@lexingtonky.gov

(859) 258-3325

TO ALL PROSPECTIVE SUBMITTERS:

Please be advised of the following clarifications to the above referenced Bid:

1. DRAWINGS

- A. Drawing C-13
 - Revise the invert elevation of the 24" stub out on MH E-24 from 714.10 to 914.10, in the profile. Elevation is shown in two locations.

2. SPECIFICATIONS

- A. Specification Section 00100 Advertisement for Bids
 - Revise Section 00100, Part 1.12, Page 00100-3, to read:
 - A <u>mandatory</u> pre-Bid meeting will be held at <u>9:00 am local time</u>, <u>January 20</u>, <u>2021</u> via teleconference. A direct link to the Microsoft Teams Meeting is as follows: https://teams.microsoft.com/l/meetup-

join/19%3ameeting NGEyODAzMWEtNjgwNi00MWQxLTg0MDctMmNIMDFiYjQzMTg3% 40thread.v2/0?context=%7b%22Tid%22%3a%22083fc4d2-72ad-412b-ae7d-6b81b83916dd%22%2c%22Oid%22%3a%223f98bafd-29d4-4ba0-9821-024d98a2833c%22%7d





Todd Slatin, Director

Division of Central Purchasing

All other terms and conditions of the Bid and specifications are unchanged.
This letter should be signed, attached to and become a part of your Bid.

COMPANY NAME: Tribute Contracting & Consultants, LLC

ADDRESS: 2125 County Rd 1, South Point OH 45680

SIGNATURE OF BIDDER: Todd Harrah, Manager/Member

Attachments:

Drawings

Specifications

