



CONTRACT DOCUMENTS
AND
SPECIFICATIONS

DIVISION OF WATER QUALITY

FOR

Haley Pike Landfill Force Main

Bid No. 21-2016

PREPARED BY:
Bell Engineering, Inc.
2480 Fortune Drive, Suite 350
Lexington, Kentucky 40509
(859)-278-5412

TABLE OF CONTENTS

CONTRACT DOCUMENTS

Haley Pike Landfill Forcemain

PART I	ADVERTISEMENT FOR BIDS
PART II	INFORMATION FOR BIDDERS
PART III	FORM OF PROPOSAL
PART IV	GENERAL CONDITIONS
PART V	SPECIAL CONDITIONS
PART VI	CONTRACT AGREEMENT
PART VII	PERFORMANCE AND PAYMENT BONDS
PART VIII	ADDENDA
PART IX	TECHNICAL SPECIFICATIONS AND PLANS

PART 1

ADVERTISEMENT FOR BIDS

INDEX

1.	INVITATION	AB-2
2.	DESCRIPTION OF WORK	AB-2
3.	OBTAINING PLANS, SPECIFICATIONS, AND BID DOCUMENTS	AB-2
4.	METHOD OF RECEIVING BIDS.....	AB-3
5.	METHOD OF AWARD	AB-3
6.	BID WITHDRAWAL.....	AB-3
7.	BID SECURITY	AB-3
8.	SUBMISSION OF BIDS	AB-3
9.	RIGHT TO REJECT.....	AB-4
10.	NOTIFICATION TO THE LFUCG FOR AFFIRMATIVE ACTION	AB-4
11.	NOTICE CONCERNING DBE GOAL.....	AB-4
12.	PRE-BID MEETING	AB-5

ADVERTISEMENT FOR BIDS

1. INVITATION

Sealed proposals for the following work will be received by the Lexington-Fayette Urban County Government (LFUCG) until 2:00 p.m., local time, **February 29, 2016**, for furnishing all labor and/or materials and performing all work as set forth by this advertisement, conditions (general and special), specifications, and/or the drawings prepared by and for Lexington-Fayette Urban County Government, Division of Environmental Services. Immediately following the scheduled closing time for reception of bids, all proposals which have been submitted in accordance with the above will be publicly opened and read aloud.

2. DESCRIPTION OF WORK

Consisting of the construction and/or furnishing of items as listed in the Bid Schedule beginning on page P-6, Part III, Form of Proposal, of this document, for the Haley Pike Landfill Forcemain, Lexington-Fayette County, Kentucky.

3. OBTAINING PLANS, SPECIFICATIONS, AND BID DOCUMENTS

Plans, Specifications, and Contract Documents may be obtained from the official bid document distributor, LYNN IMAGING, 328 Old Vine Street, Lexington, KY 40507, (859) 255-1021 or (www.lynnimaging.com) and click on plan room for a non-refundable price of reproduction for each full set of plans and documents.

Specifications, Plans, and Bid Documents may be examined at the following places:

LFUCG
Division of Central Purchasing
200 East Main Street, Third Floor, Rm 338
Lexington, Kentucky 40507
(859) 258-3320

Builder's Exchange
1035 Strader Drive, Ste 100
Lexington, Kentucky 40505

Lynn Blueprint
328 Old Vine Street
Lexington, KY 40507

McGraw-Hill/F W Dodge
2321 Fortune Drive, Ste 112-A
Lexington, Kentucky 40509

4. **METHOD OF RECEIVING BIDS**

Bids will be received from Prime Contracting firms on a **Lump Sum/Unit Price** for total Project. The Bidder must include a price for all bid items to be considered. Bids shall be submitted in the manner and subject to the conditions as set forth and described in the Instruction to Bidders and Special Conditions.

Sealed bids shall be clearly marked on the outside of the container as follows: Company Name and Address, Bid Invitation Number, and the Project Name. Bids are to remain sealed until official Bid closure time.

Mailed bids/proposals should be sent to the Director, Division of Central Purchasing, 200 East Main Street, Lexington, KY 40507.

5. **METHOD OF AWARD**

The Contract, if awarded, will be to the lowest, qualified responsible bidder for the total project whose qualifications indicate the award will be in the best interest of the OWNER and whose bid/proposal complies with all the prescribed requirements. No Notice of Award will be given until the OWNER has concluded such investigation as deemed necessary to establish the responsibility, qualifications and financial ability of Bidders to do the work in accordance with the Contract Documents to the satisfaction of the OWNER within the time prescribed. The OWNER reserves the right to reject the Bid of any Bidder who does not pass such investigation to the OWNER's satisfaction. In analyzing Bids, the OWNER may take into consideration alternate and unit prices, if requested by the Bid forms.

6. **BID WITHDRAWAL**

No bidder may withdraw his bid for a period of sixty (60) calendar days after the closing date for receipt of bids. Errors and omissions will not be cause for withdrawal of bid without forfeit of bid bond. Bids may be withdrawn in person prior to the closing date of receipt of bids.

7. **BID SECURITY**

If the bid is \$50,000 or greater, bid shall be accompanied by a certified /cashier's check or bid bond payable to the Lexington-Fayette Urban County Government in an amount not less than Five Percent (5%) of the base bid. Bid bond shall be executed by a Surety Company authorized to do business in the Commonwealth of Kentucky and countersigned by a licensed Kentucky Resident Agent, representing the Surety Company. Bid Bonds are not required for bids under \$50,000. A certified check or cashier's check is also acceptable forms of bid security.

8. **SUBMISSION OF BIDS**

CONTRACTORS shall submit their bids to the Lexington-Fayette Urban County Government, Division of Purchasing, Third Floor, 200 East Main Street, Lexington, Kentucky 40507. Bids shall be submitted in a sealed envelope not later than 2:00 p.m. local

time, **February 29, 2016**. Sealed proposals shall be clearly marked on the outside of the container as follows: Company Name and Address, Bid Invitation Number, and Project Name to be opened at 2:00 p.m. local time **February 29, 2016**. Bids are to remain sealed until official Bid closure time. Bids received after the scheduled closing time for receipt of bids will not be considered and will be returned unopened.

9. RIGHT TO REJECT

The Lexington-Fayette Urban County Government reserves the right to reject any and all bids and to waive all informalities and/or technicalities where the best interest of the Lexington-Fayette Urban County Government may be served.

10. NOTIFICATION TO THE LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT FOR AFFIRMATIVE ACTION PLAN AND CURRENT WORKFORCE

The successful bidder must submit with their bid the following items to the Lexington-Fayette Urban County Government:

1. Affirmative Action Plan for his/her firm.
2. Current Workforce Analysis Form.

Failure to submit these items as required herein may result in disqualification of the Bidder from the award of the contract.

All submissions should be directed to:

Lexington-Fayette Urban County Government
Division of Purchasing
200 East Main Street, 3rd Floor, Room 338
Lexington, Kentucky 40507

11. NOTICE CONCERNING MWDBE GOAL

Notice of requirement for Affirmative Action to ensure Equal Employment Opportunities and Disadvantaged Business Enterprises (DBE) Contract participation. Disadvantaged Business Enterprises (DBE) consists of Minority-Owned Business Enterprises (MBE) and Woman-Owned Business Enterprises (WBE).

The Lexington-Fayette Urban County Government has set a goal that not less than ten percent (10%) of the total value of this Contract be subcontracted to Disadvantaged Business Enterprises, which is made up of MBEs and WBEs. The goal for the utilization of Disadvantaged Business Enterprises as subcontractors is a recommended goal. Contractor(s) who fail to meet such goal will be expected to provide written explanations to the Director of the Division of Purchasing of efforts they have made to accomplish the recommended goal, and the extent to which they are successful in accomplishing the

recommended goal will be a consideration in the procurement process. Depending on the funding source, other DBE goals may apply.

For assistance in locating Disadvantaged Business Enterprises Subcontractors contact:

Sherita Miller, Division of Central Purchasing
Lexington-Fayette Urban County Government
200 East Main Street, 3rd Floor, Room 338
Lexington, Kentucky 40507

12. PRE-BID MEETING

A mandatory pre-bid meeting will be held at 10:00 AM local time on February 17th, 2016 at the Haley Pike Landfill, Lexington, KY.

END OF SECTION

PART II
INFORMATION FOR BIDDERS

INDEX

1.	RECEIPT AND OPENING OF BIDS	IB-2
2.	PREPARATION OF BID.....	IB-2
3.	SUBCONTRACTS.....	IB-2
4.	QUALIFICATION OF BIDDER	IB-3
5.	BID SECURITY	IB-4
6.	LIQUIDATED DAMAGES FOR FAILURE TO ENTER INTO CONTRACT.....	IB-4
7.	TIME OF COMPLETION AND LIQUIDATED DAMAGES.....	IB-4
8.	EXAMINATION OF CONTRACT DOCUMENTS AND SITE.....	IB-5
9.	ADDENDA AND INTERPRETATIONS	IB-5
10.	SECURITY FOR FAITHFUL PERFORMANCE	IB-6
11.	POWER OF ATTORNEY	IB-6
12.	TAXES AND WORKMEN'S COMPENSATION	IB-6
13.	LAWS AND REGULATIONS	IB-6
14.	EROSION AND SEDIMENT CONTROL AND PERMITS	IB-6
15.	PREVAILING WAGE LAW AND MINIMUM HOURLY RATES.....	IB-7
16.	AFFIRMATIVE ACTION PLAN.....	IB-7
17.	CONTRACT TIME.....	IB-7
18.	SUBSTITUTION OR "OR-EQUAL" ITEMS.....	IB-7
19.	ALTERNATE BIDS.....	IB-8
20.	SIGNING OF AGREEMENT	IB-8
21.	ASSISTANCE TO BE OFFERED TO DBE CONTRACTORS.....	IB-8
22.	LFUCG NON-APPROPRIATION CLAUSE.....	IB-10

PART II

INFORMATION FOR BIDDERS

1. **RECEIPT AND OPENING OF BIDS**

The Lexington-Fayette Urban County Government (herein called the OWNER) invites bids from firms on the project described in the Advertisement for Bids. The OWNER will receive bids at the Division of Purchasing, at the time and in the manner set forth in the Advertisement for Bids, and the Bids will then be publicly opened and read aloud. The OWNER may consider informal any bid not prepared and submitted in accordance with the provisions hereof and may waive any informalities or reject any and all bids. Any bid may be withdrawn prior to the scheduled time for the opening of bids or authorized postponement thereof. Any bid received after the time and date specified shall not be considered. No bidder may withdraw a bid within 60 days after the actual time and date of the bid opening, but OWNER may, in its sole discretion, release any bid and return the Bid Security prior to that date.

The Lexington-Fayette Urban County Government assumes no responsibility for bids that are not addressed and delivered as indicated above. Bids that are not delivered to the Division of Central Purchasing by the stated time and date will be rejected.

2. **PREPARATION OF BID**

Each bid must be submitted on the prescribed Form of Proposal. All blank spaces for the bid prices must be filled in, either in ink or typewritten, for both unit prices and extensions. Totals for each bid item must be added to show the total amount of the bid. Each bid must be submitted in a sealed envelope bearing on the outside the name of the bidder, their address, the name of the project, the invitation number and time and date for which the bid is submitted. Bids must be addressed to the Director of Purchasing, Lexington-Fayette Urban County Government, Third Floor, 200 East Main Street, Lexington, Kentucky 40507. If forwarded by mail, the sealed envelope containing the bid must be enclosed in another envelope addressed as specified above.

3. **SUBCONTRACTS**

The bidder is specifically advised that any person, firm, or other party to whom it is proposed to award a subcontract under this Contract must be acceptable to the OWNER. All proposed subcontractors must be identified on the Form of Proposal. Prior to the award of Contract, the OWNER or the OWNER'S representative will advise the CONTRACTOR of the acceptance and approval thereof or of any action necessary to be taken. Should any Subcontractor be rejected by the OWNER, the CONTRACTOR shall present a new name and/or firm to the OWNER at no change in the Contract Price.

4. QUALIFICATION OF BIDDER

The OWNER may make such investigations as the OWNER deems necessary to determine the ability of the bidder to perform the Work, and the bidder shall furnish to the OWNER all such information and data for this purpose as the OWNER may request. The OWNER reserves the right to reject any bid if the evidence submitted by, or investigation of, such bidder fails to satisfy the OWNER that such bidder is properly qualified to carry out the obligations of the Contract and to complete the Work contemplated therein. Conditional bids will not be accepted.

In evaluating Bids, OWNER shall consider the qualifications of the BIDDERS, whether or not the Bids comply with the prescribed requirements, and alternatives and unit prices, as requested. OWNER may consider maintenance requirements, performance data, and disruption or damage to private property. It is OWNER'S intent to accept alternatives, if requested by the bid forms, in the order in which they are listed in the Bid Form but OWNER may accept or decline them in any order or combination. The contract, if awarded, will be awarded to the lowest, qualified, responsible BIDDER based upon OWNER'S evaluation which indicates that the award will be in the best interest of OWNER and the general public.

In the event there is any question as to the bidder's qualifications and ability to complete the work, a final determination will be made in accordance with a fair evaluation by the Urban County Government of the above listed elements.

- A. If the OWNER requires filling out a detailed financial statement, the bidder may provide its current certified financial statement(s) for the required time interval.
- B. Corporate firms are required to be registered and in good standing with the requirements and provisions of the Office of the Secretary of State, Commonwealth of Kentucky.
- C. Good standing with Public Works Act - any CONTRACTOR and/or subcontractors in violation of any wage or work act provisions (KRS 337.510 to KRS 337.550) are prohibited by Statutory Act (KRS 337.990) from bidding on or working on any and all public works contracts, either in their name or in the name of any other company, firm or other entity in which he might be interested. No bid from a prime contractor in violation of the Act can be considered, nor will any subcontractor in violation of the Act be approved and/or accepted. The responsibility for the qualifications of the subcontractor is solely that of the prime contractor.
- D. Documents Required of CONTRACTOR - (1) A sworn statement signed by the President or owner of the Company regarding all current work in progress anywhere; (2) A document showing the percent of completion of each project and the total worth of each project; and (3) Documentation showing the percentage of the DBE employment levels on each project of the Bidder's current work force, and DBE participation levels for Subcontractors.

- E. Optional OWNER Requirements - The OWNER, at its discretion, may require the BIDDER/CONTRACTOR to provide: (1) a current detailed financial statement for a period including up to 3 prior years; (2) financial security or insurance in amounts and kinds acceptable to the OWNER to meet the financial responsibility requirements for the CONTRACTOR to indemnify the OWNER. (3) Additional information and/or DBE work force data, as well as DBE participation data.
- F. The bidder, or his subcontractors, shall show previous experience with boring and jacking under CSX Railroad Tracks in the last five years. This information shall appear in the Form of Proposal, as an additional sheet attached behind Item 6. List of Proposed Subcontractors.

Each bidder agrees to waive any claim it has or may have against the Owner, the Consultant, and their respective employees, arising out of or in connection with the administration, evaluation, or recommendation of any bid.

5. BID SECURITY

- A. Each bid must be accompanied by a bid bond prepared on a Form of Bid Bond and attached hereto, duly executed by the bidder as principal and having as surety thereon a surety company approved by the OWNER, in the amount of 5% of the bid. Such bid bond will be returned to the unsuccessful bidder(s) only upon written request to the Director of Central Purchasing within seven (7) days of opening of bids. Bid bond shall be made payable to the Lexington-Fayette Urban County Government. Bid security is not required for projects under \$50,000.
- B. Bonds shall be placed with an agent licensed in Kentucky with surety authorized to do business within the state. When the premium is paid for such coverage, the full commission payable shall be paid to such local agent who shall not divide such commission with any person other than a duly licensed resident local agent.

6. LIQUIDATED DAMAGES FOR FAILURE TO ENTER INTO CONTRACT

The successful bidder, upon his failure or refusal to execute and deliver the Contract and bonds required within ten (10) days after he has received notice of the acceptance of his bid, shall forfeit to the OWNER, as liquidated damages for such failure or refusal, the security deposited with his bid.

7. TIME OF COMPLETION AND LIQUIDATED DAMAGES

Bidder must agree to commence work on or before a date to be specified in a written "Notice to Proceed" from the OWNER and to fully complete the Project within the time as specified in the Contract. Bidder must agree also to pay **\$500.00** per day as liquidated damages, or the sum as specified in the Contract for each consecutive calendar day thereafter as hereinafter provided in the General Conditions.

Further, an additional liquidated damage amount will be applied to the boring and jacking of pipework under the CSX railroad tracks. Since CSX personnel will be on-site during this time, in order to cover the cost of these personnel for an extended amount of time during the bore, a liquidated damage amount of \$4,000 per day will be applied for every day in excess of five days that CSX personnel are on-site. See the schedule of values.

8. EXAMINATION OF CONTRACT DOCUMENTS AND SITE

- A. It is the responsibility of each Bidder before submitting a Bid, to (a) examine the Contract Documents thoroughly, (b) visit the site(s) to become familiar with local conditions that may affect cost, progress, performance or furnishing of the work, (c) consider Federal, State and Local laws and regulations that may affect cost, progress, performance or furnishing of the work, (d) study and carefully correlate Bidder's observations with the Contract Documents, and (e) notify Consultant of all conflicts, errors or discrepancies in the Contract Documents.
- B. Bidders should examine the requirements of section 4 of the General Conditions for information pertaining to subsurface conditions, underground structures, underground facilities, and availability of lands, easements, and rights-of-way. The completeness of data, presented in the Contract Documents, pertaining to subsurface conditions, underground structures, and underground facilities for the purposes of bidding or construction is not assured. The Bidder will, at Bidder's own expense, make or obtain any additional examinations, investigations, explorations, tests and studies and obtain any additional information and data which pertain to the physical conditions (surface and subsurface) which may affect cost, progress, performance or furnishing of the Work and which Bidder deems necessary to determine its Bid for performing and furnishing the Work in accordance with the time, price, and other terms and conditions of the Contract Documents. On request in advance, OWNER will provide access to the site to conduct such explorations and tests as each Bidder deems necessary for submission of a bid. Bidder shall fill all holes, clean up and restore the site to its former condition upon completion of such explorations.
- C. The submission of a Bid will constitute an incontrovertible representation by the Bidder that Bidder has complied with every requirement of this paragraph 8; that without exception the Bid is premised upon furnishing and performing the Work required by the Contract Documents and such means, methods, techniques, sequences or procedures of construction as may be indicated in or required by the Contract Documents; and that the Contract Documents are sufficient in scope and detail to indicate and convey understanding of all terms and conditions for performance and furnishing of the Work.

9. ADDENDA AND INTERPRETATIONS

No interpretation of the meaning of the Contract Documents will be made to any bidder orally. Every request for such interpretation should be in writing addressed to the Director

of Central Purchasing, who in turn will have an Addendum issued for the Lexington-Fayette Urban County Government, and to be given consideration must be received prior to the date fixed for the opening of bids. Any and all such interpretations and any supplemental instructions will be in the form of written addenda to the specifications. Acknowledgement of the receipt of addenda must be included with all submitted bids. Failure of any bidder to receive any such addendum or interpretation shall not relieve such bidder from any obligation under his bid as submitted. All addenda so issued shall become part of the Contract Documents.

10. SECURITY FOR FAITHFUL PERFORMANCE

- A. Simultaneously with his delivery of the executed Contracts, the CONTRACTOR shall furnish a surety bond or bonds as security for the faithful performance of this Contract and for payment of all persons performing labor on the Project under this Contract and furnishing materials in connection with this Contract, as specified in the General Conditions. The surety on such bond or bonds shall be a duly authorized surety company satisfactory to the OWNER and authorized to do business in the Commonwealth of Kentucky.
- B. All bonds required by this Contract and laws of this State shall be placed with agents licensed in the State of Kentucky. When the premium is paid for such coverage's, the full commission shall be paid to such local agent who shall not divide such commission with any person other than a duly licensed resident local agent.
- C. **Contractor shall use standard Performance and Payment Bond forms such as documents provided with this contract book or AIA form A312-1984 (or later). Each document will be for 100% of the Contract Bid Amount.**

11. POWER OF ATTORNEY

Attorney-in-fact who signs bid bonds or contract bonds must file with each bond a certified and effectively dated copy of their power of attorney.

12. TAXES AND WORKMEN'S COMPENSATION

The CONTRACTOR and subcontractor will be required to accept liability for payment of all payroll taxes, sales and use tax, and all other taxes or deductions required by local, state or federal law, such as old age pension, social security, or annuities measured by wages. Each shall carry Workmen's Compensation Insurance to the full amounts as required by Statutes and shall include the cost of all foregoing items in the proposal. The CONTRACTOR will not otherwise be reimbursed or compensated for such tax payments. The CONTRACTOR is urged to ascertain at his own risk his actual tax liability in connection with the execution or performance of his Contract.

13. LAWS AND REGULATIONS

The bidder's attention is directed to the fact that all applicable state laws, municipal ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the Project shall apply to the Contract throughout, and they will be deemed to be included in the contract, the same as though herein written out in full.

14. EROSION AND SEDIMENT CONTROL AND PERMITS

The CONTRACTOR and Subcontractors performing work on projects on behalf of the OWNER shall also comply with all applicable federal, state, and local environmental regulations and all requirements and conditions set forth in "special" permits including but not limited to Corp of Engineers 404 permits, 401 Water Quality Certifications, Stream Crossing and Floodplain Encroachment Permits as described in Part 4 General Conditions Paragraph 5.17.

15. PREVAILING WAGE LAW AND MINIMUM HOURLY RATES

Federal or state wage rates and regulations, if required for this Project, will be as described in the Special Conditions.

16. AFFIRMATIVE ACTION PLAN

The successful Bidder must submit with their bid, the following items to the Urban County Government:

1. Affirmative Action Plan of the firm
2. Current Work Force Analysis Form
3. Good Faith Effort Documentation
4. List of Disadvantaged Business Enterprise Subcontractors and the Dollar Value of each Subcontract

A Work Force Analysis Form shall be submitted for each Contract. Failure to submit these items as required herein may result in disqualification of the Bidder from award of the Contract.

All submissions should be directed to:

Director, Division of Central Purchasing
Lexington-Fayette Urban County Government
200 East Main Street, Third Floor
Lexington, KY 40507

17. CONTRACT TIME

The number of calendar days within which the Work is to be substantially completed and ready for final payment (the Contract Time) is set forth in the Form of Proposal and the Agreement.

18. SUBSTITUTE OR "OR-EQUAL" ITEMS

The Contract, if awarded, will be on the basis of materials and equipment described in the Drawings or specified in the Specifications without consideration of possible substitute or "or-equal" items. Whenever it is indicated in the Drawings or specified in the Specifications that a substitute or "or-equal" item of material or equipment may be furnished or used by the CONTRACTOR if acceptable to the CONSULTANT and OWNER, application for such acceptance will not be considered by the CONSULTANT and OWNER until after the effective date of the Agreement. The procedure for submission of any such application by the CONTRACTOR and consideration by the CONSULTANT and OWNER is set forth in the General Conditions.

19. ALTERNATE BIDS

Bidders shall submit alternate bids/proposals only if and when such alternate bids/proposals have been specifically requested in an Invitation for Bids. If alternate bids/proposals are requested in an Invitation for Bids, the form of submission of such alternate bid and the conditions under which such alternate bids will be considered for award of a contract will be established in the Invitation.

Any Bidder who submits a bid incorporating an alternate proposal when alternate bids/proposals have not been requested in the Invitation for Bids shall have his/her bid rejected as non-responsive.

Any Bidder who submits a bid incorporating two (2) or more prices for an item or groups of items (unless such method of pricing is requested in the Invitation for Bids), or which imposes conditions for acceptance other than those established in the Invitation for Bids, shall have their bid rejected as non-responsive.

20. SIGNING OF AGREEMENT

When OWNER gives a Notice of Award to the successful Bidder, it will be accompanied by the required number of unsigned counterparts of the Agreement with all other written Contract Documents attached. Within ten days thereafter, CONTRACTOR shall sign and deliver the required number of counterparts of the Agreement and attached documents to OWNER with the required Bonds, Certificate of Insurance, and Power of Attorney. The OWNER will deliver one fully signed counterpart to CONTRACTOR at such time as it has been signed by the Mayor.

21. ASSISTANCE TO BE OFFERED TO DISADVANTAGED BUSINESS ENTERPRISE (MWDBE) CONTRACTORS

A. Outreach for MWDBE(s)

The Lexington-Fayette Urban County Government (LFUCG) maintains a database of MWDBE contractors and organizations. When a LFUCG construction project is advertised for bidding, notices are sent to companies registered at <https://lfucg.economicengine.com>. The notices describe the project and indicate the deadline for submitting bids.

If you wish to be added to the LFUCG MWDBE contractor database, please contact:

Sherita Miller, Division of Central Purchasing
Lexington-Fayette Urban County Government
200 East Main Street, Room 338
Lexington, Kentucky 40507
smiller@lexingtonky.gov

B. Bid Bond Assistance for MWDBE(s)

For those MWDBE contractors who wish to bid on LFUCG project, bid bond assistance is available. This bid bond assistance is in the form of a "Letter of Certification" which is accepted by the LFUCG's Division of Purchasing, in lieu of a bid bond. The "Letter of Certification" must be included in the bid package when it is submitted to the Division of Purchasing. The "Letter of Certification" will reference the specific project for which the bid is being submitted, and the time and date on which the bid is due. Bid bond assistance must be requested from the Lexington-Fayette Urban County Government's Division of Central Purchasing.

C. Eligibility for Bid Bond Assistance for MWDBE(s)

In order to be eligible for any Bid bonding assistance, a MWDBE construction company must be owned or controlled at the level of 51% or more by a member or members of a minority group or females. Prior to receiving assistance, a statement providing evidence of ownership and control of the company by a member or members of a minority group or females must be signed by the Owner or corporate officer and by an attorney or accountant submitted to:

Sherita Miller, Division of Central Purchasing
Lexington-Fayette Urban County Government

200 East Main Street, Room 338
Lexington, Kentucky 40507
smiller@lexingtonky.gov

D. MWDBE Subcontractors

The LFUCG will, upon request, assist prime contractors in the procurement of eligible DBE subcontractors in an effort to achieve 10% minimum MWDBE goal.

For a list of eligible subcontractors, please contact:

Sherita Miller, Division of Central Purchasing
Lexington-Fayette Urban County Government
200 East Main Street, Room 338
Lexington, Kentucky 40507
smiller@lexingtonky.gov

22. LFUCG NON-APPROPRIATION CLAUSE

Contractor acknowledges that the LFUCG is a governmental entity, and the contract validity is based upon the availability of public funding under the authority of its statutory mandate.

In the event that public funds are unavailable and not appropriated for the performance of the LFUCG's obligations under this contract, then this contract shall automatically expire without penalty to the LFUCG thirty (30) days after written notice to Contractor of the unavailability and non-appropriation of public funds. It is expressly agreed that the LFUCG shall not activate this non-appropriation provision for its convenience or to circumvent the requirements of this contract, but only as an emergency fiscal measure during a substantial fiscal crisis, which affects generally its governmental operations.

In the event of a change in the LFUCG's statutory authority, mandate and mandated functions, by state and federal legislative or regulatory action, which adversely affects the LFUCG's authority to continue its obligations under this contract, then this contract shall automatically terminate without penalty to the LFUCG upon written notice to Contractor of such limitation or change in the LFUCG's legal authority.

PART III
FORM OF PROPOSAL

INDEX

1.	FORM OF PROPOSAL	P-2
2.	LEGAL STATUS OF BIDDER.....	P-4
3.	BIDDERS AFFIDAVIT	P-5
4.	BID SCHEDULE – SCHEDULE OF VALUES	P-9
5.	STATEMENT OF BIDDER'S QUALIFICATIONS	P-12
6.	LIST OF PROPOSED SUBCONTRACTORS	P-13
7.	LEXINGTON FAYETTE URBAN COUNTY GOVERNMENT MWD BE PARTICIPATION GOALS, FORMS, AND GOOD FAITH EFFORTS	P-25
8.	AUTHENTICATION OF BID AND STATEMENT OF NON-COLLUSION AND NON-CONFLICT OF INTEREST.....	P-26
9.	STATEMENT OF EXPERIENCE.....	P-28
10.	EQUAL OPPORTUNITY AGREEMENT.....	P-31
11.	EQUAL EMPLOYMENT OPPORTUNITY AFFIRMATIVE ACTION POLICY	P-32
12.	WORKFORCE ANALYSIS	P-33
13.	EVIDENCE OF INSURABILITY	P-34
14.	DEBARRED FIRMS.....	P-38
15.	DEBARRED CERTIFICATION	P-35

PART III

Invitation to Bid No. 21-2016

Haley Pike Landfill Forcemain

1. FORM OF PROPOSAL

Place: Lexington, Kentucky

Date: _____

The following Form of Proposal shall be followed exactly in submitting a proposal for this Work.

This Proposal Submitted by _____

(Name and Address of Bidding Contractor)

(Hereinafter called "Bidder"), organized and existing under the laws of the State of _____, doing business as _____
_____ "a corporation," "a partnership", or an "individual" as applicable.

To: Lexington-Fayette Urban County Government
(Hereinafter called "OWNER")
Office of the Director of Purchasing
200 East Main Street, 3rd Floor
Lexington, KY 40507

Gentlemen:

The Bidder, in compliance with your Invitation for Bids for **Haley Pike Landfill Forcemain** having examined the Plans and Specifications with related documents, having examined the site for proposed Work, and being familiar with all of the conditions surrounding the construction of the proposed Project, including the availability of materials and labor, hereby proposes to furnish all labor, materials, and supplies, and to construct the Project in accordance with the Contract Documents, within the time set forth therein, and at the lump sum and/or unit prices stated hereinafter. These prices are to cover all expenses incurred in performing the Work required under the Contract Documents, of which this proposal is a part. The OWNER will issue work orders for work to be performed under this Contract.

BIDDER hereby agrees to commence work under this contract on or before a date to be specified in the Notice to Proceed and to fully complete the project within the time provided in the

Purchase Order or Work Orders issued by the OWNER. BIDDER further agrees to pay liquidated damages, the sum of \$500.00 for each consecutive calendar day thereafter.

The Bidder hereby acknowledges receipt of the following addenda:

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Addendum No. ____ Date _____

Insert above the number and the date of any Addendum issued and received. If none has been issued and received, the word "NONE" should be inserted.

2. **LEGAL STATUS OF BIDDER**

Bidder _____

Date _____

* 1. A corporation duly organized and doing business under the laws of the State of _____, for whom _____, bearing the official title of _____, whose signature is affixed to this Bid/Proposal, is duly authorized to execute contracts.

* 2. A Partnership, all of the members of which, with addresses are: (Designate general partners as such)

* 3. An individual, whose signature is affixed to this Bid/Proposal (please print name)

*(The Bidder shall fill out the appropriate form and strike out the other two.)

3. **BIDDERS AFFIDAVIT**

Comes the Affiant, _____, and after being first duly sworn, states under penalty of perjury as follows:

1. His/her name is _____ and he/she is the individual submitting the bid or is the authorized representative of _____, the entity submitting the bid (hereinafter referred to as "Bidder").
2. Bidder will pay all taxes and fees, which are owed to the Lexington-Fayette Urban County Government at the time the bid is submitted, prior to award of the contract and will maintain a "current" status in regard to those taxes and fees during the life of the contract.
3. Bidder will obtain a Lexington-Fayette Urban County Government business license, if applicable, prior to award of the contract.
4. Bidder has authorized the Division of Central Purchasing to verify the above-mentioned information with the Division of Revenue and to disclose to the Urban County Council that taxes and/or fees are delinquent or that a business license has not been obtained.
5. Bidder has not knowingly violated any provision of the campaign finance laws of the Commonwealth of Kentucky within the past five (5) years and the award of a contract to the Bidder will not violate any provision of the campaign finance laws of the Commonwealth.
6. Bidder has not knowingly violated any provision of Chapter 25 of the Lexington-Fayette Urban County Government Code of Ordinances, known as the "Ethics Act."
7. Bidder acknowledges that "knowingly" for purposes of this Affidavit means, with respect to conduct or to circumstances described by a statute or ordinance defining an offense, that a person is aware or should have been aware that his conduct is of that nature or that the circumstance exists.
Further, Affiant sayeth naught.

(Affiant)

STATE OF _____

COUNTY OF _____

The foregoing instrument was subscribed, sworn to and acknowledged before me by

_____ on this the _____ day of _____, 20____.

My Commission expires: _____

NOTARY PUBLIC, STATE AT LARGE

4. **BID SCHEDULE – SCHEDULE OF VALUES**

The Bidder agrees to perform all the Work described in the Specifications and shown on the Plans for the following proposed lump sum and/or unit prices, if applicable, which shall include the furnishing of all labor, materials, supplies, equipment and/or vehicle usage, services, all items of cost, overhead, taxes (federal, state, local), and profit for the Contractor and any Subcontractor involved, within the time set forth herein. If unit prices are applicable, Bidder must make the extensions and additions showing the total amount of bid.

Form of proposal must include unit bid prices written in words, unit price written in numbers and total amount bid (unit price x quantity) per line item OR bid may be considered non-responsive. In case of price discrepancy, unit bid price written in words will prevail followed by unit price written in numbers then total amount bid per line item.

If a discrepancy between the unit price and the item total exists, the unit price prevails except:

If the unit price is illegible, omitted, or the same as the item total, item total prevails and the unit price is the quotient of the item total and the quantity.

If the unit price and the item total are illegible or are omitted, the bid may be determined nonresponsive. If a lump sum total price is illegible or is omitted, the bid may be determined nonresponsive.

For a lump sum based bid, the item total is the bid amount the Division uses for bid comparison.

For a unit price based bid, the sum of the item totals is the bid amount the Division uses for bid comparison.

The LFUCG's decision on the bid amount is final.

ITEM NO.	ITEM	QUANTITY	UNIT	UNIT PRICE	TOTAL
Division "A" 6-Inch Force Main					
1	6-Inch Class 250 (SDR 17) HDPE Pipe, Furnishing, Trenching, Bedding, Laying and Backfilling, Tracer Wire, Unclassified Excavation, Complete	3,000	L.F.	\$ _____	\$ _____
2	6-Inch Class 250 (SDR 17) PVC Pipe, Furnishing, Trenching, Bedding, Laying and Backfilling, Tracer Wire, Unclassified Excavation, Complete	164	L.F.	\$ _____	\$ _____
3	6-Inch Mechanical Joint Resilient Seated Gate Valve and Box, Including Concrete Collar, Complete	5	Each	\$ _____	\$ _____
4	Automatic Air Release Valve Assembly, Furnish and Install, Complete per Detail	3	Each	\$ _____	\$ _____
5	Fiberglass Line Marker, Furnish and Install, Complete	10	Each	\$ _____	\$ _____
6	Cut and Tie Into Existing 6-Inch Force Main, Including Fittings, PVC to PE Transition, Complete	1	Each	\$ _____	\$ _____
7	Connect to Existing HDPE Irrigation Piping	1	Each	\$ _____	\$ _____
8	Remove and Reinstall New CMP Drainage Pipe Including Bedding and Backfill, Concrete Encase Force Main per Plans, Complete	35	L.F.	\$ _____	\$ _____
9	Extra for Crushed Rock for Trench Stabilization, Only on Order of the Engineer	20	Ton	\$ _____	\$ _____
Subtotal Division "A"					\$ _____
Division "B" Railroad Bore and Jack					
1	6-Inch Class 250 (SDR 17) PVC Pipe, Furnishing, Trenching, Bedding, Laying and Backfilling, Tracer Wire, Unclassified Excavation, Complete	100	L.F.	\$ _____	\$ _____
2	Boring and Jacking for 12" x 0.25 Steel Cover Pipe, Unclassified Excavation	100	L.F.	\$ _____	\$ _____
3	12-Inch x 0.250 Inch Steel Cover Pipe, Including Casing Spacers and End Seals, Furnish and Install, Complete (by open cut or boring)	100	Each	\$ _____	\$ _____
Subtotal Division "B"					\$ _____
TOTAL LFUCG CONTRACT 21-2016					\$ _____

Note: For each additional day over five days that CSX/RJ Corman personnel are on site, in connection with the Contractor's work on this project, a liquidated damage amount of \$4,000.00 per day will be assessed against the Contractor.

TOTAL OF ALL BID PRICES FOR Haley Pike Landfill Force Main Project (Item 1) in words and figures.
In case of discrepancy, the amount shown in words will govern.

_____ (\$ _____).

Submitted by:

Firm

Address

City, State & Zip

***Bid must be signed:
(original signature)***

Signature of Authorized Company Representative – Title

Representative/s Name (Typed or Printed)

Area Code – Phone – Extension

Fax #

E-Mail Address

OFFICIAL ADDRESS:

_____ (Seal if Bid is by Corporation)

By signing this form you agree to ALL terms, conditions, and associated forms in this bid package

5. **STATEMENT OF BIDDER'S QUALIFICATIONS**

The following statement of the Bidder's qualifications is required to be filled in, executed, and submitted with the Proposal:

1. Name of Bidder: _____
2. Permanent Place of Business: _____
3. When Organized: _____
4. Where Incorporated: _____
5. Construction Plant and Equipment Available for this Project:

(Attach Separate Sheet If Necessary)

6. Financial Condition:

If specifically requested by the OWNER, the apparent low Bidder is required to submit its latest three (3) years audited financial statements to the OWNER'S Division of Central Purchasing within seven (7) calendar days following the bid opening.

7. In the event the Contract is awarded to the undersigned, surety bonds will be furnished by:

_____ (Surety)

Signed: _____ (Representative of Surety)

8. The following is a list of similar projects performed by the Bidder: (Attach separate sheet if necessary).

<u>NAME</u>	<u>LOCATION</u>	<u>CONTRACT SUM</u>

9. The Bidder has now under contract and bonded the following projects:

<u>NAME</u>	<u>LOCATION</u>	<u>CONTRACT SUM</u>

10. List Key Bidder Personnel who will work on this Project.

<u>NAME</u>	<u>POSITION DESCRIPTION</u>	<u>NO. OF YEARS WITH BIDDER</u>

11. DBE Participation on current bonded projects under contract:

<u>SUBCONTRACTORS</u> <u>(LIST)</u>	<u>PROJECT</u> <u>(SPECIFIC TYPE)</u>	<u>DBE</u>	<u>% of WORK</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

(USE ADDITIONAL SHEETS IF NECESSARY)

12. We acknowledge that, if we are the apparent low Bidder, we may be required to submit to the OWNER within 7 calendar days following the Bid Opening, a sworn statement regarding all current work on hand and under contract, and a statement on the OWNER'S form of the experience of our officers, office management and field management personnel. Additionally, if requested by the OWNER, we will within 7 days following the request submit audited financial statements and loss history for insurance claims for the 3 most recent years (or a lesser period stipulated by the OWNER).

6. **LIST OF PROPOSED SUBCONTRACTORS**

The following list of proposed subcontractors is required by the OWNER to be executed, completed and submitted with the BIDDER'S FORM OF PROPOSAL. All subcontractors are subject to approval of the Lexington-Fayette Urban County Government. Failure to submit this list completely filled out may be cause for rejection of bid.

<u>BRANCH OF WORK - LIST EACH MAJOR ITEM</u> Such as: Grading, Boring and jacking under railroad, concrete, seeding and protection, etc.	<u>SUBCONTRACTOR</u>	<u>DBE</u> <u>Yes/No</u>	% of Work
1. _____	Name: _____ Address: _____	_____	_____
2. _____	Name: _____ Address: _____	_____	_____
3. _____	Name: _____ Address: _____	_____	_____
4. _____	Name: _____ Address: _____	_____	_____
5. _____	Name: _____ Address: _____	_____	_____
6. _____	Name: _____ Address: _____	_____	_____
7. _____	Name: _____ Address: _____	_____	_____

(Attach additional sheet(s) if necessary.)

7. **LEXINGTON FAYETTE URBAN COUNTY GOVERNMENT MWDBE PARTICIPATION GOALS, FORMS, AND GOOD FAITH EFFORTS**

A. GENERAL

- 1) The LFUCG request all potential contractors to make a concerted effort to include Minority-Owned (MBE), Woman-Owned (WBE) and Disadvantaged (DBE) Business Enterprises as subcontractors or suppliers in their bids.
- 2) Toward that end, the LFUCG has established 10% of total procurement costs as a Goal for participation of Minority-Owned, Woman-Owned and Disadvantaged Businesses on this contract.
- 3) **It is therefore a request of each Bidder to include in its bid, the same goal (10%) for MWDBE participation and other requirements as outlined in this section.**

B. PROCEDURES

- 1) The successful bidder will be required to report to the LFUCG, the dollar amounts of all payments submitted to Minority-Owned or Woman-Owned subcontractors and suppliers for work done or materials purchased for this contract. (See Subcontractor Monthly Payment Report)
- 2) Replacement of a Minority-Owned or Woman-Owned subcontractor or supplier listed in the original submittal must be requested in writing and must be accompanied by documentation of Good Faith Efforts to replace the subcontractor / supplier with another MWDBE Firm; this is subject to approval by the LFUCG. (See LFUCG MWDBE Substitution Form)
- 3) For assistance in identifying qualified, certified businesses to solicit for potential contracting opportunities, bidders may contact:
 - a) The Lexington-Fayette Urban County Government, Division of Central Purchasing (859-258-3320)
- 4) The LFUCG will make every effort to notify interested MWDBE subcontractors and suppliers of each Bid Package, including information on the scope of work, the pre-bid meeting time and location, the bid date, and all other pertinent information regarding the project.

C. DEFINITIONS

- 1) A Minority-Owned Business Enterprise (MBE) is defined as a business which is certified as being at least 51% owned and operated by persons of African American, Hispanic, Asian, Pacific Islander, American Indian or Alaskan Native Heritage.
- 2) A Woman-Owned Business Enterprise (WBE) is defined as a business which is certified as being at least 51% owned and operated by one or more Non-Minority Females.

- 3) A Disadvantaged Business (DBE) is defined as a business which is certified as being at least 51% owned and operated by a person(s) that are economically and socially disadvantaged.
- 4) Good Faith Efforts are efforts that, given all relevant circumstances, a bidder or proposer actively and aggressively seeking to meet the goals, can reasonably be expected to make. In evaluating good faith efforts made toward achieving the goals, whether the bidder or proposer has performed the efforts outlined in the Obligations of Bidder for Good Faith Efforts outlined in this document will be considered, along with any other relevant factors.

D. OBLIGATION OF BIDDER FOR GOOD FAITH EFFORTS

- 1) **The bidder shall make a Good Faith Effort to achieve the Participation Goal for MWDBE subcontractors/suppliers. The failure to meet the goal shall not necessarily be cause for disqualification of the bidder; however, bidders not meeting the goal are required to furnish with their bids written documentation of their Good Faith Efforts to do so.**
- 2) Award of Contract shall be conditioned upon satisfaction of the requirements set forth herein.
- 3) The Form of Proposal includes a section entitled "MWDBE Participation Form". The applicable information must be completed and submitted as outlined below.
- 4) **Failure to submit this information as requested may be cause for rejection of bid.**

E. DOCUMENTATION REQUIRED FOR GOOD FAITH EFFORTS

- 1) Bidders reaching the Goal are required to submit only the MWDBE Participation Form." The form must be fully completed including names and telephone number of participating MWDBE firm(s); type of work to be performed; estimated value of the contract and value expressed as a percentage of the total Lump Sum Bid Price. The form must be signed and dated, and is to be submitted with the bid.
- 2) Bidders not reaching the Goal must submit the "MWDBE Participation Form", the "Quote Summary Form" and a written statement documenting their Good Faith Effort to do so. If bid includes no MWDBE participation, bidder shall enter "None" on the subcontractor / supplier form). In addition, the bidder must submit written proof of their Good Faith Efforts to meet the Participation Goal:
 - a. Advertised opportunities to participate in the contract in at least two (2) publications of general circulation media; trade and professional association publications; small and minority business or trade publications; and publications or trades targeting minority, women and disadvantaged businesses not less than fifteen (15) days prior to the deadline for submission of bids to allow MWDBE firms to participate.
 - b. Included documentation of advertising in the above publications with the bidders good faith efforts package

- c. Attended LFUCG Central Purchasing Economic Inclusion Outreach event
- d. Attended pre-bid meetings that were scheduled by LFUCG to inform MWDBEs of subcontracting opportunities
- e. Sponsored Economic Inclusion event to provide networking opportunities for prime contractors and MWDBE firms
- f. Requested a list of MWDBE subcontractors or suppliers from LFUCG Economic Engine and showed evidence of contacting the companies on the list(s).
- g. Contacted organizations that work with MWDBE companies for assistance in finding certified MWDBE firms to work on this project. Those contacted and their responses should be a part of the bidder's good faith efforts documentation.
- h. Sent written notices, by certified mail, email or facsimile, to qualified, certified MWDBEs soliciting their participation in the contract not less than seven (7) days prior to the deadline for submission of bids to allow them to participate effectively.
- i. Followed up initial solicitations by contacting MWDBEs to determine their level of interest.
- j. Provided the interested MWDBE firm with adequate and timely information about the plans, specifications, and requirements of the contract.
- k. Selected portions of the work to be performed by MWDBE firms in order to increase the likelihood of meeting the contract goals. This includes, where appropriate, breaking out contract work items into economically feasible units to facilitate MWDBE participation, even when the prime contractor may otherwise perform these work items with its own workforce
- l. Negotiated in good faith with interested MWDBE firms not rejecting them as unqualified without sound reasons based on a thorough investigation of their capabilities. Any rejection should be so noted in writing with a description as to why an agreement could not be reached.
- m. Included documentation of quotations received from interested MWDBE firms which were not used due to uncompetitive pricing or were rejected as unacceptable and/or copies of responses from firms indicating that they would not be submitting a bid.
- n. Bidder has to submit sound reasons why the quotations were considered unacceptable. The fact that the bidder has the ability and/or desire to perform the contract work with its own forces will not be considered a sound reason for rejecting a

MWDBE quote. Nothing in this provision shall be construed to require the bidder to accept unreasonable quotes in order to satisfy MWDBE goals.

o. Made an effort to offer assistance to or refer interested MWDBE firms to obtain the necessary equipment, supplies, materials, insurance and/or bonding to satisfy the work requirements of the bid proposal

p. Made efforts to expand the search for MWBE firms beyond the usual geographic boundaries.

q. Other--any other evidence that the bidder submits which may show that the bidder has made reasonable good faith efforts to include MWDBE participation.

Failure to submit any of the documentation requested in this section may be cause for rejection of bid. Bidders may include any other documentation deemed relevant to this requirement. Documentation of Good Faith Efforts are to be submitted with the Bid, if the participation Goal is not met.



MINORITY BUSINESS ENTERPRISE PROGRAM

Sherita Miller
Minority Business Enterprise Liaison
Division of Central Purchasing
Lexington-Fayette Urban County Government
200 East Main Street
Lexington, KY 40507
smiller@lexingtonky.gov
859-258-3323

OUR MISSION: The mission of the Minority Business Enterprise Program is to facilitate the full participation of minority and women owned businesses in the procurement process and to promote economic inclusion as a business imperative essential to the long term economic viability of Lexington-Fayette Urban County Government.

To that end the city council adopted and implemented resolution 167-91—Disadvantaged Business Enterprise (DBE) 10% Goal Plan in July of 1991. The resolution states in part (a full copy is available in Central Purchasing):

“A Resolution supporting adoption of the administrative plan for a ten percent (10%) Minimum goal for disadvantaged business enterprise participation in Lexington-Fayette Urban County Government construction and professional services contracts; Providing that as part of their bids on LFUCG construction contracts, general Contractors shall make a good faith effort to award at least ten percent (10%) of All subcontracts to disadvantaged business enterprises; providing that divisions of LFUCG shall make a good faith effort to award at least ten percent of their Professional services and other contracts to disadvantaged business enterprises...”

A Disadvantaged Business Enterprise is defined as a business that has been certified as being at least 51% owned, operated and managed by a U.S. Citizen of the following groups:

- African-American
- Hispanic-American
- Asian/Pacific Islander
- Native American/Native Alaskan
- Non-Minority Female
- Economically and Socially Disadvantaged

We have compiled the list below to help you locate certified MBE, WBE and DBE certified businesses. Below is a listing of contacts for LFUCG Certified MWDBEs in Economic Engine (<https://lfucg.economicengine.com>)

Business	Contact	Email Address	Phone
LFUCG	Sherita Miller	smiller@lexingtonky.gov	859-258-3323
Commerce Lexington – Minority Business Development	Tyrone Tyra	ttyra@commercelexington.com	859-226-1625
Tri-State Minority Supplier Diversity Council	Sonya Brown	sbrown@tsmsdc.com	502-625-0137
Small Business Development Council	Dee Dee Harbut UK SBDC	ddharbut@uky.edu	
	Shiree Mack	smack@uky.edu	
Community Ventures Corporation	James Coles	jcoles@cyckv.org	859-231-0054
KY Department of Transportation	Melvin Bynes	Melvin.bynes@ky.gov	502-564-3601
	Shella Eagle	Shella.Eagle@ky.gov	502-564-3601
Ohio River Valley Women’s Business Council (WBENC)	Rea Waldon	rwaldon@gcul.org	513-487-6534
Kentucky MWBE Certification Program	Yvette Smith, Kentucky Finance Cabinet	Yvette.Smith@ky.gov	502-564-8099
National Women Business Owner’s Council (NWBOC)	Janet Harris-Lange	janet@nwbo.org	800-675-5066
Small Business Administration	Robert Coffey	robertcoffey@sba.gov	502-582-5971
LaVoz de Kentucky	Andres Cruz	lavozdeky@yahoo.com	859-621-2106
The Key News Journal	Patrice Muhammad	paatricem@keynewsjournal.com	859-373-9428



LFUCG MWDBE PARTICIPATION FORM
 Bid/RFP/Quote Reference # _____

The MWDBE subcontractors listed have agreed to participate on this Bid/RFP/Quote. If any substitution is made or the total value of the work is changed prior to or after the job is in progress, it is understood that those substitutions must be submitted to Central Purchasing for approval immediately.

MWDBE Company, Name, Address, Phone, Email	Work to be Performed	Total Dollar Value of the Work	% Value of Total Contract
1.			
2.			
3.			
4.			

The undersigned company representative submits the above list of MWDBE firms to be used in accomplishing the work contained in this Bid/RFP/Quote. Any misrepresentation may result in the termination of the contract and/or be subject to applicable Federal and State laws concerning false statements and false claims.

 Company

 Company Representative

 Date

 Title



LFUCG MWDBE SUBSTITUTION FORM

Bid/RFP/Quote Reference # _____

The substituted MWDBE subcontractors listed below have agreed to participate on this Bid/RFP/Quote. These substitutions were made prior to or after the job was in progress. These substitutions were made for reasons stated below and are now being submitted to Central Purchasing for approval. By the authorized signature of a representative of our company, we understand that this information will be entered into our file for this project.

SUBSTITUTED MWDBE Company Name, Address, Phone, Email	MWDBE Formally Contracted/ Name, Address, Phone, Email	Work to Be Performed	Reason for the Substitution	Total Dollar Value of the Work	% Value of Total Contract
1.					
2.					
3.					
4.					

The undersigned acknowledges that any misrepresentation may result in termination of the contract and/or be subject to applicable Federal and State laws concerning false statements and false claims.

Company

Company Representative

Date

Title



MWDBE QUOTE SUMMARY FORM

Bid/RFP/Quote Reference # _____

The undersigned acknowledges that the minority subcontractors listed on this form did submit a quote to participate on this project.

Company Name	Contact Person
Address/Phone/Email	Bid Package / Bid Date

MWDBE Company Address	Contact Person	Contact Information (work phone, Email, cell)	Date Contacted	Services to be performed	Method of Communication (email, phone meeting, ad, event etc)	Total dollars \$\$ Do Not Leave Blank (Attach Documentation)	MBE * AA HA AS NA Female

(MBE designation / AA=African American / HA= Hispanic American/AS = Asian American/Pacific Islander/ NA= Native American)

The undersigned acknowledges that all information is accurate. Any misrepresentation may result in termination of the contract and/or be subject to applicable Federal and State laws concerning false statements and claims.

Company

Company Representative

Date

Title



LFUCG SUBCONTRACTOR MONTHLY PAYMENT REPORT

The LFUCG has a 10% goal plan adopted by city council to increase the participation of minority and women owned businesses in the procurement process. In order to measure that goal LFUCG will track spending with MWDBE vendors on a monthly basis. By the signature below of an authorized company representative, you certify that the information is correct, and that each of the representations set forth below is true. Any misrepresentation may result in termination of the contract and/or prosecution under applicable Federal and State laws concerning false statements and false claims. Please submit this form monthly to the Division of Central Purchasing/ 200 East Main Street / Room 338 / Lexington, KY 40507.

Bid/RFP/Quote # _____

Total Contract Amount Awarded to Prime Contractor for this Project _____

Project Name/ Contract #	Work Period/ From: _____ To: _____
Company Name:	Address:
Federal Tax ID:	Contact Person:

Subcontractor Vendor ID (name, address, phone, email)	Description of Work	Total Subcontract Amount	% of Total Contract Awarded to Prime for this Project	Total Amount Paid for this Period	Purchase Order number for subcontractor work (please attach PO)	Scheduled Project Start Date	Scheduled Project End Date

By the signature below of an authorized company representative, you certify that the information is correct, and that each of the representations set forth below is true. Any misrepresentations may result in the termination of the contract and/or prosecution under applicable Federal and State laws concerning false statements and false claims.

Company

Company Representative

Date

Title

LFUCG STATEMENT OF GOOD FAITH EFFORTS

Bid/RFP/Quote # _____

By the signature below of an authorized company representative, we certify that we have utilized the following Good Faith Efforts to obtain the maximum participation by MWDBE business enterprises on the project and can supply the appropriate documentation.

- _____ Advertised opportunities to participate in the contract in at least two (2) publications of general circulation media; trade and professional association publications; small and minority business or trade publications; and publications or trades targeting minority, women and disadvantaged businesses not less than fifteen (15) days prior to the deadline for submission of bids to allow MWDBE firms to participate.
- _____ Included documentation of advertising in the above publications with the bidders good faith efforts package
- _____ Attended LFUCG Central Purchasing Economic Inclusion Outreach event
- _____ Attended pre-bid meetings that were scheduled by LFUCG to inform MWDBEs of subcontracting opportunities
- _____ Sponsored Economic Inclusion event to provide networking opportunities for prime contractors and MWDBE firms
- _____ Requested a list of MWDBE subcontractors or suppliers from LFUCG Economic Engine and showed evidence of contacting the companies on the list(s).
- _____ Contacted organizations that work with MWDBE companies for assistance in finding certified MWDBE firms to work on this project. Those contacted and their responses should be a part of the bidder's good faith efforts documentation.
- _____ Sent written notices, by certified mail, email or facsimile, to qualified, certified MWDBEs soliciting their participation in the contract not less than seven (7) days prior to the deadline for submission of bids to allow them to participate effectively.
- _____ Followed up initial solicitations by contacting MWDBEs to determine their level of interest.
- _____ Provided the interested MWDBE firm with adequate and timely information about the plans, specifications, and requirements of the contract.
- _____ Selected portions of the work to be performed by MWDBE firms in order to increase the likelihood of meeting the contract goals. This includes, where appropriate, breaking out contract work items into economically feasible units to facilitate MWDBE participation, even when the prime contractor may otherwise perform these work items with its own workforce

- _____ Negotiated in good faith with interested MWDBE firms not rejecting them as unqualified without sound reasons based on a thorough investigation of their capabilities. Any rejection should be so noted in writing with a description as to why an agreement could not be reached.
- _____ Included documentation of quotations received from interested MWDBE firms which were not used due to uncompetitive pricing or were rejected as unacceptable and/or copies of responses from firms indicating that they would not be submitting a bid.
- _____ Bidder has to submit sound reasons why the quotations were considered unacceptable. The fact that the bidder has the ability and/or desire to perform the contract work with its own forces will not be considered a sound reason for rejecting a MWDBE quote. Nothing in this provision shall be construed to require the bidder to accept unreasonable quotes in order to satisfy MWDBE goals.
- _____ Made an effort to offer assistance to or refer interested MWDBE firms to obtain the necessary equipment, supplies, materials, insurance and/or bonding to satisfy the work requirements of the bid proposal
- _____ Made efforts to expand the search for MWDBE firms beyond the usual geographic boundaries.
- _____ Other - any other evidence that the bidder submits which may show that the bidder has made reasonable good faith efforts to include MWDBE participation.

Failure to submit any of the documentation requested in this section may be cause for rejection of bid. Bidders may include any other documentation deemed relevant to this requirement. Documentation of Good Faith Efforts are to be submitted with the Bid, if the participation Goal is not met.

The undersigned acknowledges that all information is accurate. Any misrepresentations may result in termination of the contract and/or be subject to applicable Federal and State laws concerning false statements and claims.

Company

Company Representative

Date

Title

8. **AUTHENTICATION OF BID AND STATEMENT OF NON-COLLUSION, NON-CONFLICT OF INTEREST**

I hereby swear (or affirm) under the penalty for false swearing:

1. That I am the Bidder (if the Bidder is an individual), a partner of the Bidder (if the Bidder is a partnership), or an officer or employee of the bidding corporation having authority to sign on its behalf (if the Bidder is a corporation);
2. That the attached bid has been arrived at by the Bidder independently, and has been submitted without collusion with, and without any agreement, understanding or planned common course of action, with any other contractor, vendor of materials, supplies, equipment or services described in the Invitation to Bid, designed to limit independent bidding or competition;
3. That the contents of the bid or bids have not been communicated by the Bidder or its employees or agents to any person not an employee or agent of the Bidder or its surety on any bond furnished, with the bid or bids, and will not be communicated to any such person, prior to the official opening of the bid or bids;
4. That the Bidder is legally entitled to enter into the contracts with the Lexington-Fayette Urban County Government, and is not in violation of any prohibited conflict of interest;
5. (Applicable to corporation only) That as a foreign corporation, we are registered with the Secretary of State, Commonwealth of Kentucky, and authorized to do business in the State _____ or, that as a domestic corporation, we are in good standing with the Secretary of State, Commonwealth of Kentucky _____. Check the statement applicable.
6. This offer is for 60 calendar days from the date this bid is opened. In submitting the above, it is expressly agreed that, upon proper acceptance by the Lexington-Fayette Urban County Government of any or all items bid above, a contract shall thereby be created with respect to the items accepted.
7. That I have fully informed myself regarding the accuracy of the statements made in this statement.
8. That I certify that Subcontractors have not and will not be awarded to any firm(s) that have been debarred from noncompliance with the Federal Labor Standards, Title VI of the Civil Rights Act of 1964 As Amended, Executive Order 11246 As Amended or any other Federal Law.

9. **STATEMENT OF EXPERIENCE**

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

NAME OF INDIVIDUAL: _____

POSITION/TITLE: _____

STATEMENT OF EXPERIENCE: _____

* Include all officers, office management's, Affirmative Action officials, and field management personnel. (Attach separate sheets if necessary.)

10. EQUAL OPPORTUNITY AGREEMENT

The Law

- * Title VII of the Civil Rights Act of 1964 (amended 1972) states that it is unlawful for an employer to discriminate in employment because of race, color, religion, sex, age (40-70 years) or national origin.
- * Executive Order No. 11246 on Nondiscrimination under Federal contract prohibits employment discrimination by contractor and subcontractor doing business with the Federal Government or recipients of Federal funds. This order was later amended by Executive Order No. 11375 to prohibit discrimination on the basis of sex.
- * Section 503 of the Rehabilitation Act of 1973 States:

The Contractor will not discriminate against any employee or applicant for employment because of physical or mental handicap.

- * Section 2012 of the Vietnam Era Veterans Readjustment Act of 1973 requires Affirmative Action on behalf of disabled veterans and veterans of the Vietnam Era by contractors having Federal Contracts.
- * Section 206 (A) of Executive Order 12086, Consolidation of Contract Compliance Functions for Equal Employment Opportunity, states:

The Secretary of Labor may investigate the employment practices of any Government contractor or sub-contractor to determine whether or not the contractual provisions specified in Section 202 of this order have been violated.

The Lexington-Fayette Urban County Government practices Equal Opportunity in recruiting, hiring and promoting. It is the Government's intent to affirmatively provide employment opportunities for those individuals who have previously not been allowed to enter into the mainstream of society. Because of its importance to the local Government, this policy carries the full endorsement of the Mayor, Commissioners, Directors, and all supervisory personnel. In following this commitment to Equal Employment Opportunity and because the Government is the benefactor of the Federal funds, it is both against the Urban County Government policy and illegal for the Government to let contracts to companies which knowingly or unknowingly practice discrimination in their employment practices. Violation of the above mentioned ordinances may cause a contract to be canceled and the contractor may be declared ineligible for future consideration.

Please sign this statement in the appropriate space acknowledging that you have read and understand the provisions contained herein. Return this document as part of your application packet.

Bidders

I/We agree to comply with the Civil Rights Laws listed above that govern employment rights of minorities, women, Vietnam veterans, handicapped, and aged persons.

Signature

Name of Business

The Entity (regardless of whether construction contractor, non-construction contractor or supplier) agrees to provide equal opportunity in employment for all qualified persons, to prohibit discrimination in employment because of race, color, creed, national origin, sex or age, and to promote equal employment through a positive, continuing program from itself and each of its sub-contracting agents. This program of equal employment opportunity shall apply to every aspect of its employment policies and practices.

The Kentucky equal Employment Opportunity Act of 1978 (KRS 45.560-45.640) requires that any count, city, town, school district, water district, hospital district, or other political subdivision of the state shall include in directly or indirectly publicly funded contracts for supplies, materials, services, or equipment hereinafter entered into the following provisions:

During the performance of this contract, the contractor agrees as follows:

- (1) *The contractor will not discriminate against any employee or applicant for employment because of race, color, religion, sex, age or national origin;*
- (2) *The contractor will state in all solicitations or advertisements for employees placed by or on behalf of the contractors that all qualified applicants will receive consideration for employment without regard to race, color, religion, sex, age or national origin;*
- (3) *The contract will post notices in conspicuous places, available to employees and applicants for employment, setting forth the provisions of the non-discrimination clauses required by this section; and*
- (4) *The contractor will send a notice to each labor union or representative of workers with which he has a collective bargaining agreement or other contract or understanding advising the labor union or workers' representative of the contractor's commitments under the nondiscrimination clauses.*

The Act further provides:

KRS 45.610. Hiring minorities – Information required

- (1) *For the length of the contract, each contractor shall hire minorities from other sources within the drawing area, should the union with which he has collective bargaining agreements be unwilling to supply sufficient minorities to satisfy the agreed upon goals and timetable.*
- (2) *Each contractor shall, for the length of the contract, furnish such information as required by KRS 45.560 to KRS 45.640 and by such rules, regulations and orders issued pursuant thereto and will permit access to all books and records pertaining to his employment practices and work sites by the contracting agency and the department for purposes of investigation to ascertain compliance with KRS 45.560 to 45.640 and such rules, regulations and orders issued pursuant thereto.*

KRS 45.620. Action against contractor – Hiring of minority contractor or subcontractor

- (1) *If any contractor is found by the department to have engaged in an unlawful practice under this chapter during the course of performing under a contract or subcontract covered under KRS 45.560 to 45.640, the department shall so certify to the contracting agency and such certification shall be binding upon the contracting agency unless it is reversed in the course of judicial review.*
- (2) *If the contractor is found to have committed an unlawful practice under KRS 45.560 to 45.640, the contracting agency may cancel or terminate the contract, conditioned upon a program for future compliance approved by the contracting agency and the department. The contracting agency may declare such a contractor ineligible to bid on further contracts with that agency until such time as the contractor complies in full with the requirements of KRS 45.560 – 45.640.*
- (3) *The equal employment provisions of KRS 45.560 to 45.640 may be met in part by a contractor by subcontracting to a minority contractor or subcontractor. For the provisions of KRS 45.560 to 45.640, a minority contractor or subcontractor shall mean a business that is owned and controlled by one or more persons disadvantaged by racial or ethnic circumstances.*

KRS 45.630 Termination of existing employee not required, when

Any provision of KRS 45.560 to 45.640 notwithstanding, no contractor shall be required to terminate an existing employee upon proof that that employee was employed prior to the date of the contract.

KRS 45.640 Minimum skills

Nothing in KRS 45.560 to 45.640 shall require a contractor to hire anyone who fails to demonstrate the minimum skills required to perform a particular job.

It is recommended that all of the provisions quoted above to be included as special conditions in each contract. In the case of a contract exceeding \$250,000, the contractor is required to furnish evidence that his work-force in Kentucky is representative of the available work-force in the area from which he draws employees, or to supply an Affirmative Action plan which will achieve such representation during the life of the contract.

11. **EQUAL EMPLOYMENT OPPORTUNITY AFFIRMATIVE ACTION POLICY**

It is the policy of _____
to assure that all applicants for employment and all employees are treated on a fair and equitable basis without regard to their race, religion, sex, color, handicap, natural origin or age.

Such action shall include employment, promotion, demotion, recruitment or recruitment advertising, layoff or termination, rates of pay and other forms of compensation, and selection for training, whether apprenticeship and/or on-the-job-training.

Furthermore, this company agrees to make special recruitment efforts to hire the protected class whenever feasible. This company also agrees to adhere to all applicable federal, state, and local laws relating to Equal Employment Opportunity for all individuals.

12. WORKFORCE ANALYSIS FORM

Name of Organization: _____

Date: ____ / ____ / ____

Categories	Total	White		Black		Other		Total	
		M	F	M	F	M	F	M	F
Administrators									
Professionals									
Superintendents									
Supervisors									
Foremen									
Technicians									
Protective Service									
Para-Professionals									
Office/Clerical									
Skilled Craft									
Service/Maintenance									
Total:									

Prepared By: _____

13. EVIDENCE OF INSURABILITY

LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT CONSTRUCTION PROJECT
(Use separate form for each Agency or Brokerage agreeing to provide coverage)

Names Insured: _____ Employee ID: _____
 Address: _____ Phone: _____
 Project to be insured: _____

In lieu of obtaining certificates of insurance at this time, the undersigned agrees to provide the above Named Insured with the minimum coverage listed below. These are outlined in the Insurance and Risk Management of Part V (Special Conditions), including all requirements, and conditions:

Section Items	Coverage	Minimum Limits and Policy Requirements	Limits Provided To Insured	Name of Insurer	A.M. Best's Code	Rating
SC-4, Section 2, Part 4.1 – see provisions	CGL	\$1,000,000 per occ. And \$2,000,000 aggregate	\$			
SC-4, Section 2, Part 4.1 – see provisions	AUTO	\$2,000,000/per occ.	\$			
SC-4, Section 2, Part 4.1 – see provisions	WC	Statutory w /endorsement as noted				
SC-4, Section 2, Part 4.1 – see provisions	RPL	\$2,000,000 per occ. And \$6,000,000 aggregate	\$			

Section 2 includes required provisions, statements regarding insurance requirements, and the undersigned agrees to abide by all provisions for the coverage's checked above unless stated otherwise when submitting. For the Railroad Protective Liability Policy, (RPL), see section "f" under insurance requirements.

Agency or Brokerage	Name of Authorized Representative
Street Address	Title
City State Zip	Authorized Signature
Telephone Number	Date

NOTE: Authorized signatures may be the agent's if agent has placed insurance through an agency agreement with the insurer. If insurance is brokered, authorized signature must be that of authorized representative of insurer.

IMPORTANT: Contract may not be awarded if a completed and signed copy of this form for all coverage's listed above is not provided with the bid.

14. DEBARRED FIRMS

PROJECT NAME: _____

BID NUMBER: _____

**LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT
LEXINGTON, KY**

All prime Contractors shall certify that Subcontractors have not and will not be awarded to any firms that has been debarred for noncompliance with the Federal Labor Standards, Title VI of the Civil Rights Act of 1964 As Amended, Executive Order 11246 As Amended or any other Federal Law.

All bidders shall complete the attached certification in duplicate and submit both copies to the Owner with the bid proposal. The Owner (grantee) shall transmit one copy to the Lexington-Fayette Urban County Government, Division of Community Development, within fourteen (14) days after bid opening.

The undersigned hereby certifies that the firm of _____ has not and will not award a subcontract, in connection with any contract award to it as the result of this bid, to any firm that has been debarred for noncompliance with the Federal labor Standards, Title VI of the civil Rights Act of 1964, Executive Order 11246 as amended or any Federal Law.

Name of Firm Submitting Bid

Signature of Authorized Official

Title

Date

15. DEBARMENT CERTIFICATION

All contractors/subcontractors shall complete the following certification and submit it with the bid proposal.

The contractor/subcontractor certifies in accordance with Executive Order 12549 (Debarment and Suspension 2/18/86) that to the best of its knowledge and belief, that it and its principals:

- 1) Are not presently debarred, suspended, proposed for debarment, declared negligible, or voluntarily excluded from covered transactions or contract by any Federal department or agency for noncompliance with the Federal Labor Standards, Title VI of the Civil Rights Act of 1964 as amended, Executive Order 11246 as amended or any other Federal law;
 - a) Have not within a three year period preceding this proposal been convicted of or had a civil judgment rendered against them for commission of fraud or a criminal offense in connection with obtaining, attempting to obtain, or performing a public (Federal, State or local) transaction or contract under a public transaction; violation of Federal or State antitrust statutes or commission of embezzlement, theft, forgery, bribery, falsification or destruction of records, making false statements, or receiving stolen property;
 - b) Are not presently indicted for or otherwise criminally or civilly charged by a government entity (Federal, State or local) with commission of any of the offenses enumerated in paragraph (1)(a) of this certification; and
 - c) Have not within a three year period preceding this bid has one or more public (Federal, State or local) transactions or contracts terminated for cause or default.
- 2) Where the contractor is unable to certify to any of the statements in this certification, such prospective contractors shall attach an explanation to this certification form.

Firm Name: _____

Project: _____

Printed Name and Title of Authorized Representative: _____

Signature: _____

Date: _____

END OF SECTION

PART IV
GENERAL CONDITIONS
TABLE OF CONTENTS

Article Number	Title	Page
1.	DEFINITIONS	GC-6
2.	PRELIMINARY MATTERS.....	GC-10
3.	CONTRACT DOCUMENTS: INTENT, CONFLICTS, AMENDING AND REUSE	GC-11
4.	AVAILABILITY OF LANDS; PHYSICAL CONDITIONS; REFERENCE POINTS	GC-13
5.	CONTRACTOR'S RESPONSIBILITIES	GC-16
6.	OTHER WORK	GC-27
7.	OWNER'S RESPONSIBILITIES	GC-28
8.	CONSULTANT'S STATUS DURING CONSTRUCTION	GC-28
9.	CHANGES IN THE WORK	GC-31
10.	CHANGE OF CONTRACT PRICE.....	GC-32
11.	CHANGE OF CONTRACT TIME	GC-39
12.	WARRANTY AND GUARANTEE; TESTS AND INSPECTIONS; CORRECTION, REMOVAL OR ACCEPTANCE OF DEFECTIVE WORK.....	GC-39
13.	PAYMENTS TO CONTRACTOR AND COMPLETION	GC-43
14.	SUSPENSION OF WORK AND TERMINATION	GC-46
15.	MISCELLANEOUS	GC-49

DETAILED TABLE OF CONTENTS OF GENERAL CONDITIONS

1. Definitions
2. Preliminary Matters
 - 2.1 Delivery of Bonds
 - 2.2 Copies of Documents
 - 2.3 Commencement of Contract Time; Notice to Proceed
 - 2.4 Starting the Project
 - 2.5 Before Starting Construction
 - 2.6 Submittal of Schedules
 - 2.7 Preconstruction Conference
 - 2.8 Finalizing Schedules
3. Contract Documents, Intent, Conflicts, Amending, and Reuse
 - 3.1 General
 - 3.2 Intent
 - 3.3 Conflicts
 - 3.4 Amending and Supplementing Contract Documents
 - 3.5 Reuse of Documents
4. Availability of Lands, Physical Conditions, Reference Points
 - 4.1 Availability of Lands
 - 4.2 Physical Conditions
 - 4.3 Physical Conditions - Underground Facilities
 - 4.4 Reference Points
5. CONTRACTOR'S Responsibilities
 - 5.1 Supervision
 - 5.2 Superintendence
 - 5.3 Labor
 - 5.4 Start-Up and Completion of Work
 - 5.5 Materials and Equipment
 - 5.6 Adjusting Progress Schedule
 - 5.7 Substitutes or "Or-Equal" Items
 - 5.8 Subcontractors, Suppliers and Others
 - 5.9 Patent Fees and Royalties
 - 5.10 Permits
 - 5.11 Laws and Regulations
 - 5.12 Taxes
 - 5.13 Use of Premises

- 5.14 Record Drawings
- 5.15 Shop Drawings and Samples
- 5.16 Continuing the Work
- 5.17 Erosion and Sediment Control

- 6. Other Work
 - 6.1 Related Work at Site
 - 6.2 Other Contractors or Utility Owners
 - 6.3 Delays Caused By Others
 - 6.4 Coordination

- 7. OWNER'S Responsibilities
 - 7.1 Communications
 - 7.2 Data and Payments
 - 7.3 Lands, Easements, and Surveys
 - 7.4 Change Orders
 - 7.5 Inspections, Tests, and Approvals
 - 7.6 Stop or Suspend Work

- 8. CONSULTANT'S Status During Construction
 - 8.1 OWNER'S Representative
 - 8.2 Visits to Site
 - 8.3 Project Representation
 - 8.4 Clarification and Interpretations
 - 8.5 Authorized Variations in Work
 - 8.6 Rejecting Defective Work
 - 8.7 Shop Drawings
 - 8.8 Change Orders
 - 8.9 Payments
 - 8.10 Determinations for Unit Prices
 - 8.11 Decisions on Disputes
 - 8.12 Limitations on CONSULTANT'S Responsibilities

- 9. Changes in the Work
 - 9.1 OWNER May Order Changes
 - 9.2 Claims
 - 9.3 Work Not in Contract Documents
 - 9.4 Change Orders
 - 9.5 Notice of Change

- 10. Change of Contract Price
 - 10.1 Total Compensation
 - 10.2 Claim for Increase or Decrease in Price
 - 10.3 Value of Work
 - 10.4 Cost of the Work
 - 10.5 Not to Be Included in Cost of the Work
 - 10.6 CONTRACTOR'S Fee
 - 10.7 Itemized Cost Breakdown
 - 10.8 Cash Allowance
 - 10.9 Unit Price Work

- 11. Change of Contract Time
 - 11.1 Change Order
 - 11.2 Justification for Time Extension
 - 11.3 Time Limits

- 12. Warranty and Guarantee; Tests and Inspections; Correction, Removal or Acceptance of Defective Work
 - 12.1 Warranty and Guarantee
 - 12.2 Access to Work
 - 12.3 Tests and Inspections
 - 12.4 OWNER May Stop Work
 - 12.5 Correction or Removal of Defective Work
 - 12.6 One Year Correction Period
 - 12.7 Acceptance of Defective work
 - 12.8 Owner May Correct Defective Work

- 13. Payments to CONTRACTOR and Completion
 - 13.1 Schedule of Values
 - 13.2 Application for Progress Payments
 - 13.3 CONTRACTOR'S Warranty of Title
 - 13.4 Review of Application for Progress Payments
 - 13.5 Partial Utilization
 - 13.6 Final Inspection
 - 13.7 Final Application for Payment
 - 13.8 Final Payment and Acceptance
 - 13.9 CONTRACTOR'S Continuing Obligation
 - 13.10 Waiver of Claims

- 14. Suspension of Work and Termination
 - 14.1 OWNER May Suspend Work
 - 14.2 OWNER May Terminate
 - 14.3 CONTRACTOR'S Services Terminated
 - 14.4 Payment After Termination
 - 14.5 CONTRACTOR May Stop or Terminate

- 15. Miscellaneous
 - 15.1 Claims for Injury or Damage
 - 15.2 Non-Discrimination in Employment
 - 15.3 Temporary Street Closing or Blockage
 - 15.4 Percentage of Work Performed by Prime CONTRACTOR
 - 15.5 Clean-up
 - 15.6 General
 - 15.7 Debris Disposal

END OF SECTION

PART IV

GENERAL CONDITIONS

1. DEFINITIONS

Wherever used in these General Conditions or the other Contract Documents, the following terms have the meanings indicated which are applicable to both the singular and plural thereof.

1.1 Addenda

Written or graphic instruments issued prior to the opening of Bids which clarify, correct, or change the Bid Documents or the Contract Documents.

1.2 Agreement

The written agreement between OWNER and CONTRACTOR covering the Work to be performed; other Contract Documents are attached to the Agreement and made a part thereof as provided therein.

1.3 Application for Payment

The form accepted by CONSULTANT which is to be used by CONTRACTOR in requesting progress or final payments and which is to include such supporting documentation as is required by the Contract Documents.

1.4 Bid

The offer or proposal of the Bidder submitted on the prescribed form setting forth the prices for the Work to be performed.

1.5 Bidder

An individual, partnership, or corporation, who submit a Bid for a prime contract with the OWNER, for the Work described in the proposed Contract Documents.

1.6 Bonds

Bid, performance and payment bonds and other instruments of security.

1.7 Calendar Day

A calendar day of twenty-four hours measured from midnight to the next midnight shall constitute a day.

1.8 Change Order

A document recommended by CONSULTANT, which is signed by CONTRACTOR and OWNER and authorizes an addition, deletion or revision in the Work, or an adjustment in the Contract Price or the Contract Time, issued on or after the Effective Date of the Agreement.

- 1.9 Contract Documents**
The Advertisement for Bidders, Information for Bidders, Agreement, Addenda (which pertain to the Contract Documents), CONTRACTOR'S Bid (including documentation accompanying the Bid and any post-bid documentation submitted prior to the Notice of Award) when attached as an exhibit to the Agreement, the Bonds, these General Conditions, the Special Conditions, the Specifications and the Drawings as the same are more specifically identified in the Agreement, together with all amendments, modifications and supplements.
- 1.10 Contract Unit Price**
The monies payable by OWNER to CONTRACTOR under the Contract Documents as stated in the Agreement. Unit Prices are to be firm for the term of this Contract.
- 1.11 Contract Time**
The number of consecutive calendar days between the date of issuance of the Notice to Proceed and the contract completion date.
- 1.12 CONTRACTOR**
The person, firm or corporation with whom OWNER has entered into the Agreement.
- 1.13 Defective**
An adjective which when modifying the word Work refers to Work that is unsatisfactory, faulty or deficient, or does not conform to the Contract Documents, or does not meet the requirements of any inspection, reference standard, test or approval referred to in the Contract Documents, or has been damaged prior to CONSULTANT'S recommendation of final payment (unless responsibility for the protection thereof has been assumed by OWNER).
- 1.14 Drawings**
The drawings which show the character and scope of the Work to be performed and which have been prepared or approved by CONSULTANT and are referred to in the Contract Documents.
- 1.15 Effective Date of the Agreement**
The date indicated in the Agreement on which it becomes effective.
- 1.16 CONSULTANT**
The Lexington-Fayette Urban County Government or its authorized representative.
- 1.17 Field Order**
A documented order issued by CONSULTANT which orders minor changes in the Work, but which does not involve a change in the Contract Price or the Contract Time.

1.18 Giving Notice

Whenever any provision of the Contract Documents requires the giving of written notice, it will be deemed to have been validly given if delivered in person to the individual or to a member of the firm or to an officer of the corporation for whom it is intended, or if delivered at or sent by registered or certified mail, postage prepaid, to the last business address known to the giver of the notice.

1.19 Laws and Regulations

Laws, rules, regulations, ordinances, codes and/or orders.

1.20 Notice of Award

The written notice by OWNER to the apparent successful bidder stating that upon compliance by the apparent successful bidder with the conditions enumerated therein, within the time specified, OWNER will sign and deliver the Agreement.

1.21 Notice to Proceed

A written notice given by OWNER to CONTRACTOR fixing the date on which the Contract Time will commence to run and on which CONTRACTOR shall start to perform CONTRACTOR'S obligations under the Contract Documents.

1.22 OWNER

The Lexington-Fayette Urban County Government.

1.23 Partial Utilization

Placing a portion of the Work in service for the purpose for which it is intended (or related purpose) before reaching Completion for all the Work.

1.24 Project

The total construction of which the Work to be provided under the Contract Documents may be the whole, or a part as indicated elsewhere in the Contract Documents.

1.25 Inspector

The authorized representative who is assigned to the site or any part thereof.

1.26 Shop Drawings

All drawings, diagrams, illustrations, schedules and other data which are specifically prepared by or for CONTRACTOR to illustrate some portion of the Work and all illustrations, brochures, standard schedules, performance charts, instructions, diagrams and other information prepared by a Supplier and submitted by CONTRACTOR to illustrate material or equipment for some portion of the Work.

1.27 Specifications

Those portions of the Contract Documents consisting of written technical descriptions of materials, equipment, construction systems, standards and

workmanship as applied to the Work and certain administrative details applicable thereto.

1.28 Standard Specifications

The "Standard Specifications for Road and Bridge Construction", Transportation Cabinet, Department of Highways, Commonwealth of Kentucky, current edition. MUTCD shall refer to the "Manual of Uniform Traffic Control Devices.

1.29 Subcontractor

An individual, firm or corporation having a direct contract with CONTRACTOR or with any other Subcontractor for the performance of a part of the Work at the site.

1.30 Special Conditions

The part of the Contract Documents which amends or supplements these General Conditions.

1.31 Supplier

A manufacturer, fabricator, supplier, distributor, materialman or vendor.

1.32 Underground Facilities

All pipelines, conduits, ducts, cables, wires, manholes, vaults, tanks, tunnels or other such facilities or attachments, and any encasements containing such facilities which have been installed underground to furnish any of the following services or materials: electricity, gases, steam, liquid petroleum products, telephone or other communications, cable television, sewage and drainage removal, traffic or other control systems or water.

1.33 Unit Price Work

Not applicable

1.34 Work

The entire completed construction or the various separately identifiable parts thereof required to be furnished under the Contract Documents. Work is the result of performing services, furnishing labor and furnishing and incorporating materials and equipment into the construction, all as required by the Contract Documents.

1.35 Time Period

When any period of time is referred to in the Contract Documents by days, it will be computed to exclude the first and include the last day of such period. If the last day of any such period falls on a Saturday or Sunday or on a day made a legal holiday by the law of the applicable jurisdiction, such day will be omitted from the computation.

2. PRELIMINARY MATTERS

2.1 Delivery of Bonds

When the CONTRACTOR delivers the executed Agreements to OWNER, CONTRACTOR shall also deliver to OWNER, such Bonds, Insurance Certificate, and Power of Attorney as CONTRACTOR may be required to furnish.

2.2 Copies of Documents

Owner shall furnish to CONTRACTOR up to three copies (unless otherwise specified in the Special Conditions) of the Contract Documents as are reasonably necessary for the execution of the Work. Additional copies will be furnished, upon request, at the cost of reproduction.

2.3 Commencement of Contract Time; Notice to Proceed

The Contract Time will commence to run on the day specified in the Notice to Proceed.

2.4 Starting the Project

CONTRACTOR shall start to perform the Work on the date when the Contract Time commences to run, but no Work shall be done at the site prior to the date on which the Contract Time commences to run.

2.5 Before Starting Construction

Before undertaking each part of the Work, CONTRACTOR shall carefully study and compare the Contract Documents and check and verify pertinent figures shown thereon and all applicable field measurements. CONTRACTOR shall promptly report in writing to CONSULTANT any conflict, error or discrepancy which CONTRACTOR may discover and shall obtain a written interpretation or clarification from CONSULTANT before proceeding with any Work affected thereby; however, CONTRACTOR shall not be liable to OWNER or CONSULTANT for failure to report any conflict, error or discrepancy in the Contract Documents, unless CONTRACTOR had actual knowledge thereof or should reasonably have known thereof.

2.6 Submittal of Schedules

Within ten days after the effective date of the Agreement (unless otherwise specified) CONTRACTOR shall submit to CONSULTANT for review:

2.6.1 an estimated progress schedule indicating the starting and completion dates of the various stages of the Work;

2.6.2 a preliminary schedule of Shop Drawing submissions; and

2.6.3 a preliminary schedule of values for all of the Work which will include quantities and prices of items aggregating the Contract Price and will subdivide the Work into costs per labor and materials by specification

section to serve as the basis for progress payments during construction. Such prices will include an appropriate amount of overhead and profit applicable to each item of Work which will be confirmed in writing by CONTRACTOR at the time of submission. Schedule of values shall be submitted on AIA G702/703 forms, or approved equal.

2.7 Preconstruction Conference

Before CONTRACTOR starts the Work at the proposed site, a conference attended by CONTRACTOR, CONSULTANT, EEO-Affirmative Action Officer, and other appropriate parties will be held to discuss the following issues: (1) The scheduling of the Work to be completed; (2) The procedures for handling shop drawings and other submittals; (3) The processing of applications for payment; (4) The establishment of an understanding among the involved parties in regard to the proposed project; and (5) The establishment of procedures for effectively implementing the LFUCG's 10% minimum DBE goals.

2.8 Finalizing Schedules

At least ten days before submission of the first Application for Payment a conference attended by CONTRACTOR, CONSULTANT and others as appropriate will be held to finalize the schedules submitted in accordance with paragraph 2.6. The finalized progress schedule will be acceptable to CONSULTANT as providing orderly progression of the Work to completion within the Contract Time, but such acceptance will neither impose on CONSULTANT responsibility for the progress or scheduling of the Work nor relieve CONTRACTOR from full responsibility thereof. The finalized schedule of Shop Drawing submissions will be acceptable to CONSULTANT as providing a workable arrangement for processing the submissions. The finalized schedule of values will be acceptable to CONSULTANT as to form and substance.

3. CONTRACT DOCUMENTS: INTENT, CONFLICTS, AMENDING AND REUSE

3.1 General

The Contract Documents comprise the entire agreement between OWNER and CONTRACTOR concerning the Work. The Contract Documents are complementary; what is called for by one is as binding as if called for by all. The Contract Documents will be construed in accordance with the law of the place of the Project.

3.2 Intent

It is the intent of the Contract Documents to describe a functionally complete Project (or part thereof) to be constructed in accordance with the Contract Documents. Any Work, materials or equipment that may reasonably be inferred from the Contract Documents as being required to produce the intended result will be supplied whether or not specifically called for. When words which have a well-known technical or trade meaning are used to describe Work, materials or equipment such words shall be

interpreted in accordance with that meaning. Reference to standard specifications, manuals or codes of any technical society, organization or association, or to the laws or regulations of any governmental authority, whether such reference be specific or by implication, shall mean the latest standard specification, manual, code or laws or regulations in effect at the time of opening of Bids (or, on the Effective Date of the Agreement if there were no Bids), except as may be otherwise specifically stated. However, no provision of any referenced standard specification, manual or code (whether or not specifically incorporated by reference in the Contract Documents) shall be effective to change the duties and responsibilities of OWNER, CONTRACTOR or CONSULTANT, or any of their consultants, agents or employees from those set forth in the Contract Documents, nor shall it be effective to assign to CONSULTANT, or any of CONSULTANT'S consultants, agents or employees, any duty or authority to supervise or direct the furnishing or performance of the Work or any duty or authority to undertake responsibility contrary to the provisions of paragraph 8.12.3 or 8.12.4. Clarifications and interpretations of the Contract Documents shall be issued by CONSULTANT as provided in paragraph 8.4.

3.3 Conflicts

If, during the performance of the Work, CONTRACTOR finds a conflict, error or discrepancy in the Contract Documents, CONTRACTOR shall so report to CONSULTANT in writing at once and before proceeding with the Work affected thereby shall obtain a written interpretation or clarification from CONSULTANT; however, CONTRACTOR shall not be liable to OWNER or CONSULTANT for failure to report any conflict, error or discrepancy in the Contract Documents unless CONTRACTOR had actual knowledge thereof or should reasonably have known thereof.

In resolving such conflicts, errors and discrepancies, the documents shall be given precedence in the following order:

1. Agreement
2. Field and Change Orders
3. Addenda
4. Special Conditions
5. Instruction to Bidders
6. General Conditions
7. Specifications and Drawings

Figure dimension on drawings shall govern over scale dimensions and detailed Drawings shall govern over general Drawings.

3.4 Amending and Supplementing Contract Documents

The Contract Documents may be amended to provide for additions, deletions and revisions in the Work or to modify the terms and conditions thereof by means of a Change Order or a Field Order. Contract Price and Contract Time may only be changed by a Change Order.

3.5 Reuse of Documents

Neither CONTRACTOR nor any Subcontractor or Supplier or other person or organization performing or furnishing any of the Work under a direct or indirect contract with OWNER shall have or acquire any title to or ownership rights in any of the Drawings, Specifications or other documents (or copies of any thereof) prepared by or bearing the seal of CONSULTANT; and they shall not reuse any of them on extensions of the Project or any other project without written consent of OWNER and CONSULTANT and specific written verification or adaptation by CONSULTANT.

4. AVAILABILITY OF LANDS; PHYSICAL CONDITIONS, REFERENCE POINTS

4.1 Availability of Lands

OWNER shall furnish, as indicated in the Contract Documents, the lands upon which the Work is to be performed, rights-of-way and easements for access thereto, and such other lands which are designated for the use of CONTRACTOR. Easements for permanent structures or permanent changes in existing facilities will be obtained and paid for by OWNER, unless otherwise provided in the Contract Documents. If CONTRACTOR believes that any delay in OWNER'S furnishing these lands, rights-of-way or easements entitles CONTRACTOR to an extension of the Contract Time, CONTRACTOR may make a claim therefor as provided in Article 11. CONSULTANT shall determine if the claim is legitimate or not. CONTRACTOR shall provide for all additional lands and access thereto that may be required for temporary construction facilities or storage of materials and equipment.

4.2 Physical Conditions

4.2.1 Explorations and Reports

Reference is made to the Special Conditions for identification of those reports of explorations and tests of subsurface conditions at the site that have been utilized by CONSULTANT in preparation of the Contract Documents. CONTRACTOR may rely upon the accuracy of the technical data contained in such reports, but not upon non-technical data, interpretations or opinions contained therein or for the completeness thereof for CONTRACTOR'S purposes. Except as indicated in the immediately preceding sentence and in paragraph 4.2.6, CONTRACTOR shall have full responsibility with respect to subsurface conditions at the site.

4.2.2 Existing Structures

Reference is made to the Special Conditions for identification of those drawings of physical conditions in or relating to existing surface and

subsurface structures (except Underground Facilities referred to in paragraph 4.3 which are at or contiguous to the site that have been utilized by CONSULTANT in preparation of the Contract Documents. CONTRACTOR may rely upon the accuracy of the technical data contained in such drawings, but not for the completeness thereof for CONTRACTOR'S purposes. Except as indicated in the immediately preceding sentence and in paragraph 4.2.6, CONTRACTOR shall have full responsibility with respect to physical conditions in or relating to such structures.

4.2.3 Report of Differing Conditions
If CONTRACTOR believes that:

4.2.3.1 any technical data on which CONTRACTOR is entitled to rely as provided in paragraphs 4.2.1 and 4.2.2 is inaccurate, or

4.2.3.2 any physical conditions uncovered or revealed at the site differ materially from that indicated, reflected or referred to in the Contract Documents,

CONTRACTOR shall, promptly after becoming aware thereof and before performing and WORK in connection therewith (except in an emergency) notify OWNER and CONSULTANT in writing about the inaccuracy or difference.

4.2.4 CONSULTANT'S Review

CONSULTANT will promptly review the pertinent conditions, determine the necessity of obtaining additional explorations or tests with respect thereto and advise CONTRACTOR of CONSULTANT'S findings and conclusions.

4.2.5 Possible Document Change

If CONSULTANT concludes that there is a material error in the Contract Documents or that because of newly discovered conditions a change I the Contract Documents is required, a Change Order will be issued as provided in Article 10 to reflect and document the consequences of the inaccuracy or difference.

4.2.6 Possible Price and Time Adjustments

In each such case, an increase or decrease in the Contract Price or an extension or shortening of the Contract Time, or any combination thereof, will be allowable to the extent that they are attributable to any such inaccuracy or difference.

4.3 Physical Conditions-Underground Facilities

4.3.1 Shown or Indicated

The information and data shown or indicated in the Contract Documents with respect to existing Underground Facilities at or contiguous to the site is

based on information and data furnished to OWNER or CONSULTANT by the owners of such underground facilities or by others. Unless it is otherwise expressly provided in the Special Conditions:

4.3.1.1 OWNER and CONSULTANT shall not be responsible for the accuracy or completeness of any such information or data; and,

4.2.1.2 CONTRACTOR shall have full responsibility for reviewing and checking all such information and data; for locating all underground facilities shown or indicated in the Contract Documents; for coordination of the Work with the owners of such underground facilities during construction; and for the safety and protection thereof and repairing any damage thereto resulting from the Work, the cost of all of which will be considered as having been included in the Contract Price.

4.3.2 Not Shown or Indicated

If an underground facility is uncovered or revealed at or contiguous to the site which was not shown or indicated in the Contract Documents and which CONTRACTOR could not reasonably have been expected to be aware of, CONTRACTOR shall, promptly after becoming aware thereof and before performing any Work affected thereby (except in an emergency), identify the owner of such Underground Facility and give written notice thereof to that owner and to OWNER and CONSULTANT. CONSULTANT will promptly review the underground facility to determine the extent to which the Contract Documents should be modified to reflect and document the consequences of the existence of the Underground Facility, and the Contract Documents will be amended or supplemented to the extent necessary. During such time, CONTRACTOR shall be responsible for the safety and protection of such underground facility. CONTRACTOR shall be allowed an increase in the Contract Price or an extension of the Contract Time, or both, to the extent that they are attributable to the existence of any underground facility that was not shown or indicated in the Contract Documents and which CONTRACTOR could not reasonably have been expected to be aware of.

4.4 Reference Points

OWNER shall provide engineering surveys to establish reference points for construction which in CONSULTANT'S judgment are necessary to enable CONTRACTOR to proceed with the Work. CONTRACTOR shall be responsible for laying out the Work (unless otherwise specified), shall protect and preserve the established reference points and shall make no changes or relocations without the prior written approval of OWNER. CONTRACTOR shall report to CONSULTANT whenever any reference point is lost or destroyed or requires relocation because of necessary changes in grades or locations, and shall be responsible for the accurate replacement or relocation of such reference points by a Registered Land Surveyor.

5. CONTRACTOR'S RESPONSIBILITIES

5.1 Supervision

CONTRACTOR shall supervise and direct the Work competently and efficiently, devoting such attention thereto and applying such skills and expertise as may be necessary to perform the Work in accordance with the Contract Documents. CONTRACTOR shall assure that all CONTRACTOR personnel (including subcontractors, etc.) conduct themselves in a courteous and respectful manner toward the CONSULTANT and the general public. CONTRACTOR shall keep at the Project Site during the progress of the Work a competent project manager/superintendent and all necessary assistants, all of whom shall be satisfactory to OWNER. OWNER reserves the right to reject CONTRACTOR'S construction superintendent and project management personnel if they are unsatisfactory to OWNER and upon such rejection CONTRACTOR shall designate and provide competent successors. Failure to comply with this condition of the Contract will result in immediate suspension of the Work. Following a review by the Commissioner of Public Works, the Contract may be terminated (see GC section 14). CONTRACTOR shall be solely responsible for the means, methods, techniques, sequences and procedures of construction, but CONTRACTOR shall not be responsible for the negligence of others in the design or selection of a specific means, method, technique, sequence or procedure of construction which is indicated in and required by the Contract Documents. CONTRACTOR shall be responsible to see that the finished Work complies accurately with the Contract Documents.

5.2 Superintendence

CONTRACTOR shall keep on the Work at all times during its progress a competent resident superintendent, who shall not be replaced without written notice to OWNER and CONSULTANT except under extraordinary circumstances. The superintendent will be CONTRACTOR'S representative at the site and shall have authority to act on behalf of CONTRACTOR. All communications given to the superintendent shall be as binding as if given to CONTRACTOR.

5.3 Labor

CONTRACTOR shall provide competent, suitably qualified personnel to survey and lay out the Work and perform construction as required by the Contract Documents. CONTRACTOR shall at all times maintain good discipline and order at the site. OWNER reserves the right to require CONTRACTOR to remove from the Project any of it's personnel, or subcontractor's personnel for violating LFUCG Policies, Rules or Regulations. Except in connection with the safety or protection of persons or the Work or property at the site or adjacent thereto, and except as otherwise indicated in the Contract Documents, all Work at the site shall be performed during regular working hours, and CONTRACTOR will not permit overtime work or the performance of Work on Saturday, Sunday or any legal holiday without OWNER'S written consent given after prior written notice to CONSULTANT.

5.4 Start-Up and Completion of Work

Unless otherwise specified, CONTRACTOR shall furnish and assume full responsibility for all materials, equipment, labor, transportation, construction equipment and machinery, tools, appliances, fuel, power, light, heat, telephone, water, sanitary facilities, temporary facilities and all other facilities and incidentals necessary for the furnishing, performance, testing, start-up and completion of the Work.

5.5 Materials and Equipment

All materials and equipment shall be of good quality and new, except as otherwise provided in the Contract Documents. If required by CONSULTANT, CONTRACTOR shall furnish satisfactory evidence (including reports of required tests) as to the kind and quality of materials and equipment. All materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned in accordance with the instructions of the applicable supplier except as otherwise provided in the Contract Documents; but no provision of any such instructions will be effective to assign to CONSULTANT, or any of CONSULTANT'S consultants, agents or employees, any duty or authority to supervise or direct the furnishing or performance of the Work or any duty or authority to undertake responsibility contrary to the provisions of paragraph 8.12.3 or 8.12.4.

5.5.1 Not Clearly Specified or Indicated

In all instances where materials specified are obtainable in different sizes, weights, trade grades, qualities or finishes, etc., whose weights, trade grades, qualities or finishes, etc., are not clearly specified or indicated on the Drawings, the CONTRACTOR shall notify the CONSULTANT of all such instances at least five (5) days in advance of receiving the proposals. The CONSULTANT will then determine which size, weight, trade grade, quality, finish, etc., is required.

5.5.2 Coordination of Work

The CONTRACTOR shall see that for his own Work and for the work of each subcontractor, proper templates and patterns necessary for the coordination of the various parts of the Work are prepared. The CONTRACTOR shall furnish or require the Subcontractor to furnish such duplicates as will enable the Subcontractors to fit together and execute fully their respective portions of the Work.

5.6 Adjusting Progress Schedule

CONTRACTOR shall submit to CONSULTANT for acceptance (to the extent indicated in paragraph 2.8) adjustments in the progress schedule to reflect the impact thereon of new developments; these will conform generally to the progress schedule then in effect and additionally will comply with any provisions of the Contract Documents applicable thereto.

5.7 Substitutes or "Or-Equal" Items

5.7.1 General

Whenever materials or equipment are specified or described in the Contract Documents by using the name of a proprietary item or the name of a particular supplier, the naming of the item is intended to establish the type, function, and quality required. Unless the name is followed by words indicating that no substitution is permitted, materials or equipment of other Suppliers may be accepted by OWNER/CONSULTANT if sufficient information is submitted by CONTRACTOR to allow OWNER/CONSULTANT to determine that the material or equipment proposed is equivalent or equal to that named. The procedure for review by OWNER/CONSULTANT will include the following. Requests for review of substitute items of material and equipment will not be accepted by OWNER/CONSULTANT from anyone, other than CONTRACTOR. If CONTRACTOR wishes to furnish or use a substitute item of material or equipment, CONTRACTOR shall make written application to OWNER/CONSULTANT for acceptance thereof, certifying that the proposed substitute will perform adequately the functions and achieve the results called for by the general design, be similar and of equal substance to that specified and be suited to the same use as that specified. The application will state that the evaluation and acceptance of the proposed substitute will not prejudice CONTRACTOR'S achievement of completion on time, whether or not acceptance of the substitute for use in the Work will require a change in any of the Contract Documents (or in the provisions of any other direct contract with OWNER for work on the Project) to adapt the design to the proposed substitute and whether or not incorporation or use of the substitute in connection with the Work is subject to payment of any license fee or royalty. All variations of the proposed substitute from that specified will be identified in the application and available maintenance, repair and replacement service will be indicated. The application will also contain an itemized estimate of all costs that will result directly or indirectly from acceptance of such substitute, including costs of redesign and claims of other contractors affected by the resulting change, all of which shall be considered by OWNER/CONSULTANT in evaluating the proposed substitute. OWNER/CONSULTANT may require CONTRACTOR to furnish at CONTRACTOR'S expense additional data about the proposed substitute.

5.7.2 Substitutes

If a specific means, method, technique, sequence or procedure of construction is indicated in or required by the Contract Documents, CONTRACTOR may furnish or utilize a substitute means, method, sequence, technique or procedure of construction acceptable to OWNER/CONSULTANT, if CONTRACTOR submits sufficient information to allow OWNER/CONSULTANT to determine that the substitute proposed is equivalent to that indicated or required by the Contract Documents. The procedure for review by OWNER/CONSULTANT will be

similar to that provided in paragraph 5.7.1 as applied by OWNER/CONSULTANT.

5.7.3 OWNER/CONSULTANT'S Approval

OWNER/CONSULTANT will be allowed a reasonable time within which to evaluate each proposed substitute. OWNER/CONSULTANT will be the sole judge of acceptability, and no substitute will be ordered, installed or utilized without OWNER/CONSULTANT'S prior written acceptance which will be evidenced by either a Change Order or an approved Shop Drawing. OWNER may require CONTRACTOR to furnish at CONTRACTOR'S expense a special performance guarantee or other surety with respect to any substitute. OWNER/CONSULTANT will record time required by OWNER/CONSULTANT and OWNER/CONSULTANT'S consultants in evaluating substitutions proposed by CONTRACTOR and in making changes in the Contract Documents occasioned thereby. Whether or not OWNER/CONSULTANT accepts a proposed substitute, CONTRACTOR shall reimburse OWNER for the charges of OWNER/CONSULTANT and OWNER/CONSULTANT'S consultants for evaluating each proposed substitute.

5.8 Subcontractors, Suppliers, and Others

5.8.1 Acceptable to CONSULTANT

CONTRACTOR shall not employ any Subcontractor, Supplier or other person or organization (including those acceptable to OWNER and CONSULTANT as indicated in paragraph 5.8.2), whether initially or as a substitute, against whom OWNER or CONSULTANT may have reasonable objection. CONTRACTOR shall not be required to employ any Subcontractor, Supplier or other person or organization to furnish or perform any of the Work against whom CONTRACTOR has reasonable objection.

5.8.2 Objection After Due Investigation

If the Contract Documents require the identity of certain Subcontractors, Suppliers or other persons or organizations (including those who are to furnish the principal items of materials and equipment) to be submitted to OWNER in advance of the specified date prior to the Effective Date of the Agreement for acceptance by OWNER and CONSULTANT and if CONTRACTOR has submitted a list thereof, OWNER'S or CONSULTANT'S acceptance (either in writing or by failing to make written objection thereto by the date indicated for acceptance or objection in the bidding documents or the Contract Documents) of any such Subcontractor, Supplier or other person or organization so identified may be revoked on the basis of reasonable objection after due investigation, in which case CONTRACTOR shall submit an acceptable substitute. No acceptance by OWNER or CONSULTANT of any such Subcontractor, Supplier or other

person or organization shall constitute a waiver of any right of OWNER or CONSULTANT to reject defective Work.

5.8.3 Contractor Responsible for Acts of Subcontractors

The CONTRACTOR shall perform on the site, and with its own organization, work equivalent to at least fifty (50) percent of the total amount of Work to be performed under the Contract. This percentage may be reduced by a supplemental agreement to this Contract if, during performing the Work, the CONTRACTOR requests a reduction and the Urban County project manager determines that the reduction would be to the advantage of the Urban County Government.

The CONTRACTOR shall, at the time he submits his proposal for the Contract, notify the OWNER in writing of the names of Subcontractors proposed for the Work. He shall not employ any Subcontractor without the prior written approval of the OWNER.

CONTRACTOR shall be fully responsible to OWNER and CONSULTANT for all acts and omissions of the Subcontractors, Suppliers and other persons and organizations performing or furnishing any of the Work under a direct or indirect contract with CONTRACTOR just as CONTRACTOR is responsible for CONTRACTOR'S own acts and omissions. Nothing in the Contract Documents shall create any contractual relationship between OWNER or CONSULTANT and any such Subcontractor, Supplier or other person or organization, nor shall it create any obligation on the part of OWNER or CONSULTANT to pay or to see to the payment of any moneys due any such Subcontractor, Supplier or other person or organization except as may otherwise be required by Laws and Regulations.

5.8.4 Division of Specifications

The divisions and sections of the Specifications and the identifications of any Drawings shall not control CONTRACTOR in dividing the Work among Subcontractors or Suppliers or delineating the Work to be performed by any specific trade.

5.8.5 Agreement Between Contractor and Subcontractors

All Work performed for CONTRACTOR by a Subcontractor will be pursuant to an appropriate agreement between CONTRACTOR and the Subcontractor which specifically binds the Subcontractor to the applicable terms and conditions of the Contract Documents for the benefit of OWNER and CONSULTANT.

5.8.6 Statements and Comments by CONTRACTOR

Neither the CONTRACTOR, his employees, nor his subcontractors shall at any time make any statement or comment as to the project scope, nature, intention, design, or construction

method to any third party or parties without the explicit written consent of the OWNER.

Any third party requesting such information shall be referred to the OWNER or his representative.

Should there be any change from the original intent of the project as a result of any statement or comment by the contractor, his employees or subcontractors, contractor shall be held liable for any change in the scope, nature, design, or construction method and shall bear the full cost for the previously mentioned changes.

5.9 Patent Fees and Royalties

CONTRACTOR shall pay all license fees and royalties and assume all costs incident to the use in the performance of the Work or the incorporation in the Work of any invention, design, process, product or device which is the subject of patent rights or copyrights held by others.

5.10 Permits

Unless otherwise provided in the Special conditions, CONTRACTOR shall obtain and pay for all construction permits and licenses. OWNER shall assist CONTRACTOR, when necessary, in obtaining such permits and licenses. CONTRACTOR shall pay all governmental charges and inspection fees necessary for the prosecution of the Work, which are applicable at the time of opening of Bids, or if there are no Bids on the Effective Date of the Agreement. CONTRACTOR shall pay all charges of utility owners for connections to the Work, and OWNER shall pay all charges of such utility owners for capital costs related thereto such as plant investment fees.

5.11 Laws and Regulations

5.11.1 CONTRACTOR to Comply

CONTRACTOR shall give all notices and comply with all Laws and Regulations applicable to furnishing and performance of the Work. Except where otherwise expressly required by applicable Laws and Regulations, neither OWNER nor CONSULTANT shall be responsible for monitoring CONTRACTOR'S compliance with any Laws and Regulations.

5.11.2 Specifications and Drawings at Variance

If CONTRACTOR observes that the Specifications or Drawings are at variance with any Laws or Regulations, CONTRACTOR shall give CONSULTANT prompt written notice thereof, and any necessary changes will be authorized by one of the methods indicated in paragraph 3.4. If CONTRACTOR performs any Work knowing or having reason to know that it is contrary to such Laws, or Regulations, and without such notice to CONSULTANT, CONTRACTOR shall bear all costs arising therefrom; however, it shall not be CONTRACTOR'S primary responsibility to make certain that the Specifications and Drawings are in accordance with such Laws and Regulations.

Any party, firm or individual submitting a proposal pursuant to invitation must have paid all taxes owed to the Lexington-Fayette Urban County Government at the time the proposal is submitted, and must maintain a "current" status in regard to those taxes throughout the Contract. If applicable, business must be licensed in Fayette County.

5.12 Taxes

CONTRACTOR shall pay all sales, consumer, use and other similar taxes required to be paid by CONTRACTOR in accordance with the Laws and Regulations of the place of the Project which are applicable during the performance of the Work. Any party, firm or individual submitting a proposal pursuant to invitation must have paid all taxes owed to the Lexington-Fayette Urban County Government at the time the proposal is submitted, and must maintain a "current" status in regard to those taxes throughout the Contract. If applicable, business must be licensed in Fayette County.

5.13 Use of Premises

5.13.1 Project Site

CONTRACTOR shall confine construction equipment, the storage of materials and equipment and the operations of workers to the staging areas or work site areas identified in and permitted by the Contract Documents and other land and areas permitted by Laws and Regulations, rights-of-way, permits and easements, and shall not unreasonably encumber the premises with construction equipment or other materials or equipment. CONTRACTOR shall assume full responsibility for any damage to any such

land or area, or to the owner or occupant thereof or of any land or areas contiguous thereto, resulting from the performance of the Work. Should any claim be made against OWNER or CONSULTANT by any such owner or occupant because of the performance of the Work, CONTRACTOR shall promptly attempt to settle with such other party by agreement or otherwise resolve the claim by arbitration or at law. CONTRACTOR shall, to the fullest extent permitted by Laws and Regulations, indemnify and hold OWNER and CONSULTANT harmless from and against all claims, damages, losses and expenses (including, but not limited to, fees of engineers, architects, attorneys and other professionals and court and arbitration costs) arising directly, indirectly or consequentially out of any action, legal or equitable, brought by any such other party against OWNER or CONSULTANT to the extent based on a claim arising out of CONTRACTOR'S performance of the Work.

5.13.2 Clean UP

During the progress of the Work, CONTRACTOR shall keep the premises free from accumulations of waste materials, rubbish and other debris resulting from the Work. At the completion of the Work, CONTRACTOR shall remove all waste materials, rubbish and debris from and about the premises as well as all tools, appliances, construction equipment and machinery, and surplus materials, and shall leave the site clean and ready for occupancy by OWNER. CONTRACTOR shall restore to original condition all property not designated for alteration by the Contract Documents.

5.13.1 Loading of Structures

CONTRACTOR shall not load nor permit any part of any structure to be loaded in any manner that will endanger the structure, nor shall CONTRACTOR subject any part of the Work or adjacent property to stresses or pressures that will endanger it.

5.14 **Record Drawings**

CONTRACTOR shall maintain in a safe place at the site one record copy of all Drawings, Specifications, Addenda, Change Orders, Field Orders and written interpretations and clarifications (issued pursuant to paragraph 9.4) in good order and annotated to show all changes made during construction. These record documents together with all approved samples and a counterpart of all approved Shop Drawings will be available to CONSULTANT for reference. Upon completion of the Work, these record documents, samples and Shop Drawings will be delivered to CONSULTANT for OWNER.

5.15 **Shop Drawings and Samples**

5.15.1 Shop Drawing Submittals

After checking and verifying all field measurements and after complying

with applicable procedures specified, CONTRACTOR shall submit to CONSULTANT for review and approval in accordance with the accepted schedule of Shop Drawing submissions (see paragraph 2.8), or for other appropriate action if so indicated in the Special Conditions, five copies (unless otherwise specified) of all Shop Drawings, which will bear a stamp or specific written indication that CONTRACTOR has satisfied CONTRACTOR'S responsibilities under the Contract Documents with respect to the review of the submission. All submissions will be identified as CONSULTANT may require. The data shown on the Shop Drawings will be complete with respect to quantities, dimensions, specified performance and design criteria, materials and similar data to enable CONSULTANT to review the information as required.

5.15.2 Sample Submittals

CONTRACTOR shall also submit to CONSULTANT for review and approval with such promptness as to cause no delay in Work, all samples required by the Contract Documents. All samples will have been checked by and accompanied by a specific written indication that CONTRACTOR has satisfied CONTRACTOR'S responsibilities under the Contract Documents with respect to the review of the submission and will be identified clearly as to material, Supplier, pertinent data such as catalog numbers and the use for which intended.

5.15.3 Review by CONTRACTOR

Before submission of each Shop Drawing or sample CONTRACTOR shall have determined and verified all quantities, dimensions, specified performance criteria, installation requirements, materials, catalog numbers and similar data with respect thereto and reviewed or coordinated each Shop Drawing or sample with other Shop Drawings and samples and with the requirements of the Work and the Contract Documents.

5.15.4 Notice of Variation

At the time of each submission, CONTRACTOR shall give CONSULTANT specific written notice of each variation that the Shop Drawings or samples may have from the requirements of the Contract Documents, and, in addition, shall cause a specific notation to be made on each Shop Drawing submitted to CONSULTANT for review and approval of each such variation.

5.15.5 CONSULTANT'S Approval

CONSULTANT will review and approve with reasonable promptness Shop Drawings and samples, but CONSULTANT'S review and approval will be only for conformance with the design concept of the Project and for compliance with the information given in the Contract Documents and shall not extend to means, methods, techniques, sequences or procedures of construction (except where a specific means, method, technique, sequence or

procedure of construction is indicated in or required by the Contract Documents) or to safety precautions or programs incident thereto. The review and approval of a separate item as such will not indicate approval of the assembly in which the item functions. CONTRACTOR shall make corrections required by CONSULTANT, and shall return the required number of corrected copies of Shop Drawings and submit, as required, new samples for review and approval. CONTRACTOR shall direct specific attention in writing to revisions other than the corrections called for by CONSULTANT on previous submittals.

5.15.6 Responsibility for Errors and Omissions

CONSULTANT'S review and approval of Shop Drawings or samples shall not relieve CONTRACTOR from responsibility for any variation from the requirements of the Contract Documents unless CONTRACTOR has in writing called CONSULTANT'S attention to each such variation at the time of submission as required by paragraph 5.15.4 and CONSULTANT has given written approval of each such variation by a specific written notation thereof incorporated in or accompanying the Shop Drawing or sample approval; nor will any approval by CONSULTANT relieve CONTRACTOR from responsibility for errors or omissions in the Shop Drawings or from responsibility for having complied with the provisions of paragraph 5.15.3.

5.15.7 Cost of Related Work

Where a Shop or sample is required by the Specifications, any related Work performed prior to CONSULTANT'S review and approval of the pertinent submission will be the sole expense and responsibility of CONTRACTOR.

5.16 Continuing the Work

CONTRACTOR shall carry on the Work and adhere to the progress schedule during all disputes or disagreements with OWNER. No Work shall be delayed or postponed pending resolutions of any disputes or disagreements, except as permitted by paragraph 14.5 or as CONTRACTOR and OWNER may otherwise agree in writing.

5.17 Erosion and Sediment Control

5.17.1 General Environmental Requirements

The CONTRACTOR and Subcontractors performing work on projects on behalf of the OWNER shall comply with all applicable federal, state, and local environmental regulations and all requirements and conditions set forth in "special" permits including but not limited to Corp of Engineers 404 permits, 401 Water Quality Certifications, Stream Crossing and Floodplain Encroachment Permits.

Any fines or penalties resulting from the failure to comply with the terms of the federal, state or local permits or perform necessary corrective action are solely the obligation of the CONTRACTOR.

5.17.2 Stormwater Pollution Prevention

A. The CONTRACTOR shall exercise due care to prevent or minimize any damage to any stream or wetland from pollution by debris, sediment or other material. The operation of equipment and/or materials in a jurisdictional wetland is expressly prohibited. Water that has been used for washing or processing, or that contains oils, sediments or other pollutants shall not be discharged from the job site. Such waters shall be collected and properly disposed of by the CONTRACTOR in accordance with applicable local, state and federal law.

B. The CONTRACTOR is solely responsible for securing all required state and local permits associated with stormwater discharges from the project including, but not necessarily limited to the KY Notice of Intent to Disturb (NOI) for Coverage of Storm Water Discharges Associated with Construction Activities under the KPDES Storm Water General Permit KYR100000 and the LFUCG, Land Disturbance Permit. Permit application preparation and all required documentation are the responsibility of the CONTRACTOR. The CONTRACTOR is solely responsible for maintaining compliance with the stormwater pollution prevention plan or erosion and sediment control plan and ensuring the following:

- a. That the Stormwater Pollution Prevention Plan (SWPPP) or erosion control plan is current and available for review on site;
- b. That any and all stormwater inspection reports required by the permit are conducted by qualified personnel and are available for review onsite; and
- c. That all best management practices (BMPs) are adequately maintained and effective at controlling erosion and preventing sediment from leaving the site.

C. The CONTRACTOR shall provide the necessary equipment and personnel to perform any and all emergency measures that may be required to contain any spillage or leakage and to remove materials, soils or liquids that become contaminated. The collected spill material shall be properly disposed at the CONTRACTOR's expense.

D. Upon completion of the work and with the concurrence of the OWNER, the CONTRACTOR must file a Notice of Termination (NOT) of Coverage Under the KPDES General Permit for Storm Water Discharges Associated with Construction Activity with the appropriate local and state authorities.

E. Any fines or penalties resulting from the failure to comply with the terms of the state or local stormwater permits or perform necessary corrective action are solely the obligation of the CONTRACTOR.

6. OTHER WORK

6.1 Related Work at Site

OWNER may perform other work related to the Project at the site by OWNER'S own forces, have other work performed by utility owners or let other direct contracts therefor which shall contain General Conditions similar to these. If the fact that such other work is to be performed was not noted in the Contract Documents, written notice thereof will be given to CONTRACTOR prior to starting any such other work; and, if such performance will involve additional expense to CONTRACTOR or requires additional time, a Change Order to the Contract will be negotiated.

6.2 Other Contractors or Utility Owners

CONTRACTOR shall afford each utility owner and other contractor who is a party to such a direct contract (or OWNER, if OWNER is performing the additional work with OWNER'S employees) proper and safe access to the site and a reasonable opportunity for the introduction and storage of materials and equipment and the execution of such work, and shall properly connect and coordinate the Work with theirs. CONTRACTOR shall do all cutting, fitting and patching of the Work that may be required to make its several parts come together properly and integrate with such other work. CONTRACTOR shall not endanger any work of others by cutting, excavating or otherwise altering their work and will only cut or alter their work with the written consent of CONSULTANT and the others whose work will be affected. The duties and responsibilities of CONTRACTOR under this paragraph are for the benefit of such utility owners and other contractors to the extent that there are comparable provisions for the benefit of CONTRACTOR in said direct contracts between OWNER and such utility owners and other contractors.

6.3 Delays Caused by Others

If any part of CONTRACTOR'S Work depends for proper execution or results upon the work of any such other contractor or utility owner (or OWNER), CONTRACTOR shall inspect and promptly report to CONSULTANT in writing any delays, defects or deficiencies in such work that render it unavailable or unsuitable for such proper execution and results. CONTRACTOR'S failure so to report will constitute an acceptance of the other work as fit and proper for integration with CONTRACTOR'S Work except for latent or non-apparent defects and deficiencies in the other work.

6.4 Coordination

If OWNER contracts with others for the performance of other work on the Project at the site, the person or organization who will have authority and responsibility for coordination of the activities among the various prime contractors will be identified in the Special Conditions, and the specific matters to be covered by such authority and

responsibility will be itemized, and the extent of such authority and responsibilities will be provided, in the Special Conditions.

7. OWNER'S RESPONSIBILITIES

7.1 Communications

OWNER shall issue all communications to CONTRACTOR through CONSULTANT.

7.2 Data and Payments

OWNER shall furnish the data required of OWNER under the Contract Documents promptly after they are due.

7.3 Lands, Easements, and Surveys

OWNER'S duties in respect of providing lands and easements and providing engineering surveys to establish reference points are set forth in paragraphs 4.1 and 4.4. Paragraph 4.2 refers to OWNER'S identifying and making available to CONTRACTOR copies of reports of explorations and tests of subsurface conditions at the site and in existing structures which have been utilized by CONSULTANT in preparing the Drawings and Specifications.

7.4 Change Orders

OWNER is obligated to execute Change Orders as indicated in paragraph 9.4.

7.5 Inspections, Tests and Approvals

OWNER'S responsibility in respect to certain inspections, tests and approvals is set forth in paragraph 13.3.

7.6 Stop or Suspend Work

In connection with OWNER'S right to stop Work or suspend Work, see paragraph 12.4 and 14.1 Paragraph 14.2 deals with OWNER'S rights to terminate services of CONTRACTOR under certain circumstances.

8. CONSULTANT'S STATUS DURING CONSTRUCTION

8.1 OWNER'S Representative

CONSULTANT will be OWNER'S representative during the construction period. The duties and responsibilities and the limitations of authority of CONSULTANT as OWNER'S representative during construction are set forth in the Contract Documents and shall not be extended without written consent of OWNER and CONSULTANT.

8.2 Visits to Site

CONSULTANT will make visits to the site at intervals appropriate to the various stages of construction to observe the progress and quality of the executed Work and to determine, in general, if the Work is proceeding in accordance with the Contract Documents. CONSULTANT will not be required to make exhaustive or

continuous on-site inspections to check the quality or quantity of the Work. CONSULTANT'S efforts will be directed toward providing for OWNER a greater degree of confidence that the completed Work will conform to the Contract Documents. On the basis of such visits and on-site observations, CONSULTANT will keep OWNER informed of the progress of the Work and will endeavor to guard OWNER against defects and deficiencies in the Work.

8.3 Project Representation

CONSULTANT will provide an Inspector to assist CONSULTANT in observing the performance of the Work. If OWNER designates another agent to represent OWNER at the site who is not CONSULTANT'S agent or employee, the duties, responsibilities and limitations of authority of such other person will be as provided in the Special Conditions.

8.4 Clarifications and Interpretations

CONSULTANT will issue with reasonable promptness such written clarifications or interpretations of the requirements of the Contract Documents (in the form of Drawings or otherwise) as CONSULTANT may determine necessary, which shall be consistent with or reasonably inferable from the overall intent of the Contract Documents.

8.5 Authorized Variations in Work

CONSULTANT may authorize minor variations in the Work from the requirements of the Contract Documents which do not involve an adjustment in the Contract Price or the Contract Time and are consistent with the overall intent of the Contract Documents. These may be accomplished by a Field Order.

8.6 Rejecting Defective Work

CONSULTANT will have authority to disapprove or reject Work which CONSULTANT believes to be defective, and will also have authority to require special inspection or testing of the Work as provided in paragraph 12.3, whether or not the Work is fabricated, installed or completed.

8.7 Shop Drawings

In connection with CONSULTANT'S responsibility for Shop Drawings and samples, see paragraphs 5.15.1 through 5.16 inclusive.

8.8 Change Orders

In connection with CONSULTANT'S responsibilities as to Change Orders, see Articles 10, 11 and 12.

8.9 Payments

In connection with CONSULTANT'S responsibilities with respect to Applications for Payment, etc., see Article 13.

8.10 Determinations for Unit Prices

CONSULTANT will determine the actual quantities and classifications of Unit Price Work performed by CONTRACTOR.

CONSULTANT will review with CONTRACTOR CONSULTANT'S preliminary determinations on such matters before rendering a written decision thereon (by recommendation of an Application for Payment or otherwise).

8.11 Decision on Disputes

CONSULTANT will be the initial interpreter of the requirements of the Contract Documents and judge of the acceptability of the Work thereunder. Claims, disputes and other matters relating to the acceptability of the Work or the interpretation of the requirements of the Contract Documents pertaining to the performance and furnishing of the Work and claims under Articles 10 and 11 in respect of changes in the Contract Price or Contract Time will be referred initially to CONSULTANT in writing with a request for a formal decision in accordance with this paragraph, which CONSULTANT will render in writing within a reasonable time. Written notice of each such claim, dispute and other matter will be delivered to CONSULTANT promptly (but in no event later than thirty days) after the occurrence of the event giving rise thereto, and written supporting data will be submitted to CONSULTANT within sixty days after such occurrence unless CONSULTANT allows an additional period of time to ascertain more accurate data in support of the claim.

8.12 Limitations on CONSULTANT's Responsibilities

8.12.1 CONTRACTOR, Supplier, or Surety

Neither CONSULTANT'S authority to act under this Article 8 or elsewhere in the Contract Documents nor any decision made by CONSULTANT in good faith either to exercise or not exercise such authority shall give rise to any duty or responsibility of CONSULTANT to CONTRACTOR, any Subcontractor, any Supplier, or any other person or organization performing any of the Work, or to any surety for any of them.

8.12.2 To Evaluate the Work

Whenever in the Contract Documents the terms "as ordered", "as directed", "as required", "as allowed", "as approved" or terms of like effect or import are used, or the adjectives "reasonable", "suitable", "acceptable", "proper", or "satisfactory" or adjectives or like "effect" or "import" are used to describe a requirement, direction, review or judgment of CONSULTANT as to the Work, it is intended that such requirement, direction, review or judgment will be solely to evaluate the Work for compliance with the Contract Documents (unless there is a specific statement indicating otherwise). The use of any such term or adjective shall not be effective to assign CONSULTANT any duty or authority to supervise or direct the furnishing or performance of the Work or any duty or authority to undertake responsibility contrary to the provisions of paragraph 8.12.3 or 8.12.4.

8.12.3 CONTRACTOR'S Means, Methods, Etc.

CONSULTANT will not be responsible for CONTRACTOR'S means, methods, techniques, sequences or procedures of construction, or the safety precautions and programs incident thereto, and CONSULTANT will not be responsible for CONTRACTOR'S failure to perform or furnish the Work in accordance with the Contract Documents.

8.12.4 Acts of Omissions of CONTRACTOR

CONSULTANT will not be responsible for the acts or omissions of CONTRACTOR or of any Subcontractor, any Supplier, or of any other person or organization performing or furnishing any of the Work.

9. CHANGES IN THE WORK

9.1 OWNER May Order Change

Without invalidating the Agreement and without notice to any surety, OWNER may, at any time or from time to time, order additions, deletions or revisions in the Work; these will be authorized by a Change Order. Upon receipt of such notice, CONTRACTOR shall promptly proceed with the Work involved which will be performed under the applicable conditions of the Contract Documents (except as otherwise specifically provided).

9.2 Claims

Claims for an increase or decrease in the Contract Price or an extension or shortening of the Contract Time that should be allowed as a result of a Change Order will be settled as provided for in Article 10 or Article 11.

9.3 Work Not in Contract Documents

CONTRACTOR shall not be entitled to an increase in the Contract Price or an extension of the Contract Time with respect to any Work performed that is not required by the Contract Documents as amended, modified and supplemented as provided in paragraph 3.4, except in the case of an emergency and except in the case of uncovering Work as provided in paragraph 12.3.4.

9.4 Change Orders

OWNER and CONTRACTOR shall execute appropriate Change Orders covering:

9.4.1 changes in the Work which are ordered by OWNER pursuant to paragraph 9.1, are required because of acceptance of defective Work under paragraph 12.7 or corrective defective Work under paragraph 12.8, or are agreed to by the parties;

9.4.2 changes in the Contract Price or Contract Time which are agreed to by the parties; and

9.4.3 changes in the Contract Price or Contract Time which embody the substance of any written decision rendered by CONSULTANT pursuant to paragraph 8.11; provided that, in lieu of executing any such Change Order, an appeal may be taken from any such decision in accordance with the provisions of the Contract Documents and applicable Laws and REGULATIONS, but during any such appeal, CONTRACTOR shall carry on the Work and adhere to the progress schedule as provided in paragraph 5.16.

9.5 Notice of Change

If notice of any change affecting the general scope of the Work or the provisions of the Contract Documents (including, but not limited to, Contract Price or Contract Time) is required by the provisions of any Bond to be given to a surety, the giving of any such notice will be CONTRACTOR'S responsibility, and the amount of each applicable Bond will be adjusted accordingly.

10. CHANGE OF CONTRACT PRICE

10.1 Total Compensation

The Contract Price constitutes the total compensation (subject to authorized adjustments) payable to CONTRACTOR for performing the Work. All duties, responsibilities and obligations assigned to or undertaken by CONTRACTOR shall be at his expense without change in the Contract Price.

10.2 Claim for Increase or Decrease in Price

The Contract Price may only be changed by a Change Order. Any claim for an increase or decrease in the Contract Price shall be based on written notice delivered by the CONTRACTOR to the CONSULTANT promptly (but in no event later than thirty days) after the occurrence of the event giving rise to the claim and stating the general nature of the claim. Notice of the amount of the claim with supporting data shall be delivered within sixty days after such occurrence (unless CONSULTANT allows an additional period of time to ascertain more accurate data in support of the claim) and shall be accompanied by CONTRACTOR'S written statement that the amount claimed covers all known amounts (direct, indirect, and consequential) to which the CONTRACTOR is entitled as a result of the occurrence of said event.

10.3 Value of Work

The value of any Work covered by a Change Order or of any claim for an increase or decrease in the Contract Price shall be determined in one of the following ways:

10.3.1 Unit Prices

Where the Work involved is covered by unit prices contained in the Contract Documents, by application of unit prices to the quantities of the items involved (subject to the provisions of paragraphs 10.9.1. through 10.9.3, inclusive).

10.3.2 Lump Sum

By mutual acceptance of a lump sum (which may include an allowance for overhead and profit not necessarily in accordance with paragraph 10.6.2.1).

10.3.3 Cost Plus Fee

On the basis of the Cost of the Work (determined as provided in paragraphs 10.4 and 10.5) plus a CONTRACTOR'S fee for overhead and profit (determined as provided in paragraphs 10.6 and 10.7).

10.4 Cost of the Work

The term Cost of the Work means the sum of all costs necessarily incurred and paid by CONTRACTOR in the proper performance of the Work. Except as otherwise may be agreed to in writing by OWNER, such costs shall be in amounts no higher than those prevailing in the locality of the Project; shall include only the following items; and shall not include any of the costs itemized in paragraph 10.5:

10.4.1 Payroll Costs

Payroll costs for employees in the direct employ of CONTRACTOR in the performance of the Work under schedules of job classifications agreed upon by OWNER and CONTRACTOR. Payroll costs for employees not employed full time on the Work shall be apportioned on the basis of their time spent on the Work. Payroll costs shall include, but not be limited to, salaries and wages plus the cost of fringe benefits which shall include social security contributions, unemployment, excise and payroll taxes, workers' or workmen's compensation, health and retirement benefits, bonuses, sick leave, vacation and holiday pay applicable thereto. Such employees shall include superintendents and foremen at the site. The expenses of performing Work after regular working hours, on Saturday, Sunday or legal holidays, shall be included in the above to the extent authorized by OWNER.

10.4.2 Materials and Equipment Costs

Cost of all materials and equipment furnished and incorporated in the Work, including costs of transportation and storage thereof, and Suppliers' field services required in connection therewith. All cash discounts shall accrue to CONTRACTOR unless OWNER deposits funds with CONTRACTOR with which to make payments, in which case the cash discounts shall accrue to OWNER. All trade discounts, rebates and refunds and all returns from sale of surplus materials and equipment shall accrue to OWNER, and CONTRACTOR shall make provisions so that they may be obtained.

10.4.3 Subcontractor Costs

Payments made by CONTRACTOR to the Subcontractors for Work performed by Subcontractors. If required by OWNER, CONTRACTOR shall obtain competitive bids from Subcontractors acceptable to CONTRACTOR and shall deliver such bids to OWNER who will then determine, with the advice of CONSULTANT, which bids will be accepted. If a subcontract provides that the Subcontractor is to be paid on the basis of Cost of the Work Plus a Fee, the Subcontractor's Cost of the Work shall be determined in the same manner as CONTRACTOR'S Cost of the Work. All subcontracts shall be subject to the other provisions of the Contract Documents insofar as applicable.

10.4.4 Special Consultant Costs

Costs of special consultants (including but not limited to engineers, architects, testing laboratories, surveyors, attorneys and accountants) employed for services specifically related to the Work.

10.4.5 Supplemental Costs

10.4.5.1 The proportion of necessary transportation, travel and subsistence expenses of CONTRACTOR'S employees incurred in discharge of duties connected with the Work.

10.4.5.2 Cost, including transportation and maintenance, of all materials, supplies, equipment, machinery, appliances, office and temporary facilities at the site and hand tools not owned by the workers, which are consumed in the performance of the Work, and cost less market value of such items used but not consumed which remain the property of CONTRACTOR.

10.4.5.3 Rentals of all construction equipment and machinery and the parts thereof whether rented from CONTRACTOR or others in accordance with rental agreements approved by OWNER with the advice of CONSULTANT, and the costs of transportation, loading, unloading, installation, dismantling and removal shall be in accordance with terms of said rental agreements. The rental of any such equipment, machinery or parts shall cease when the use thereof is no longer necessary for the Work.

10.4.5.4 Sales, consumer, use or similar taxes related to the Work, and for which CONTRACTOR is liable, imposed by Laws and Regulations.

10.4.5.5 Deposits lost for causes other than negligence of CONTRACTOR, any Subcontractor or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, and royalty payments and fees for permits and licenses.

10.4.5.6 Losses and damages (and related expenses), not compensated by insurance or otherwise, to the Work or otherwise sustained by CONTRACTOR in connection with the performance and furnishing of the Work (except losses and damages within the deductible amounts of property insurance established by OWNER), provided they have resulted from causes other than the negligence of CONTRACTOR, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable. Such losses shall include settlements made with the written consent and approval of OWNER. No such losses, damages and expenses shall be included in the Cost of the Work for the purpose of determining CONTRACTOR'S fee. If, however, any such loss or damage requires reconstruction and CONTRACTOR is placed in charge thereof, CONTRACTOR shall be paid a fee proportionate to that stated in paragraph 10.6.2 for services.

10.4.5.7 The cost of utilities, fuel and sanitary facilities at the site.

10.4.5.8 Minor expenses such as telegrams, long distance telephone calls, telephone service at the site, expressage and similar petty cash items in connection with the Work.

10.4.5.9 Cost of premiums for additional Bonds and insurance required because of changes in the Work and premiums for property insurance coverage within the limits of the deductible amounts established by OWNER.

10.5 Not to Be Included in Cost of the Work

The term Cost of the Work shall not include any of the following:

10.5.1 Costs of Officers and Executives

Payroll costs and other compensation of CONTRACTOR'S officers, executives, principals (of partnership and sole proprietorships), general managers, engineers, architects, estimators, attorneys, auditors, accountants, purchasing and contracting agents, expeditors, timekeepers, clerks and other personnel employed by CONTRACTOR whether at the site or in CONTRACTOR'S principal or a branch office for general administration of

the Work and not specifically included in the agreed upon schedule of job classifications referred to in paragraph 10.4.1 or specifically covered by paragraph 10.4.4 - all of which are to be considered administrative costs covered by the CONTRACTOR'S fee.

10.5.2 Principal Office

Expenses of CONTRACTOR'S principal and branch offices other than CONTRACTOR'S office at the site.

10.5.3 Capital Expense

Any part of CONTRACTOR'S capital expenses, including interest on CONTRACTOR'S capital employed for the Work and charges against CONTRACTOR for delinquent payments.

10.5.4 Bonds and Insurance

Cost of premiums for all Bonds and for all insurance whether or not CONTRACTOR is required by the Contract Documents to purchase and maintain the same (except for the cost of premiums covered by subparagraph 10.4.5.9 above).

10.5.5 Costs Due to Negligence

Costs due to the negligence of CONTRACTOR, any Subcontractor, or anyone directly or indirectly employed by any of them or for whose acts any of them may be liable, including but not limited to, the correction of defective Work, disposal of materials or equipment wrongly supplied and making good any damage to property.

10.5.6 Other Costs

Other overhead or general expense costs of any kind and the costs of any item not specifically and expressly included in paragraph 10.4.

10.6 Contractor's Fee

The CONTRACTOR'S Fee allowed to CONTRACTOR for overhead and profit shall be determined as follows:

10.6.1 a mutually acceptable fixed fee; or if none can be agreed upon,

10.6.2 a fee based on the following percentages of the various portions of the Cost of the Work:

10.6.2.1 for costs incurred under paragraphs 10.4.1 and 10.4.2, the CONTRACTOR'S fee shall be fifteen percent;

10.6.2.2 for costs incurred under paragraph 10.4.3, the CONTRACTOR'S fee shall be five percent; and if a subcontract is on the basis of Cost of the Work Plus a fee, the maximum allowable to CONTRACTOR on account of overhead and profit of all Subcontractors shall be fifteen percent;

10.6.2.3 no fee shall be payable on the basis of costs itemized under paragraphs 10.4.4, 10.4.5 and 10.5;

10.6.2.4 the amount of credit to be allowed by CONTRACTOR to OWNER for any such change which results in a net decrease in cost will be the amount of the actual net decrease plus a deduction in CONTRACTOR'S Fee by an amount equal to ten percent of the net decrease; and

10.6.2.5 when both additions and credits are involved in any one change, the adjustment in CONTRACTOR'S fee shall be computed on the basis of the net change in accordance with paragraphs 10.6.2.1 through 10.6.2.4, inclusive.

10.7 Itemized Cost Breakdown

Whenever the cost of any Work is to be determined pursuant to paragraph 10.4 or 10.5, CONTRACTOR will submit in form acceptable to CONSULTANT an itemized cost breakdown together with supporting data.

10.8 Cash Allowances

It is understood that CONTRACTOR has included in the Contract Price all allowances so named in the Contract Documents and shall cause the Work so covered to be done by such Subcontractors or Suppliers and for such sums within the limit of the allowances as may be acceptable to CONSULTANT, CONTRACTOR agrees that:

10.8.1 Materials and Equipment

The allowances include the cost to CONTRACTOR (less any applicable trade discounts) of materials and equipment required by the allowances to be delivered at the site, and all applicable taxes; and

10.8.2 Other Costs

CONTRACTOR'S costs for unloading and handling on the site, labor, installation costs, overhead, profit and other expenses contemplated for the allowances have been included in the Contract Price and not in the allowances. No demand for additional payment on account of any thereof will be valid.

10.8.3 Change Order

Prior to final payment, an appropriate Change Order will be issued as recommended by CONSULTANT to reflect actual amounts due CONTRACTOR on account of Work covered by allowances, and the Contract Price shall be correspondingly adjusted.

10.9 Unit Price Work

10.9.1 General

Where the Contract Documents provide that all or part of the Work is to be Unit Price Work, initially the Contract Price will be deemed to include for all Unit Price Work an amount equal to the sum of the established unit prices for each separately identified item of Unit Price Work times the estimated quantity of each item as indicated in the Agreement. The estimated quantities of items of Unit Price Work are not guaranteed and are solely for the purpose of comparison of Bids and determining an initial Contract Price. Determinations of the actual quantities and classifications of Unit Price Work performed by CONTRACTOR will be made by CONSULTANT in accordance with Paragraph 8.10.

10.9.2 Overhead and Profit

Each unit price will be deemed to include an amount considered by CONTRACTOR to be adequate to cover CONTRACTOR'S overhead and profit for each separately identified item.

10.9.3 Claim for Increase in Unit Price

Where the quantity of any item of Unit Price Work performed by CONTRACTOR differs materially and significantly from the estimated quantity of such item indicated in the Agreement and there is no corresponding adjustment with respect to any other item of Work and if CONTRACTOR believes that CONTRACTOR has incurred additional expense as a result thereof, CONTRACTOR may make a claim for an increase in the Contract Price in accordance with Article 10.

11. CHANGE OF CONTRACT TIME

11.1 Change Order

The Contract Time may only be changed by a Change Order. Any claim for an extension or shortening of the Contract Time shall be based on written notice delivered to CONSULTANT promptly (but in no event later than thirty days) after the occurrence of the event giving rise to the claim and stating the general nature of the claim. Notice of the extent of the claim with supporting data shall be delivered within sixty days after such occurrence (unless CONSULTANT allows an additional period of time to ascertain more accurate data in support of the claim) and shall be accompanied by the claimant's written statement that the adjustment claimed is the entire adjustment to which the claimant has reason to believe it is entitled as a result of the occurrence of said event. All claims for adjustment in the Contract Time shall be determined by CONSULTANT in accordance with paragraph 8.11. No claim for an adjustment in the Contract Time will be valid if not submitted in accordance with the requirements of this paragraph 11.1.

11.2 Justification for Time Extensions

The Contract Time will be extended in an amount equal to time lost due to delays beyond the control of CONTRACTOR if a claim is made therefore as provided in paragraph 11.1. Such delays shall include, but not be limited to, acts or neglect by OWNER or others performing additional work as contemplated by Article 6, or to fires, floods, labor disputes, epidemics, abnormal weather conditions or acts of God.

11.3 Time Limits

All time limits stated in the Contract Documents are of the essence of the Agreement. The provisions of this Article 11 shall not exclude recovery for damages (including but not limited to fees and charges of engineers, architects, attorneys and other professionals and court costs) for delay by either party.

12. WARRANTY AND GUARANTEE; TESTS AND INSPECTIONS; CORRECTION, REMOVAL OR ACCEPTANCE OF DEFECTIVE WORK

12.1 Warranty and Guarantee

CONTRACTOR warrants and guarantees to OWNER and CONSULTANT that all Work will be in accordance with the Contract Documents and will not be defective. All defective Work, whether or not in place, may be rejected, corrected or accepted as provided in this Article 12.

12.2 Access to Work

CONSULTANT and CONSULTANT'S representatives, other representatives of OWNER, testing agencies and governmental agencies with jurisdictional interests will have access to the Work at reasonable times for their observation, inspecting and testing. CONTRACTOR shall provide proper and safe conditions for such access.

12.3 Tests and Inspections

12.3.1 Timely Notice

CONTRACTOR shall give CONSULTANT timely notice of readiness of the Work for all required inspections, tests or approvals.

12.3.2 Requirements and Responsibilities

The CONSULTANT may require such inspection and testing during the course of the Work as he/she deems necessary to ascertain and assure the integrity and acceptable quality of the materials incorporated and the work performed. Inspection presence may be either full-time or intermittent, and neither the presence nor absence at any time of the CONSULTANT or the INSPECTOR shall relieve the CONTRACTOR of sole responsibility for the acceptability and integrity of the Work or any part thereof.

The costs of sampling, testing, and inspection on-site to ascertain acceptability of the Work and materials will be borne by the OWNER except as otherwise provided. The OWNER will select a testing laboratory to perform such sampling and testing. Sampling and/or testing required by the CONTRACTOR or necessitated by failure of Work or materials to meet the above acceptability test shall be at the expense of the CONTRACTOR.

Inspection services may be performed by the employees of the OWNER or by others selected or designated by the OWNER or the CONSULTANT.

Sampling and/or testing required for manufacturing quality and/or process control, for certification that raw mineral materials or manufactured products are the quality specified in the contract, or to assure the acceptability for incorporation into the Work shall be borne by the CONTRACTOR or the material supplier.

Cost for inspection, sampling, testing, and approvals required by the laws or regulations of any public body having competent jurisdiction shall be borne by the CONTRACTOR or the material supplier.

Sampling and testing will be in accord with pertinent codes and regulations and with appropriate standards of the American Society of Testing Materials or other specified standards.

12.3.3 On-Site Construction Test and Other Testing

All inspections, tests or approvals other than those required by Laws or Regulations of any public body having jurisdiction shall be performed by organizations acceptable to OWNER and CONTRACTOR (or by CONSULTANT if so specified).

12.3.4 Covered Work

If any Work (including the work of others) that is to be inspected, tested or approved is covered without written concurrence of CONSULTANT, it must, if requested by CONSULTANT, be uncovered for observation. Such uncovering shall be at CONTRACTOR'S expense unless CONTRACTOR has given CONSULTANT timely notice of CONTRACTOR'S intention to cover the same and CONSULTANT has not acted with reasonable promptness in response to such notice.

12.3.5 CONTRACTOR'S Obligation

Neither observations by CONSULTANT nor inspections, tests or approvals by others shall relieve CONTRACTOR from CONTRACTOR'S obligations to perform the Work in accordance with the Contract Documents.

12.4 OWNER May Stop the Work

If the Work is defective, or CONTRACTOR fails to supply sufficient skilled workers or suitable materials or equipment, or fails to furnish or perform the Work in such a way that the completed Work will conform to the Contract Documents, OWNER may order CONTRACTOR to stop the Work, or any portion thereof, until the cause for such order has been eliminated; however, this right of OWNER to stop the Work shall not give rise to any duty on the part of OWNER to exercise this right for the benefit of CONTRACTOR or any other party.

12.5 Correction or Removal of Defective Work

If required by CONSULTANT, CONTRACTOR shall promptly, as directed, either correct all defective Work, whether or not fabricated, installed or completed, or, if the Work has been rejected by CONSULTANT, remove it from the site and replace it with non-defective Work. CONTRACTOR shall bear all direct, indirect and consequential costs of such correction or removal (including but not limited to fees and charges of engineers, architects, attorneys and other professionals) made necessary thereby.

12.6 One Year Correction Period

If within one year after the date of Completion or such longer period of time as may be prescribed by Laws or Regulations or by the terms of any applicable special guarantee required by the Contract Documents or by any specific provision of the Contract Documents, any Work is found to be defective, CONTRACTOR shall promptly, without cost to OWNER and in accordance with OWNER'S written instructions, either correct such defective Work, or, if it has been rejected by OWNER, remove it from the site and replace it with non-defective Work. If CONTRACTOR does not promptly comply with the terms of such instructions, or in an emergency where delay would cause serious risk of loss or damage, OWNER may have the defective Work corrected or the rejected Work removed and replaced, and all direct, indirect and consequential costs of such removal and replacement

(including but not limited to fees and charges of engineers, architects, attorneys and other professionals) will be paid by CONTRACTOR. In special circumstances where a particular item of equipment is placed in continuous service before Completion of all the Work, the correction period for that item may start to run from an earlier date if so provided in the Specifications or by Change Order.

12.7 Acceptance of Defective Work

If, instead of requiring correction or removal and replacement of defective Work, OWNER prefers to accept it, OWNER may do so. CONTRACTOR shall bear all direct, indirect and consequential costs attributable to OWNER'S evaluation of and determination to accept such defective Work (such costs to be approved by CONSULTANT as to reasonableness and to include but not be limited to fees and charges of engineers, architects, attorneys and other professionals).

12.8 OWNER May Correct Defective Work

If CONTRACTOR fails within a reasonable time after written notice of CONSULTANT to proceed to correct and to correct defective Work or to remove and replace rejected Work as required by CONSULTANT in accordance with paragraph 12.5, or if CONTRACTOR fails to perform the Work in accordance with the Contract Documents, or if CONTRACTOR fails to comply with any other provision of the Contract Documents, OWNER may, after seven days' written notice to CONTRACTOR, correct and remedy any such deficiency. In exercising the rights and remedies under this paragraph OWNER shall proceed expeditiously. To the extent necessary to complete corrective and remedial action, OWNER may exclude CONTRACTOR from all or part of the site, take possession of all or part of the Work, and suspend CONTRACTOR'S services related thereto, take possession of CONTRACTOR'S tools, appliances, construction equipment and machinery at the site and incorporate in the Work all materials and equipment stored at the site or for which OWNER has paid CONTRACTOR but which are stored elsewhere. CONTRACTOR shall allow OWNER, OWNER'S representatives, agents and employees such access to the site as may be necessary to enable OWNER to exercise the rights and remedies under this paragraph. All direct, indirect and consequential costs of OWNER in exercising such rights and remedies will be charged against CONTRACTOR in an amount approved as to reasonableness by CONSULTANT, and a Change Order will be issued incorporating the necessary revisions in the Contract Documents with respect to the Work; and OWNER shall be entitled to an appropriate decrease in the Contract Price. Such direct, indirect and consequential costs will include but not be limited to fees and charges of engineers, architects, attorneys and other professionals, all court costs and all costs of repair and replacement of work of others destroyed or damaged by correction, removal or replacement of CONTRACTOR'S defective Work. CONTRACTOR shall not be allowed an extension of the Contract Time because of any delay in performance of the Work attributable to the exercise by OWNER of OWNER'S rights and remedies hereunder.

13. PAYMENTS TO CONTRACTOR AND COMPLETION

13.1 Schedule of Values

The schedule of values established as provided in paragraph 2.8 will serve as the basis for progress payments and will be incorporated into a form of Application for Payment acceptable to CONSULTANT. Progress payments on account of Unit Price Work will be based on the number of units completed.

13.2 Application for Progress Payment

At least ten days before each progress payment is scheduled (but not more often than once a month), CONTRACTOR shall submit to CONSULTANT for review an Application for Payment filled out and signed by CONTRACTOR covering the Work completed as of the date of the Application and accompanied by such supporting documentation as is required by the Contract Documents. If payment is requested on the basis of materials and equipment not incorporated in the Work but delivered and suitably stored at the site or at another location agreed to in writing, the Application for Payment shall also be accompanied by a bill of sale, invoice or other documentation warranting that OWNER has received the materials and equipment free and clear of all liens, charges, security interests and encumbrances (which are hereinafter in these General Conditions referred to as "Liens") and evidence that the materials and equipment are covered by appropriate property insurance and other arrangements to protect OWNER'S interest therein, all of which will be satisfactory to OWNER. OWNER shall, within thirty (30) calendar days of presentation to him of an approved Application for Payment, pay CONTRACTOR the amount approved by CONSULTANT. Monthly progress payments shall be ninety (90) percent of the sum obtained by applying the respective bid unit prices to the approved estimated quantities of work completed by the Contractor during the preceding month. The remaining ten (10) percent will be held by the Owner, as retainage. At such time as the CONSULTANT deems appropriate - based on the quality of work performed, progress of cleanup, and other pertinent factors - the rate of retainage, or the total amount retained, may be reduced; although, any reduction in retainage, below the ten (10) percent level, is made solely at the CONSULTANT's discretion. All remaining retainage held will be included in the final payment to the Contractor.

13.3 CONTRACTOR'S Warranty of Title

CONTRACTOR warrants and guarantees that title to all Work, materials and equipment covered by any Application for Payment, whether incorporated in the Project or not, will pass to OWNER no later than the time of payment free and clear of all Liens.

13.4 Review of Applications for Progress Payment

13.4.1 Submission of Application for Payment

CONSULTANT will, after receipt of each Application for Payment, either indicate in writing a recommendation of payment and present the Application to OWNER, or return the Application to CONTRACTOR indicating in writing CONSULTANT'S reasons for refusing to recommend payment. In the latter case, CONTRACTOR may make the necessary corrections and resubmit the Application.

13.4.2 CONSULTANT'S Recommendation

CONSULTANT may refuse to recommend the whole or any part of any payment, if, in CONSULTANT'S opinion, it would be incorrect to make such representations to OWNER. CONSULTANT may also refuse to recommend any such payment, or, because of subsequently discovered evidence or the results of subsequent inspections or tests, nullify any such payment previously recommended, to such extent as may be necessary in CONSULTANT'S opinion to protect OWNER from loss because:

13.4.2.1 the Work is defective, or completed Work has been damaged requiring correction or replacement;

13.4.2.2 the Contract Price has been reduced by Written Amendment or Change Order;

13.4.2.3 OWNER has been required to correct defective Work or complete Work in accordance with paragraph 12.8; or

13.4.2.4 of CONSULTANT's actual knowledge of the occurrence of any of the events enumerated in paragraphs 14.2.1 through 14.2.9 inclusive.

13.5 Partial Utilization

OWNER at any time may request CONTRACTOR in writing to permit OWNER to use any such part of the Work which OWNER believes to be ready for its intended use and has been completed. If CONTRACTOR agrees, CONTRACTOR will certify to OWNER that said part of the Work is complete and request that a Certificate of Completion be issued for that part of the Work.

13.6 Final Inspection

Upon written notice from CONTRACTOR that the entire Work or an agreed portion thereof is complete, CONSULTANT will make a final inspection with CONTRACTOR and will notify CONTRACTOR in writing of all particulars in which this inspection reveals that the Work is incomplete or defective. CONTRACTOR shall immediately take such measures as are necessary to remedy such deficiencies.

13.7 Final Application for Payment

After CONTRACTOR has completed all such corrections to the satisfaction of CONSULTANT and delivered all maintenance and operating instructions, schedules, guarantees, Bonds, certificates of inspection, marked-up record documents (as provided in paragraph 5.14) and other documents - all as required by the Contract Documents, and after CONSULTANT has indicated that the Work is acceptable (subject to the provisions of paragraph 13.10), CONTRACTOR may make application for final payment following the procedure for progress payments. The final Application for Payment shall be accompanied by all documentation called for in the Contract Documents, together with complete and legally effective releases or waivers (satisfactory to OWNER) of all Liens arising out of or filed in connection with the Work. In lieu thereof and as approved by OWNER, CONTRACTOR may furnish receipts or releases in full; an affidavit of CONTRACTOR that the releases and receipts include all labor, services, material and equipment for which a Lien could be filed, and that all payrolls, material and equipment bills, and other indebtedness connected with the Work for which OWNER or OWNER'S property might in any way be responsible, have been paid or otherwise satisfied; and consent of the surety, if any, to final payment. If any Subcontractor or Supplier fails to furnish a release or receipt in full, CONTRACTOR may furnish a Bond or other collateral satisfactory to OWNER to indemnify OWNER against any Lien.

13.8 Final Payment and Acceptance

13.8.1 CONSULTANT'S Approval

If, on the basis of CONSULTANT'S observation of the Work during construction and final inspection, and CONSULTANT'S review of the final Application for Payment and accompanying documentation - all as required by the Contract Documents, CONSULTANT is satisfied that the Work has been completed and CONTRACTOR'S other obligations under the Contract Documents have been fulfilled, CONSULTANT will, after receipt of the final Application for Payment, indicate in writing CONSULTANT'S recommendation of payment and present the Application to OWNER for payment. Thereupon CONSULTANT will give written notice to OWNER and CONTRACTOR that the Work is acceptable, subject to the provisions of paragraph 13.10. Otherwise, CONSULTANT will return the Application to CONTRACTOR, indicating in writing the reasons for refusing to recommend final payment, in which case CONTRACTOR shall make the necessary corrections and resubmit the Application.

13.8.2 Delay in Completion of Work

If, through no fault of CONTRACTOR, final completion of the Work is significantly delayed, OWNER shall, upon receipt of CONTRACTOR'S final Application for Payment and recommendation of CONSULTANT, and without terminating the Agreement, make payment of the balance due for that portion of the Work fully completed and accepted. If the remaining balance to be held by OWNER for Work not fully completed or corrected is

less than the retainage stipulated in the Agreement, and if Bonds have been furnished as required in paragraph 10 of Part II, Information for Bidders, the written consent of the surety to the payment of the balance due for that portion of the Work fully completed and accepted shall be submitted by CONTRACTOR to CONSULTANT with the Application for such payment. Such payment shall be made under the terms and conditions governing final payment, except that it shall not constitute a waiver of claims.

13.9 CONTRACTOR'S Continuing Obligation

CONTRACTOR'S obligation to perform and complete the Work in accordance with the Contract Documents shall be absolute. Neither recommendation of any progress or final payment by CONSULTANT, nor the issuance of a certificate of Completion, nor any payment by OWNER to CONTRACTOR under the Contract Documents, nor any use or occupancy of the Work or any part thereof by OWNER, nor any act of acceptance by OWNER nor any failure to do so, nor any review and approval of a Shop Drawing or sample submission, nor any correction of defective Work by OWNER will constitute an acceptance of Work not in accordance with the Contract Documents or a release of CONTRACTOR'S obligation to perform the Work in accordance with the Contract Documents (except as provided in paragraph 13.10).

13.10 Waiver of Claims

The making and acceptance of final payment will constitute:

13.10.1 a waiver of all claims by OWNER against CONTRACTOR, except claims arising from unsettled Liens, from defective Work appearing after final inspection or from failure to comply with the Contract Documents or the terms of any special guarantees specified therein; however, it will not constitute a waiver by OWNER of any rights in respect of CONTRACTOR'S continuing obligations under the Contract Documents; and

13.10.2 a waiver of all claims by CONTRACTOR against OWNER other than those previously made in writing and still unsettled.

14. SUSPENSION OF WORK AND TERMINATION

14.1 OWNER May Suspend Work

OWNER may, at any time and without cause, suspend the Work or any portion thereof for a period of not more than ninety days by notice in writing to CONTRACTOR and CONSULTANT which will fix the date on which Work will be resumed. CONTRACTOR shall resume the Work on the date so fixed. CONTRACTOR shall be allowed an increase in the Contract Price or an extension of the Contract Time, or both, directly attributable to any suspension if CONTRACTOR makes an approved claim therefor as provided in Articles 10 and 11.

14.2 OWNER May Terminate

The OWNER may terminate the Work upon the occurrence of any one or more of the following events:

14.2.1 if CONTRACTOR commences a voluntary case under any chapter of the Bankruptcy Code (Title 11, United States Code), as now or hereafter in effect, or if CONTRACTOR takes any equivalent or similar action by filing a petition or otherwise under any other federal or state law in effect at such time relating to the bankruptcy or insolvency;

14.2.2 if a petition is filed against CONTRACTOR under any chapter of the Bankruptcy Code as now or hereafter in effect at the time of filing, or if a petition is filed seeking any such equivalent or similar relief against CONTRACTOR under any other federal or state law in effect at the time relating to bankruptcy or insolvency;

14.2.3 if CONTRACTOR makes a general assignment for the benefit of creditors;

14.2.4 if a trustee, receiver, custodian or agent of CONTRACTOR is appointed under applicable law or under contract, whose appointment or authority to take charge of property of CONTRACTOR is for the purpose of enforcing a Lien against such property or for the purpose of general administration of such property for the benefit of CONTRACTOR'S creditors;

14.2.5 if CONTRACTOR admits in writing an inability to pay its debts generally as they become due;

14.2.6 if CONTRACTOR persistently fails to perform the Work in accordance with the Contract Documents (including, but not limited to, failure to supply sufficient skilled workers or suitable materials or equipment or failure to adhere to the progress schedule established under paragraph 2.8 as revised from time to time);

14.2.7 if CONTRACTOR disregards Laws or Regulations of any public body having jurisdiction;

14.2.8 if CONTRACTOR disregards the authority of CONSULTANT, or

14.2.9 if CONTRACTOR otherwise violates in any substantial way any provisions of the Contract Documents;

OWNER may, after giving CONTRACTOR (and the surety) seven days' written notice and to the extent permitted by Laws and Regulations,

terminate the services of CONTRACTOR, exclude CONTRACTOR from the site and take possession of the Work and of all CONTRACTOR'S tools, appliances, construction equipment and machinery at the site and use the same to the full extent they could be used by CONTRACTOR (without liability to CONTRACTOR for trespass or conversion), incorporate in the Work all materials and equipment stored at the site or for which OWNER has paid CONTRACTOR but which are stored elsewhere, and finish the Work as OWNER may deem expedient. In such case CONTRACTOR shall not be entitled to receive any further payment until the Work is finished. If the unpaid balance of the Contract Price exceeds the direct, indirect and consequential costs of completing the Work (including but not limited to fees and charges of engineers, architects, attorneys and other professionals and court and arbitration costs) such excess will be paid to CONTRACTOR. If such costs exceed such unpaid balance, CONTRACTOR shall pay the difference to OWNER. Such costs incurred by OWNER will be approved as to reasonableness by CONSULTANT and incorporated in a Change Order, but when exercising any rights or remedies under this paragraph OWNER shall not be required to obtain the lowest price for the Work performed.

14.2.10 If safety violations are observed and brought to the Contractors attention and Contractor fails to take immediate corrective measures any repeat of similar safety violations, Owner will order an immediate termination of contract. Note: it is the Contractor's responsibility to know proper safety measures as they pertain to construction and OSHA.

14.2.11 This contract may be canceled by either party thirty (30) days after delivery by canceling party of written notice of intent to cancel to the other contracting party.

14.2.12 This contract may be canceled by the Lexington-Fayette Urban County Government if it is determined that the Bidder has failed to perform under the terms of this agreement, such cancellation to be effective upon receipt of written notice of cancellation by the Bidder.

14.3 CONTRACTOR'S Services Terminated

Where CONTRACTOR'S services have been so terminated by OWNER, the termination will not affect any rights or remedies of OWNER against CONTRACTOR then existing or which may thereafter accrue. Any retention or payment of moneys due CONTRACTOR by OWNER will not release CONTRACTOR from liability.

14.4 Payment After Termination

Upon seven days' written notice to CONTRACTOR, OWNER may, without cause and without prejudice to any other right or remedy, elect to abandon the Work and terminate the Agreement. In such case, CONTRACTOR shall be paid for all Work executed and any expense sustained plus reasonable termination expenses, which

will include, but not be limited to, direct, indirect and consequential costs (including, but not limited to, fees and charges of engineers, architects, attorneys and other professionals and court and arbitration costs).

14.5 CONTRACTOR May Stop Work or Terminate

If, through no act or fault of CONTRACTOR, the Work is suspended for a period of more than ninety days by OWNER or under an order of court or other public authority, or CONSULTANT fails to act on any Application for Payment within sixty days after it is submitted, or OWNER fails for sixty days to pay CONTRACTOR any sum finally determined to be due, then CONTRACTOR may, upon seven days' written notice to OWNER and CONSULTANT, terminate the Agreement and recover from OWNER payment for all Work executed and any expense sustained plus reasonable termination expenses. In addition and in lieu of terminating the Agreement, if CONSULTANT has failed to act on an Application for Payment or OWNER has failed to make any payment as aforesaid, CONTRACTOR may upon seven days' written notice to OWNER and CONSULTANT stop the Work until payment of all amounts then due. The provisions of this paragraph shall not relieve CONTRACTOR of the obligations under paragraph 5.16 to carry on the Work in accordance with the progress schedule and without delay during disputes and disagreements with OWNER.

15. MISCELLANEOUS

15.1 Claims for Injury or Damage

Should OWNER or CONTRACTOR suffer injury or damage to person or property because of any error, omission or act of the other party or of any of the other party's employees or agents or others for whose acts the other party is legally liable, claim will be made in writing to the other party within a reasonable time of the first observance of such injury or damage. The provisions of this paragraph 15.1 shall not be construed as a substitute for or a waiver of the provisions of any applicable statute of limitations or repose.

15.2 Non-Discrimination in Employment

The CONTRACTOR shall comply with the following requirements prohibiting discrimination:

15.2.1 That no person (as defined in KRS 344.010) shall bid on Lexington-Fayette Urban County Government construction projects, or bid to furnish materials or supplies to the Lexington-Fayette Urban County Government, if, within six months prior to the time of opening of bids, said person shall have been found, by declaratory judgment action in Fayette Circuit Court, to be presently engaging in an unlawful practice, as hereinafter defined. Such declaratory judgment action may be brought by an aggrieved individual or upon an allegation that an effort at conciliation pursuant to KRS 344.200 has been attempted and failed, by the Lexington-Fayette County Human Rights Commission.

15.2.2 That it is an unlawful practice for an employer:

15.2.2.1 to fail or refuse to hire, or to discharge any individual or otherwise to discriminate against an individual, with respect to his compensation, terms, conditions, or privileges of employment, because of such individual's race, color, religion, sex, age, or national origin; or

15.2.2.2 to limit, segregate or classify his employees in any way which would deprive or tend to deprive an individual of employment opportunities or otherwise adversely affect his status as an employee because of such individual's sex, race, color, religion, age, or national origin.

15.2.3 That it is an unlawful practice for an employer, labor organization, or joint-labor management committee controlling apprenticeship or other training or retraining, including on-the-job training programs to discriminate against an individual because of his race, color, religion, sex, age, or national origin in admission to, or employment in, any program established to provide apprenticeship or other training.

15.2.4 That a copy of this Ordinance shall be furnished all suppliers and made a part of all bid specifications.

15.2.5 This Ordinance shall take effect after it is signed, published and recorded, as required by law.

15.3 Temporary Street Closing or Blockage

The CONTRACTOR will notify the CONSULTANT at least 72 hours prior to making any temporary street closing or blockage. This will permit orderly notification to all concerned public agencies. Specific details and restrictions on street closure or blockage are contained in the Special Conditions.

15.4 Percentage of Work Performed by prime CONTRACTOR

The CONTRACTOR shall perform on site, and with its own organization, Work equivalent to at least fifty (50%) percent of the total amount of Work to be performed under the Contract. This percentage may be reduced by a supplemental agreement to this Contract if, during performing the Work, the CONTRACTOR requests a reduction and the CONSULTANT determines that the reduction would be to the advantage of the OWNER.

15.5 Clean-up

Cleanup shall progress, to the greatest degree practicable, throughout the course of the Work. The Work will not be considered as completed, and final payment will not be made, until the right-of-way and all ground occupied or affected by the

Contractor in connection with the Work has been cleared of all rubbish, equipment, excess materials, temporary structures, and weeds. Rubbish and all waste materials of whatever nature shall be disposed of, off of the project site, in an acceptable manner. All property, both public and private, which has been damaged in the prosecution of the Work, shall be restored in an acceptable manner. All areas shall be draining, and all drainage ways shall be left unobstructed, and in such a condition that drift will not collect or scour be induced.

15.6 General

The duties and obligations imposed by these General Conditions and the rights and remedies available hereunder to the parties hereto, and, in particular but without limitation, the warranties, guarantees and obligations imposed upon CONTRACTOR by paragraphs 12.1, 12.3.5, 13.3, and 15.2 and all of the rights and remedies available to OWNER and CONSULTANT thereunder, are in addition to, and are not to be construed in any way as a limitation of, any rights and remedies available to any or all of them which are otherwise imposed or available by Laws or Regulations, by special warranty or guarantee or by other provisions of the Contract Documents, and the provisions of this paragraph will be as effective as if repeated specifically in the Contract Documents in connection with each particular duty, obligation, right and remedy to which they apply. All representations, warranties and guarantees made in the Contract Documents will survive final payment and termination or completion of the Agreement.

15.7 Debris Disposal

For all LFUCG projects any trash, construction demolition debris, yard waste, dirt or debris of any kind that is removed from the project site must be disposed of in accordance with local, state, and federal regulations. The disposal site or facility must be approved in advance by the LFUCG and disposal documentation is required. The Contractor will be responsible for payment of any fines associated with improper disposal of material removed from the project site.

END OF SECTION

PART V
SPECIAL CONDITIONS
INDEX

1	BLASTING.....	SC-2
2	RISK MANAGEMENT PROVISIONS – INSURANCE AND INDEMNIFICATION	SC-3
3	WAGE SCALE (if applicable)	SC-7

1. **BLASTING** – not applicable.

2. **RISK MANAGEMENT PROVISIONS**
INSURANCE AND INDEMNIFICATION

INDEMNIFICATION AND HOLD HARMLESS PROVISION

- (1) It is understood and agreed by the parties that Contractor hereby assumes the entire responsibility and liability for any and all damages to persons or property caused by or resulting from or arising out of any act or omission on the part of Contractor or its employees, agents, servants, owners, principals, licensees, assigns or subcontractors of any tier (hereinafter "CONTRACTOR") under or in connection with this agreement and/or the provision of goods or services and the performance or failure to perform any work required thereby.
- (2) CONTRACTOR shall indemnify, save, hold harmless and defend the Lexington-Fayette Urban County Government and its elected and appointed officials, employees, agents, volunteers, and successors in interest (hereinafter "LFUCG") from and against all liability, damages, and losses, including but not limited to, demands, claims, obligations, causes of action, judgments, penalties, fines, liens, costs, expenses, interest, defense costs and reasonable attorney's fees that are in any way incidental to or connected with, or that arise or are alleged to have arisen, directly or indirectly, from or by CONTRACTOR's performance or breach of the agreement and/or the provision of goods or services provided that: (a) it is attributable to personal injury, bodily injury, sickness, or death, or to injury to or destruction of property (including the loss of use resulting therefrom), or to or from the negligent acts, errors or omissions or willful misconduct of the CONTRACTOR; and (b) not caused solely by the active negligence or willful misconduct of LFUCG.
- (3) In the event LFUCG is alleged to be liable based upon the above, CONTRACTOR shall defend such allegations and shall bear all costs, fees and expenses of such defense, including but not limited to, all reasonable attorneys' fees and expenses, court costs, and expert witness fees and expenses, using attorneys approved in writing by LFUCG, which approval shall not be unreasonably withheld.
- (4) These provisions shall in no way be limited by any financial responsibility or insurance requirements, and shall survive the termination of this agreement.
- (5) LFUCG is a political subdivision of the Commonwealth of Kentucky. Vendor acknowledges and agrees that LFUCG is unable to provide indemnity or otherwise save, hold harmless, or defend the Vendor in any manner.

FINANCIAL RESPONSIBILITY

BIDDER/CONTRACTOR understands and agrees that it shall, prior to final acceptance of its bid and the commencement of any work, demonstrate the ability to assure compliance with the above Indemnity provisions and these other risk management provisions.

INSURANCE REQUIREMENTS

YOUR ATTENTION IS DIRECTED TO THE INSURANCE REQUIREMENTS BELOW, AND YOU MAY NEED TO CONFER WITH YOUR INSURANCE AGENTS, BROKERS, OR CARRIERS TO DETERMINE IN ADVANCE OF SUBMISSION OF A RESPONSE THE AVAILABILITY OF THE INSURANCE COVERAGES AND ENDORSEMENTS REQUIRED HEREIN. IF YOU FAIL TO COMPLY WITH THE INSURANCE REQUIREMENTS BELOW, YOU MAY BE DISQUALIFIED FROM AWARD OF THE CONTRACT.

Required Insurance Coverage

BIDDER/CONTRACTOR shall procure and maintain for the duration of this contract the following or equivalent insurance policies at no less than the limits shown below and cause its subcontractors to maintain similar insurance with limits acceptable to LFUCG in order to protect LFUCG against claims for injuries to persons or damages to property which may arise from or in connection with the performance of the work hereunder by CONTRACTOR. The cost of such insurance shall be included in any bid:

<u>Coverage</u>	<u>Limits</u>
General Liability aggregate (Insurance Services Office Form CG 00 01)	\$5 million per occurrence, \$5 million or \$5 million combined single limit
Commercial Automobile Liability (Insurance Services Office Form CA 0001)	combined single, \$1 million per occurrence
Worker's Compensation	\$1,000,000
Employer's Liability	\$500,000.00
Railroad Protective Liability Policy	\$2 million /occurrence, \$6 million aggregate

The policies above shall contain the following conditions:

- a. All Certificates of Insurance forms used by the insurance carrier shall be properly filed and approved by the Department of Insurance for the Commonwealth of Kentucky (DOI). LFUCG shall be named as an additional insured in the General Liability Policy and Commercial Automobile Liability Policy using the Kentucky DOI approved forms.
- b. The General Liability Policy shall be primary to any insurance or self-insurance retained by LFUCG.

- c. The General Liability Policy shall include a Products and Completed Operations endorsement or Premises and Operations Liability endorsement unless it is deemed not to apply by LFUCG.
- d. LFUCG shall be provided at least 30 days advance written notice via certified mail, return receipt requested, in the event any of the required policies are canceled or non-renewed.
- e. Said coverage shall be written by insurers acceptable to LFUCG and shall be in a form acceptable to LFUCG. Insurance placed with insurers with a rating classification of no less than Excellent (A or A-) and a financial size category of no less than VIII, as defined by the most current Best's Key Rating Guide shall be deemed automatically acceptable.
- f. The Railroad Protective Liability Insurance Policy will name RJ Corman Railroad Company/Central Kentucky Line(s) as "insured". As RJ Corman does not have a written contract for this installation, coverage cannot be based on "contractual liability" or per "written contract". Please note: RJ Corman's policy does not provide for the option of adding a rider to its policy as a substitute for applicant's purchase of its own policy.

No work or entry onto railroad property on the ground, underground or aerially, is authorized until you receive written confirmation of authorization to enter and have properly scheduled such entry. Anyone on Railroad property without permission puts themselves as well as others at risk of serious, even fatal, injury. Failure to notify the railroad of your plans to be on the property can result in STOP WORK!

Failure to procure the railroad protective liability policy described in section f above, including the failure to be successfully insured, will result in the forfeiture of the contractors bid.

Renewals

After insurance has been approved by LFUCG, evidence of renewal of an expiring policy must be submitted to LFUCG, and may be submitted on a manually signed renewal endorsement form. If the policy or carrier has changed, however, new evidence of coverage must be submitted in accordance with these Insurance Requirements.

Deductibles and Self-Insured Programs

IF YOU INTEND TO SUBMIT A SELF-INSURANCE PLAN IT MUST BE FORWARDED TO LEXINGTON-FAYETTE URBAN COUNTY GOVERNMENT, DIVISION OF RISK MANAGEMENT, 200 EAST MAIN STREET, LEXINGTON, KENTUCKY 40507 NO LATER THAN A MINIMUM OF FIVE (5) WORKING DAYS PRIOR TO THE RESPONSE DATE. Self-insurance programs, deductibles, and self-insured retentions in insurance policies are subject to separate approval by Lexington-Fayette Urban County Government's Division of Risk Management, upon review of evidence of BIDDER/CONTRACTOR's financial capacity to respond to claims. Any such

programs or retentions must provide LFUCG with at least the same protection from liability and defense of suits as would be afforded by first-dollar insurance coverage. If BIDDER/CONTRACTOR satisfies any portion of the insurance requirements through deductibles, self-insurance programs, or self-insured retentions, BIDDER/CONTRACTOR agrees to provide Lexington-Fayette Urban County Government, Division of Risk Management, the following data prior to the final acceptance of bid and the commencement of any work:

- a. Latest audited financial statement, including auditor's notes.
- b. Any records of any self-insured trust fund plan or policy and related accounting statements.
- c. Actuarial funding reports or retained losses.
- d. Risk Management Manual or a description of the self-insurance and risk management program.
- e. A claim loss run summary for the previous five (5) years.
- f. Self-Insured Associations will be considered.

Safety and Loss Control

CONTRACTOR shall comply with all applicable federal, state, and local safety standards related to the performance of its works or services under this Agreement and take necessary action to protect the life, health and safety and property of all of its personnel on the job site, the public, and LFUCG.

Verification of Coverage

BIDDER/CONTRACTOR agrees to furnish LFUCG with all applicable Certificates of Insurance signed by a person authorized by the insurer to bind coverage on its behalf prior to final award, and if requested, shall provide LFUCG copies of all insurance policies, including all endorsements.

Right to Review, Audit and Inspect

CONTRACTOR understands and agrees that LFUCG may review, audit and inspect any and all of its records and operations to insure compliance with these Insurance Requirements.

DEFAULT

BIDDER/CONTRACTOR understands and agrees that the failure to comply with any of these insurance, safety, or loss control provisions shall constitute default and that LFUCG may elect at its option any single remedy or penalty or any combination of remedies and penalties, as available, including but not limited to purchasing insurance and charging BIDDER/CONTRACTOR for any such insurance premiums purchased, or suspending or terminating the work.

00357187

3. **WAGE SCALES** – not applicable.

PART VI

CONTRACT AGREEMENT

INDEX

1. SCOPE OF WORK..... CA-2

2. TIME OF COMPLETION CA-2

3. ISSUANCE OF WORK ORDERS CA-2

4. THE CONTRACT SUM..... CA-2

5. PROGRESS PAYMENTS CA-3

6. ACCEPTANCE AND FINAL PAYMENT..... CA-3

7. THE CONTRACT DOCUMENTS CA-3

8. EXTRA WORK..... CA-3

9. ENUMERATION OF SPECIFICATIONS AND DRAWINGS CA-4

PART VI

CONTRACT AGREEMENT

THIS AGREEMENT, made on the 21st day of April, 2016, by and between **Lexington-Fayette Urban County Government**, acting herein called "OWNER" and L&L Excavation and Site Prep, Inc., doing business as a corporation located in the City of Salyersville, County of Magoffin, and State of Kentucky, hereinafter called "CONTRACTOR."

WITNESSETH: That the CONTRACTOR and the OWNER in consideration of ninety thousand one hundred seventy Dollars and zero Cents (\$ 90,170.00) quoted in the proposal by the CONTRACTOR, dated 2/29/2016, hereby agree to commence and complete the construction described as follows:

1. SCOPE OF WORK

The CONTRACTOR shall furnish all the materials, supplies, machinery, equipment, tools, superintendence, labor, insurance, and other accessories and services necessary to complete the said project in accordance with the conditions and prices stated in the Proposal, the General Conditions, and the Special Conditions of the Contract, the Specifications and Contract Documents therefore as prepared by Bell Engineering for Haley Pike Landfill Force Main project.

2. TIME OF COMPLETION

The time period estimated and authorized by the OWNER for the proper execution of the Work by the Contract, in full, is hereby fixed as forty five (45) calendar days. The time shall begin in accordance with the Notice to Proceed provided by OWNER.

3. ISSUANCE OF WORK ORDERS

Notice to begin Work will be given in whole or for part of the Work as determined by the OWNER pending the availability of funds. The order of construction will be as determined by the Engineer after consultation with the CONTRACTOR and the OWNER.

4. THE CONTRACT SUM

The OWNER agrees to pay the CONTRACTOR in current funds for the performance of the Contract, as quoted in the proposal, subject to any additions and deductions, as provided therein.

5. PROGRESS PAYMENTS

The OWNER shall make payments on account of the Contract, as provided in accordance with the General Conditions, as estimated by the Engineer, less the aggregate of previous payments.

6. ACCEPTANCE AND FINAL PAYMENT

Final payment shall be due within ninety (90) days after completion of the Work, provided the Work be then fully completed and the Contract fully accepted.

Before issuance of final certificate, the CONTRACTOR shall submit evidence satisfactory to the Engineer that all payrolls, material bills, and other indebtedness connected with the Work has been paid.

If, after the Work has been substantially completed, full completion thereof is materially delayed through no fault of the CONTRACTOR, and the ENGINEER so certifies, the OWNER shall upon certificate of the ENGINEER, and without terminating the Contract, make payment of the balance due for that portion of the Work fully completed and accepted. Such payment shall be made under the terms and conditions governing final payment, except that it shall not constitute a waiver of claims.

7. THE CONTRACT DOCUMENTS

The Advertisement for Bids, Information for Bidders, the General Conditions, Performance and Payment Bonds, Contract Agreement, Special Conditions, Technical Specifications, any and all Addenda, and Proposal, and Plan Drawings form the Contract, and they are fully a part of the Contract as if hereto attached or herein repeated.

8. EXTRA WORK

The OWNER, without invalidating the Contract, may order extra work or make changes by altering, adding to or deducting from the Work, the Contract Sum being adjusted accordingly. All such Work shall be executed and paid for in accordance with the General Conditions, which is a part of this Contract.

9. THE FOLLOWING IS AN ENUMERATION OF THE SPECIFICATIONS AND DRAWINGS (CONTRACT DOCUMENTS):

SPECIFICATIONS

SECTION NO.	TITLE	PAGES
I	Advertisement for Bids	AB 1 thru 5
II	Information for Bidders	IB 1 thru 10
III	Form of Proposal	P 1 thru 35
IV	General Conditions	GC 1 thru 50
V	Special Conditions	SC 1 thru 8
VI	Contract Agreement	CA 1 thru 5
VII	Performance and Payment Bonds	PB 1 thru 7
VIII	Addenda	AD 1 thru 1
IX	Technical Specifications	

Division 1 - General Requirements

01010	Summary Of Work	1 thru 1
01020	Allowances	1 thru 1
01500	Construction Facilities and Temporary Controls	1 thru 3

Division 2 - Site Work

02110	Site Clearing and Grubbing	1 thru 2
02140	Dewatering	1 thru 1
02200	Earth and Rock Work	1 thru 12
02235	Crushed Stone and Dense Graded Aggregate	1 thru 3
02326	Steel Cover Pipe	1 thru 4
02610	Water and Sewage Force Main Pipe	1 thru 21
02930	Sodding and Seeding	1 thru 7

Division 3 – Not Used

Division 4 – Not Used

Division 5 – Not Used

Division 6 – Not Used

Division 7 – Not Used

Division 8 – Not Used

Division 9 – Not Used

Division 10 – Not Used

Division 11 – Not Used

Division 12 – Not Used

Division 13 – Not Used

Division 14 – Not Used

Division 15 – Mechanical

15101 Valves for Sewage Systems

1 thru 5

Division 16 – Not Used

Division 17 – Not Used

APPENDIX A Standard Drawings

PLAN DRAWINGS –

Haley Pike Landfill Force Main Cover Sheet

Sheet 1 of 4 - Project Map, Vicinity Map, Legend, and General Notes

Sheet 2 of 4 - Mulch Pond Leachate Force Main

Sheet 3 of 4 - Mulch Pond Leachate Force Main

Sheet 4 of 4 – Standard Details


IN WITNESSETH WHEREOF, the parties hereto have executed this Contract as of the date and year above written.

(Seal)


Lexington-Fayette Urban County Government.
Lexington, Kentucky


(Owner)

ATTEST:


Clerk of the Urban County Council

BY:


MAYOR


(Witness)

(Title)


(Seal)

L&L Excavation and Site Prep, Inc.
(Contractor)

(Secretary)*

BY:




(Witness)

Owner
(Title)

436 Brad Drive, Salyersville, KY 40465
(Address and Zip Code)

IMPORTANT: *Strike out any non-applicable terms.

Secretary of the Owner should attest. If the CONTRACTOR is corporation, Secretary should attest. Give proper title of each person-executing Contract.

PART VII

PERFORMANCE AND PAYMENT BONDS

1. PERFORMANCE BOND
2. PAYMENT BOND



AIA Document A312™ – 2010

CRA
RECEIVED

Performance Bond

APR 06 16

Beli Engineering
Front Desk

CONTRACTOR:

(Name, legal status and address)

L&L Excavation and Site Prep, Inc.

309 Parkway Drive, PO Box 614

Salyersville, KY 41465

SURETY:

(Name, legal status and principal place of business)

The Cincinnati Insurance Company

P.O. Box 145496

Cincinnati, OH 45250

OWNER:

(Name, legal status and address)

Lexington-Fayette Urban County Government

Division of Purchasing, 200 East Main Street, 3rd Floor, Room 338

Lexington, KY 40507

CONSTRUCTION CONTRACT

Date: April 20, 2016

Amount. Ninety Thousand One Hundred Seventy and 00/100

(\$90,170.00)

Description.

(Name and location)

Haley Pike Landfill Force Main

Bid No. 21-2016

BOND

Date: April 20, 2016

(Not earlier than Construction Contract Date)

Amount. Ninety Thousand One Hundred Seventy and 00/100

(\$90,170.00)

Modifications to this Bond: None

See Section 16

CONTRACTOR AS PRINCIPAL

Company *(Corporate Seal)*

L&L Excavation and Site Prep, Inc.

SURETY

Company: *(Corporate Seal)*

The Cincinnati Insurance Company

Signature: *Keith Jackson*

Name

and Title:

Signature: *Nancy Nemes*

Name

and Title: Attorney-in-Fac

(Any additional signatures appear on the last page of this Performance Bond.)

(FOR INFORMATION ONLY — Name, address and telephone)

AGENT or BROKER:

AssuredPartners NL, LLC

2305 River Road

Louisville, KY 40206

502-894-2100

OWNER'S REPRESENTATIVE:

(Architect, Engineer or other party:)

Beli Engineering, Inc.

2480 Fortune Drive, Suite 350

Lexington, KY 40509

859-278-5412

§ 1 The Contractor and Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors and assigns to the Owner for the performance of the Construction Contract, which is incorporated herein by reference.

§ 2 If the Contractor performs the Construction Contract, the Surety and the Contractor shall have no obligation under this Bond, except when applicable to participate in a conference as provided in Section 3.

§ 3 If there is no Owner Default under the Construction Contract, the Surety's obligation under this Bond shall arise after

- 1 the Owner first provides notice to the Contractor and the Surety that the Owner is considering declaring a Contractor Default. Such notice shall indicate whether the Owner is requesting a conference among the Owner, Contractor and Surety to discuss the Contractor's performance. If the Owner does not request a conference, the Surety may, within five (5) business days after receipt of the Owner's notice, request such a conference. If the Surety timely requests a conference, the Owner shall attend. Unless the Owner agrees otherwise, any conference requested under this Section 3.1 shall be held within ten (10) business days of the Surety's receipt of the Owner's notice. If the Owner, the Contractor and the Surety agree, the Contractor shall be allowed a reasonable time to perform the Construction Contract, but such an agreement shall not waive the Owner's right, if any, subsequently to declare a Contractor Default;
- .2 the Owner declares a Contractor Default, terminates the Construction Contract and notifies the Surety; and
- .3 the Owner has agreed to pay the Balance of the Contract Price in accordance with the terms of the Construction Contract to the Surety or to a contractor selected to perform the Construction Contract.

§ 4 Failure on the part of the Owner to comply with the notice requirement in Section 3.1 shall not constitute a failure to comply with a condition precedent to the Surety's obligations, or release the Surety from its obligations, except to the extent the Surety demonstrates actual prejudice.

§ 5 When the Owner has satisfied the conditions of Section 3, the Surety shall promptly and at the Surety's expense take one of the following actions:

§ 5.1 Arrange for the Contractor, with the consent of the Owner, to perform and complete the Construction Contract;

§ 5.2 Undertake to perform and complete the Construction Contract itself, through its agents or independent contractors;

§ 5.3 Obtain bids or negotiated proposals from qualified contractors acceptable to the Owner for a contract for performance and completion of the Construction Contract, arrange for a contract to be prepared for execution by the Owner and a contractor selected with the Owner's concurrence, to be secured with performance and payment bonds executed by a qualified surety equivalent to the bonds issued on the Construction Contract, and pay to the Owner the amount of damages as described in Section 7 in excess of the Balance of the Contract Price incurred by the Owner as a result of the Contractor Default; or

§ 5.4 Waive its right to perform and complete, arrange for completion, or obtain a new contractor and with reasonable promptness under the circumstances:

- 1 After investigation, determine the amount for which it may be liable to the Owner and, as soon as practicable after the amount is determined, make payment to the Owner; or
- .2 Deny liability in whole or in part and notify the Owner, citing the reasons for denial.

§ 6 If the Surety does not proceed as provided in Section 5 with reasonable promptness, the Surety shall be deemed to be in default on this Bond seven days after receipt of an additional written notice from the Owner to the Surety demanding that the Surety perform its obligations under this Bond, and the Owner shall be entitled to enforce any remedy available to the Owner. If the Surety proceeds as provided in Section 5.4, and the Owner refuses the payment or the Surety has denied liability, in whole or in part, without further notice the Owner shall be entitled to enforce any remedy available to the Owner.

§ 7 If the Surety elects to act under Section 5.1, 5.2 or 5.3, then the responsibilities of the Surety to the Owner shall not be greater than those of the Contractor under the Construction Contract, and the responsibilities of the Owner to the Surety shall not be greater than those of the Owner under the Construction Contract. Subject to the commitment by the Owner to pay the Balance of the Contract Price, the Surety is obligated, without duplication, for

- 1 the responsibilities of the Contractor for correction of defective work and completion of the Construction Contract;
- 2 additional legal, design professional and delay costs resulting from the Contractor's Default, and resulting from the actions or failure to act of the Surety under Section 5; and
- 3 liquidated damages, or if no liquidated damages are specified in the Construction Contract, actual damages caused by delayed performance or non-performance of the Contractor.

§ 8 If the Surety elects to act under Section 5.1, 5.3 or 5.4, the Surety's liability is limited to the amount of this Bond.

§ 9 The Surety shall not be liable to the Owner or others for obligations of the Contractor that are unrelated to the Construction Contract, and the Balance of the Contract Price shall not be reduced or set off on account of any such unrelated obligations. No right of action shall accrue on this Bond to any person or entity other than the Owner or its heirs, executors, administrators, successors and assigns.

§ 10 The Surety hereby waives notice of any change, including changes of time, to the Construction Contract or to related subcontracts, purchase orders and other obligations.

§ 11 Any proceeding, legal or equitable, under this Bond may be instituted in any court of competent jurisdiction in the location in which the work or part of the work is located and shall be instituted within two years after a declaration of Contractor Default or within two years after the Contractor ceased working or within two years after the Surety refuses or fails to perform its obligations under this Bond, whichever occurs first. If the provisions of this Paragraph are void or prohibited by law, the minimum period of limitation available to sureties as a defense in the jurisdiction of the suit shall be applicable.

§ 12 Notice to the Surety, the Owner or the Contractor shall be mailed or delivered to the address shown on the page on which their signature appears.

§ 13 When this Bond has been furnished to comply with a statutory or other legal requirement in the location where the construction was to be performed, any provision in this Bond conflicting with said statutory or legal requirement shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. When so furnished, the intent is that this Bond shall be construed as a statutory bond and not as a common law bond.

§ 14 Definitions

§ 14.1 **Balance of the Contract Price.** The total amount payable by the Owner to the Contractor under the Construction Contract after all proper adjustments have been made, including allowance to the Contractor of any amounts received or to be received by the Owner in settlement of insurance or other claims for damages to which the Contractor is entitled, reduced by all valid and proper payments made to or on behalf of the Contractor under the Construction Contract.

§ 14.2 **Construction Contract.** The agreement between the Owner and Contractor identified on the cover page, including all Contract Documents and changes made to the agreement and the Contract Documents.

§ 14.3 **Contractor Default.** Failure of the Contractor, which has not been remedied or waived, to perform or otherwise to comply with a material term of the Construction Contract.

§ 14.4 **Owner Default.** Failure of the Owner, which has not been remedied or waived, to pay the Contractor as required under the Construction Contract or to perform and complete or comply with the other material terms of the Construction Contract.

§ 14.5 **Contract Documents.** All the documents that comprise the agreement between the Owner and Contractor.

§ 15 If this Bond is issued for an agreement between a Contractor and subcontractor, the term Contractor in this Bond shall be deemed to be Subcontractor and the term Owner shall be deemed to be Contractor.

§ 16 Modifications to this bond are as follows:

(Space is provided below for additional signatures of added parties, other than those appearing on the cover page.)

CONTRACTOR AS PRINCIPAL

SURETY

Company

(Corporate Seal)

Company:

(Corporate Seal)

Signature: _____

Signature: _____

Name and Title:

Name and Title: **Attorney-in-Fact**

Address

Address

CAUTION: You should sign an original AIA Contract Document, on which this text appears in RED. An original assures that changes will not be obscured.

Init.

AIA Document A312™ – 2010. The American Institute of Architects.

AIA[®] Document A312[™] – 2010

Payment Bond

CONTRACTOR:

(Name, legal status and address)

L&L Excavation and Site Prep, Inc.
309 Parkway Drive, PO Box 614
Salyersville, KY 41465

SURETY:

(Name, legal status and principal place of business)

The Cincinnati Insurance Company
P.O. Box 145496
Cincinnati, OH 45250

OWNER:

(Name, legal status and address)

Lexington-Fayette Urban County Government
Division of Purchasing, 200 East Main Street, 3rd Floor, Room 338
Lexington, KY 40507

CONSTRUCTION CONTRACT

Date: April 20, 2016

Amount: Ninety Thousand One Hundred Seventy and 00/100
(\$90,170.00)

Description:

(Name and location)

Haley Pike Landfill Force Main
Bid No. 21-2016

BOND

Date: April 20, 2016

(Not earlier than Construction Contract Date)

Amount: Ninety Thousand One Hundred Seventy and 00/100
(\$90,170.00)

Modifications to this Bond: None See Section 18

CONTRACTOR AS PRINCIPAL

Company *(Corporate Seal)*

L&L Excavation and Site Prep, Inc.

SURETY

Company: *(Corporate Seal)*

The Cincinnati Insurance Company

Signature: *Keith Jenkins*

Name

and Title:

(Any additional signatures appear on the last page of this Payment Bond.)

Signature: *Nancy Nemeec*

Name Nancy Nemeec

and Title: Attorney-in-Fact

(FOR INFORMATION ONLY — Name, address and telephone)

AGENT or BROKER:

AssuredPartners NL, LLC

2305 River Road

Louisville, KY 40206

502-894-2100

OWNER'S REPRESENTATIVE:

(Architect, Engineer or other party:)

Bell Engineering, Inc.

2480 Fortune Drive, Suite 350

Lexington, KY 40509

859-278-5412

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

Any singular reference to Contractor, Surety, Owner or other party shall be considered plural where applicable.

AIA Document A312-2010 combines two separate bonds, a Performance Bond and a Payment Bond, into one form. This is not a single combined Performance and Payment Bond.

§ 1 The Contractor and Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors and assigns to the Owner to pay for labor, materials and equipment furnished for use in the performance of the Construction Contract, which is incorporated herein by reference, subject to the following terms.

§ 2 If the Contractor promptly makes payment of all sums due to Claimants, and defends, indemnifies and holds harmless the Owner from claims, demands, liens or suits by any person or entity seeking payment for labor, materials or equipment furnished for use in the performance of the Construction Contract, then the Surety and the Contractor shall have no obligation under this Bond.

§ 3 If there is no Owner Default under the Construction Contract, the Surety's obligation to the Owner under this Bond shall arise after the Owner has promptly notified the Contractor and the Surety (at the address described in Section 13) of claims, demands, liens or suits against the Owner or the Owner's property by any person or entity seeking payment for labor, materials or equipment furnished for use in the performance of the Construction Contract and tendered defense of such claims, demands, liens or suits to the Contractor and the Surety.

§ 4 When the Owner has satisfied the conditions in Section 3, the Surety shall promptly and at the Surety's expense defend, indemnify and hold harmless the Owner against a duly tendered claim, demand, lien or suit.

§ 5 The Surety's obligations to a Claimant under this Bond shall arise after the following:

§ 5.1 Claimants, who do not have a direct contract with the Contractor,

- 1 have furnished a written notice of non-payment to the Contractor, stating with substantial accuracy the amount claimed and the name of the party to whom the materials were, or equipment was, furnished or supplied or for whom the labor was done or performed, within ninety (90) days after having last performed labor or last furnished materials or equipment included in the Claim; and
- 2 have sent a Claim to the Surety (at the address described in Section 13).

§ 5.2 Claimants, who are employed by or have a direct contract with the Contractor, have sent a Claim to the Surety (at the address described in Section 13).

§ 6 If a notice of non-payment required by Section 5.1.1 is given by the Owner to the Contractor, that is sufficient to satisfy a Claimant's obligation to furnish a written notice of non-payment under Section 5.1.1.

§ 7 When a Claimant has satisfied the conditions of Sections 5.1 or 5.2, whichever is applicable, the Surety shall promptly and at the Surety's expense take the following actions:

§ 7.1 Send an answer to the Claimant, with a copy to the Owner, within sixty (60) days after receipt of the Claim, stating the amounts that are undisputed and the basis for challenging any amounts that are disputed; and

§ 7.2 Pay or arrange for payment of any undisputed amounts.

§ 7.3 The Surety's failure to discharge its obligations under Section 7.1 or Section 7.2 shall not be deemed to constitute a waiver of defenses the Surety or Contractor may have or acquire as to a Claim, except as to undisputed amounts for which the Surety and Claimant have reached agreement. If, however, the Surety fails to discharge its obligations under Section 7.1 or Section 7.2, the Surety shall indemnify the Claimant for the reasonable attorney's fees the Claimant incurs thereafter to recover any sums found to be due and owing to the Claimant.

§ 8 The Surety's total obligation shall not exceed the amount of this Bond, plus the amount of reasonable attorney's fees provided under Section 7.3, and the amount of this Bond shall be credited for any payments made in good faith by the Surety.

§ 9 Amounts owed by the Owner to the Contractor under the Construction Contract shall be used for the performance of the Construction Contract and to satisfy claims, if any, under any construction performance bond. By the Contractor furnishing and the Owner accepting this Bond, they agree that all funds earned by the Contractor in the performance of the Construction Contract are dedicated to satisfy obligations of the Contractor and Surety under this Bond, subject to the Owner's priority to use the funds for the completion of the work.

§ 10 The Surety shall not be liable to the Owner, Claimants or others for obligations of the Contractor that are unrelated to the Construction Contract. The Owner shall not be liable for the payment of any costs or expenses of any Claimant under this Bond, and shall have under this Bond no obligation to make payments to, or give notice on behalf of, Claimants or otherwise have any obligations to Claimants under this Bond.

§ 11 The Surety hereby waives notice of any change, including changes of time, to the Construction Contract or to related subcontracts, purchase orders and other obligations.

§ 12 No suit or action shall be commenced by a Claimant under this Bond other than in a court of competent jurisdiction in the state in which the project that is the subject of the Construction Contract is located or after the expiration of one year from the date (1) on which the Claimant sent a Claim to the Surety pursuant to Section 5.1.2 or 5.2, or (2) on which the last labor or service was performed by anyone or the last materials or equipment were furnished by anyone under the Construction Contract, whichever of (1) or (2) first occurs. If the provisions of this Paragraph are void or prohibited by law, the minimum period of limitation available to sureties as a defense in the jurisdiction of the suit shall be applicable.

§ 13 Notice and Claims to the Surety, the Owner or the Contractor shall be mailed or delivered to the address shown on the page on which their signature appears. Actual receipt of notice or Claims, however accomplished, shall be sufficient compliance as of the date received.

§ 14 When this Bond has been furnished to comply with a statutory or other legal requirement in the location where the construction was to be performed, any provision in this Bond conflicting with said statutory or legal requirement shall be deemed deleted herefrom and provisions conforming to such statutory or other legal requirement shall be deemed incorporated herein. When so furnished, the intent is that this Bond shall be construed as a statutory bond and not as a common law bond.

§ 15 Upon request by any person or entity appearing to be a potential beneficiary of this Bond, the Contractor and Owner shall promptly furnish a copy of this Bond or shall permit a copy to be made.

§ 16 Definitions

§ 16.1 Claim. A written statement by the Claimant including at a minimum,

- .1 the name of the Claimant;
- .2 the name of the person for whom the labor was done, or materials or equipment furnished;
- .3 a copy of the agreement or purchase order pursuant to which labor, materials or equipment was furnished for use in the performance of the Construction Contract;
- .4 a brief description of the labor, materials or equipment furnished;
- .5 the date on which the Claimant last performed labor or last furnished materials or equipment for use in the performance of the Construction Contract;
- .6 the total amount earned by the Claimant for labor, materials or equipment furnished as of the date of the Claim;
- .7 the total amount of previous payments received by the Claimant; and
- .8 the total amount due and unpaid to the Claimant for labor, materials or equipment furnished as of the date of the Claim.

§ 16.2 Claimant. An individual or entity having a direct contract with the Contractor or with a subcontractor of the Contractor to furnish labor, materials or equipment for use in the performance of the Construction Contract. The term Claimant also includes any individual or entity that has rightfully asserted a claim under an applicable mechanic's lien or similar statute against the real property upon which the Project is located. The intent of this Bond shall be to include without limitation in the terms "labor, materials or equipment" that part of water, gas, power, light, heat, oil, gasoline, telephone service or rental equipment used in the Construction Contract, architectural and engineering services required for performance of the work of the Contractor and the Contractor's subcontractors, and all other items for which a mechanic's lien may be asserted in the jurisdiction where the labor, materials or equipment were furnished.

§ 16.3 Construction Contract. The agreement between the Owner and Contractor identified on the cover page, including all Contract Documents and all changes made to the agreement and the Contract Documents.

§ 16.4 **Owner Default.** Failure of the Owner, which has not been remedied or waived, to pay the Contractor as required under the Construction Contract or to perform and complete or comply with the other material terms of the Construction Contract.

§ 16.5 **Contract Documents.** All the documents that comprise the agreement between the Owner and Contractor.

§ 17 If this Bond is issued for an agreement between a Contractor and subcontractor, the term Contractor in this Bond shall be deemed to be Subcontractor and the term Owner shall be deemed to be Contractor.

§ 18 Modifications to this bond are as follows:

(Space is provided below for additional signatures of added parties, other than those appearing on the cover page.)

CONTRACTOR AS PRINCIPAL

Company

(Corporate Seal)

SURETY

Company:

(Corporate Seal)

Signature: _____

Name and Title: _____

Address _____

Signature: _____

Name and Title: **Attorney-in-Fact**

Address _____

CAUTION: You should sign an original AIA Contract Document, on which this text appears in RED. An original assures that changes will not be obscured.

THE CINCINNATI INSURANCE COMPANY

Fairfield, Ohio

POWER OF ATTORNEY

KNOW ALL MEN BY THESE PRESENTS: That THE CINCINNATI INSURANCE COMPANY, a corporation organized under the laws of the State of Ohio, and having its principal office in the City of Fairfield, Ohio, does hereby constitute and appoint

G. Dale Derr; Tammie J. Landess; Evan R. Derr; Randal T. Noah; Mary Beth Milling; Nancy Nemec; Kelsey Freytag; Stella Adams; Tiffany Gobich; Elizabeth McDevitt; Mark Nelson and/or Tammy Masterson

of Dayton and Cincinnati, Ohio its true and lawful Attorney(s)-in-Fact to sign, execute, seal and deliver on its behalf as Surety, and as its act and deed, any and all bonds, policies, undertakings, or other like instruments, as follows:

Any such obligations in the United States, up to Twenty Five Million and No/100 Dollars (\$25,000,000.00).

This appointment is made under and by authority of the following resolution passed by the Board of Directors of said Company at a meeting held in the principal office of the Company, a quorum being present and voting, on the 6th day of December, 1958, which resolution is still in effect:

"RESOLVED, that the President or any Vice President be hereby authorized, and empowered to appoint Attorneys-in-Fact of the Company to execute any and all bonds, policies, undertakings, or other like instruments on behalf of the Corporation, and may authorize any officer or any such Attorney-in-Fact to affix the corporate seal; and may with or without cause modify or revoke any such appointment or authority. Any such writings so executed by such Attorneys-in-Fact shall be binding upon the Company as if they had been duly executed and acknowledged by the regularly elected officers of the Company."

This Power of Attorney is signed and sealed by facsimile under and by the authority of the following Resolution adopted by the Board of Directors of the Company at a meeting duly called and held on the 7th day of December, 1973.

"RESOLVED, that the signature of the President or a Vice President and the seal of the Company may be affixed by facsimile on any power of attorney granted, and the signature of the Secretary or Assistant Secretary and the seal of the Company may be affixed by facsimile to any certificate of any such power and any such power of certificate bearing such facsimile signature and seal shall be valid and binding on the Company. Any such power so executed and sealed and certified by certificate so executed and sealed shall, with respect to any bond or undertaking to which it is attached, continue to be valid and binding on the Company."

IN WITNESS WHEREOF, THE CINCINNATI INSURANCE COMPANY has caused these presents to be sealed with its corporate seal, duly attested by its Vice President this 1st day of October, 2015.



THE CINCINNATI INSURANCE COMPANY

Stephen A. Jantke

Vice President

STATE OF OHIO) ss:
COUNTY OF BUTLER)

On this 1st day of October, 2015, before me came the above-named Vice President of THE CINCINNATI INSURANCE COMPANY, to me personally known to be the officer described herein, and acknowledged that the seal affixed to the preceding instrument is the corporate seal of said Company and the corporate seal and the signature of the officer were duly affixed and subscribed to said instrument by the authority and direction of said corporation.



Mark J. Huller

MARK J. HULLER, Attorney at Law
NOTARY PUBLIC - STATE OF OHIO
My commission has no expiration date. Section 147.03 O.R.C.

I, the undersigned Secretary or Assistant Secretary of THE CINCINNATI INSURANCE COMPANY, hereby certify that the above is a true and correct copy of the Original Power of Attorney issued by said Company, and do hereby further certify that the said Power of Attorney is still in full force and effect.

GIVEN under my hand and seal of said Company at Fairfield, Ohio.
this 20th day of April, 2016



Scott R. Bolan

Secretary



The Cincinnati Insurance Company ■ The Cincinnati Indemnity Company
The Cincinnati Casualty Company ■ The Cincinnati Specialty Underwriters Insurance Company
The Cincinnati Life Insurance Company

THE CINCINNATI INSURANCE COMPANY
FINANCIAL STATEMENT
DECEMBER 31, 2015

ASSETS


Cash	\$ 350,245,654
Bonds	5,317,509,438
Stocks	3,847,880,811
Agents Balance Receivable	1,488,420,069
All Other Admitted Assets	190,120,698
TOTAL ADMITTED ASSETS	<u>\$11,194,176,670</u>


LIABILITIES

Reserve for Losses and Loss Expense	\$4,160,506,314
Reserve for Unearned Premiums	2,079,433,143
All Other Liabilities	541,805,740
Capital	\$ 3,586,355
Surplus	4,408,845,118
TOTAL LIABILITIES & EQUITY	<u>4,412,431,473</u> <u>\$11,194,176,670</u>

State of Ohio
County of Butler


Theresa A. Hoffer, Senior Vice President & Treasurer of The Cincinnati Insurance Company, being duly sworn for herself, deposes and says that she is the above described officer of the said company and that the above Financial Statement as of December 31, 2015 is true and correct to the best of her knowledge and belief.


Theresa A. Hoffer
Senior Vice President, Treasurer



Jennifer L. Scheid
Notary Public, State of Ohio
My Commission Expires 01-16-2021

Subscribed and sworn before me this 23rd day of February, 2016.





CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)

3/24/2016

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).


PRODUCER Lexington / AssuredPartners NL 2416 Sir Barton Way, Suite 300 Lexington, KY 40509		CONTACT NAME: PHONE (A/C, No, Ext): (859) 543-1716 FAX (A/C, No): (859) 543-1987 E-MAIL ADDRESS:	
		INSURER(S) AFFORDING COVERAGE	
		NAIC #	
INSURED L&L Excavation and Site Prep Inc US Contracting, Inc. P.O. Box 614 Salyersville, KY 41465		INSURER A : Westfield Insurance Company 24112 INSURER B : Northstone Insurance Company 13045 INSURER C : INSURER D : INSURER E : INSURER F :	

COVERAGES **CERTIFICATE NUMBER:** **REVISION NUMBER:**

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN. THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL SUBR INSD WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	<input checked="" type="checkbox"/> COMMERCIAL GENERAL LIABILITY		TRA7915325	10/01/2015	10/01/2016	EACH OCCURRENCE \$ 1,000,000
	CLAIMS-MADE <input checked="" type="checkbox"/> OCCUR					DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 500,000
	GENL AGGREGATE LIMIT APPLIES PER					MED EXP (Any one person) \$ 5,000
	POLICY <input type="checkbox"/> PRO-JECT <input type="checkbox"/> LOC					PERSONAL & ADV INJURY \$ 1,000,000
	OTHER:					GENERAL AGGREGATE \$ 3,000,000
						PRODUCTS - COMPIOP AGG \$ 3,000,000
A	<input checked="" type="checkbox"/> AUTOMOBILE LIABILITY		TRA7915325	10/01/2015	10/01/2016	COMBINED SINGLE LIMIT (Ea accident) \$ 1,000,000
	ANY AUTO ALL OWNED AUTOS <input checked="" type="checkbox"/> SCHEDULED AUTOS <input checked="" type="checkbox"/> HIRED AUTOS <input checked="" type="checkbox"/> NON-OWNED AUTOS					BODILY INJURY (Per person) \$
						BODILY INJURY (Per accident) \$
						PROPERTY DAMAGE (Per accident) \$
						\$
A	<input checked="" type="checkbox"/> UMBRELLA LIAB <input type="checkbox"/> OCCUR		TRA7915325	10/01/2015	10/01/2016	EACH OCCURRENCE \$ 4,000,000
	EXCESS LIAB <input type="checkbox"/> CLAIMS-MADE <input type="checkbox"/>					AGGREGATE \$ 4,000,000
	DED <input checked="" type="checkbox"/> RETENTION \$ 0					\$
B	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY		WCN6001277	10/01/2015	10/01/2016	<input checked="" type="checkbox"/> PER STATUTE <input type="checkbox"/> OTH-ER
	ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH)	<input type="checkbox"/> Y <input type="checkbox"/> N <input type="checkbox"/> N/A				E.L. EACH ACCIDENT \$ 1,000,000
	If yes, describe under DESCRIPTION OF OPERATIONS below					E.L. DISEASE - EA EMPLOYEE \$ 1,000,000
						E.L. DISEASE - POLICY LIMIT \$ 1,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)
Lexington-Fayette Urban County Government is listed as additional insured with respects to the General Liability and Auto policies. Primary and Non-Contributory applies with respect to the General Liability policy. 30 days NOC included.

CERTIFICATE HOLDER Lexington-Fayette Urban County Government Division of Purchasing 200 East Main Street, 3rd Floor, Room 338 Lexington, KY 40507	CANCELLATION SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS. AUTHORIZED REPRESENTATIVE 
--	--

PART VIII

ADDENDA

All addenda issued during the bidding of the Project will be reproduced in the signed Contract Documents, on the pages following this heading sheet.

<u>Addendum Number</u>	<u>Title</u>	<u>Date</u>
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____
5.	_____	_____

IX. TECHNICAL SPECIFICATIONS



CONTRACT DOCUMENTS
AND
SPECIFICATIONS

DIVISION OF WATER QUALITY

FOR

Haley Pike Landfill Force Main

Bid No. 21-2016

PREPARED BY:
Bell Engineering, Inc.
2480 Fortune Drive, Suite 350
Lexington, Kentucky 40509
(859)-278-5412

TABLE OF CONTENTS
TECHNICAL SPECIFICATIONS
HALEY PIKE LANDFILL FORCE MAIN

Number	Description	Pages
	Geotechnical Report	1 Thru 3
01010	Summary of Work	01010-1
01020	Allowances	01020-1
01500	Construction Facilities and Temporary Controls	01500-1 Thru 01500-3
02110	Site Clearing and Grubbing	02110-1 Thru 02110-2
02140	Dewatering	02140-1
02200	Earth and Rock Work	02200-1 Thru 02200-12
02235	Crushed Stone and Dense Graded Aggregate	02235-1 Thru 02235-4
02326	Steel Cover Pipe	02326-1 Thru 02326-4
02610	Water and Sewage Force Main Pipe	02610-1 Thru 02610-21
02930	Sodding and Seeding	02930-1 Thru 02930-7
15101	Valves for Sewage Systems	15101-1 Thru 15101-5

SECTION 01010
SUMMARY OF WORK

PART 1 GENERAL

1.01 SCOPE OF WORK COVERED BY THE CONTRACT

- A. These Specifications and the accompanying Drawings describe the work to be done and materials to be furnished for the construction of Contract 21-2016, Haley Pike Landfill Force Main, Lexington, Fayette County, Kentucky.
- B. The Work is located at the Haley Pike Landfill, Hedger Lane, Lexington, Fayette County, Kentucky.
- C. Major work items in this Contract include:
 - 1. Approximately 3,085 L.F. of 6-inch HDPE force main piping.
 - 2. Bore and jack under existing railroad.

1.02 WORK SEQUENCE

- A. No priorities are assigned to this work.

PART 2 MATERIALS

Not used.

PART 3 EXECUTION

Not used.

END OF SECTION

Bid No. 21-2016 (2/16)

SECTION 01020

ALLOWANCES

PART 1 GENERAL

1.01 CASH ALLOWANCES

- A. No cash allowances are included in this Project.

END OF SECTION

01020-1

SECTION 01500

CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS

PART 1 GENERAL

1.01 SANITARY FACILITIES

- A. The CONTRACTOR shall construct and maintain, in a sanitary condition, sanitary facilities for the CONTRACTOR'S employees and also employees of the Subcontractors. The CONTRACTOR shall, at completion of the Contract Work, properly dispose of these sanitary facilities.

1.02 UTILITIES

- A. The obtaining of all utilities for construction, including power and water, shall be the responsibility of the CONTRACTOR, and he shall bear the cost of all utilities used for construction. Cost of all connections and facilities for use of utilities shall be borne by the CONTRACTOR.

1.03 MAINTENANCE OF SERVICE IN EXISTING UTILITIES

- A. Where the existing utilities must be disturbed during construction under this Contract, their operation and function shall be maintained by the CONTRACTOR to such a degree that service to customers will be interrupted for minimum time periods only. Such disturbances and any maintenance use of these lines shall constitute no cost to the OWNER. **The OWNER shall be notified of interruptions in sufficient time to prepare for them and shall agree to the hour, date, and duration of them before they are undertaken.**
- B. Should shutdowns in service be in excess of the time of duration agreed upon, and such excessive shutdown time be due to the CONTRACTOR's negligence, faulty Work and/or inability to perform, then and in that event, the CONTRACTOR shall be held liable to the OWNER for any and all damages that may accrue to the OWNER, by reason of such excessive shutdown periods.
- C. Digging through services with trenching machines will not be permitted. Upon damage to utility services, such services shall be repaired immediately and tested to the satisfaction of the ENGINEER. The CONTRACTOR shall notify all utility users of impending interruption of service and shall be responsible for all damage resulting from same. Payment for necessary disconnection and reconnection of utility services shall be included as a part of the CONTRACTOR's bid and no extra compensation will be made for same.
- D. The CONTRACTOR shall at all times maintain on hand an adequate supply of repair materials and tools with which to make repair to damaged water, gas and sewer lines. Should the CONTRACTOR inadvertently damage existing utilities, he shall make immediate repair thereto and in no event shall he leave the site before such repair has been made and proven to be successful.

- E. As far as possible, the locations and sizes of existing mains are indicated on the Drawings; however, exact locations, pipe materials and sizes cannot be guaranteed. It shall be the responsibility of the CONTRACTOR to locate and uncover existing lines, to which new mains are to be connected, and provide all connecting fittings of the correct size and type for each connection. Payment for the above shall be included in the unit price bid for each item used for the connection as indicated on the Drawings or as specified.

1.04 PROPERTY PROTECTION

- A. Care is to be exercised by the CONTRACTOR in all phases of construction, to prevent damage and/or injury to the OWNER's and/or other property. Payments for the repair and restoration are limited as set forth in "Conflict With or Damage to Underground Facilities" of the Supplementary General Conditions.
- B. The CONTRACTOR shall avoid unnecessary injury to trees and shall remove only those **authorized** to be removed by written consent of the OWNER. Fences, gates, and terrain damaged or disarranged by the CONTRACTOR's forces shall be immediately restored in their original condition or better.

1.05 RESIDENT PROJECT REPRESENTATIVE OFFICE

- A. Not required this Contract.

1.06 ACCESS ROADWAYS

- A. The CONTRACTOR shall maintain all existing roadways within the project site which are used for any purpose by his construction operations. The degree and frequency of maintenance shall be adequate to keep existing roadways in a condition at least equal to their condition prior to construction. Road maintenance shall include dust control and grading as necessary.

1.07 RESPONSIBILITY FOR TRENCH SETTLEMENT

- A. The CONTRACTOR shall be responsible for any settlement caused by the construction, that occurs within 1 year after the final acceptance of this Contract by the OWNER. Repair of any damage caused by settlement shall meet the approval of the OWNER.

1.08 DAMAGE TO CROPS, LIVESTOCK AND VEGETATION

- A. The CONTRACTOR shall protect crops, livestock and vegetation against damage or injury from construction operations at all times. Crops damaged or equipment access obtained outside of the easements provided shall be the responsibility of the CONTRACTOR. Temporary fences shall be provided at no extra cost to the OWNER wherever necessary to keep livestock away from the construction area. Ornamental shrubbery and tree branches shall be temporarily tied back, where appropriate, to minimize damage. Damaged limbs shall be trimmed and damaged tree trunks shall be treated with wound dressing.

Bid No. 21-2016 (2/16)

1.09 WASTE DISPOSAL

- A. The CONTRACTOR shall dispose of waste, including any hazardous waste, off-site in accordance with all applicable laws and regulations.

1.10 CONTRACTOR'S TRAILERS AND MATERIAL STORAGE

- A. The location of the CONTRACTOR'S and Subcontractors' office and work trailers and parking areas on the project site shall be subject to the OWNER's approval.
- B. The location of the CONTRACTOR's and Subcontractors' material storage yards on the project site shall be subject to the OWNER's approval.

1.11 CONSTRUCTION IDENTIFICATION SIGNS

- A. The CONTRACTOR shall furnish and erect project identification signs if such are required by the funding agency.
- B. The CONTRACTOR shall obtain the OWNER'S permission before erecting any construction signs not specifically required by the Contract.

PART 2 PRODUCTS

Not used.

PART 3 EXECUTION

Not used.

END OF SECTION

SECTION 02110

SITE CLEARING AND GRUBBING

PART 1 GENERAL

1.01 WORK INCLUDED

- A. Furnish all labor and equipment required and perform all clearing, grubbing and stripping of topsoil complete as shown on the Drawings and as specified herein.

1.02 RELATED WORK

- A. Earth and rock work are included in Section 02200.

1.03 SUBMITTALS

- A. None required for this Section.

PART 2 PRODUCTS

None in this Section.

PART 3 EXECUTION

3.01 GENERAL

- A. The proposed building sites, paved areas, areas designated for ditches and channel changes, borrow pits, etc., (except any portions thereof that may be reserved) shall be cleared of all trees, timber, brush, stumps, rubbish and other debris. All this material, unless otherwise specified, shall be removed and disposed of away from the site.
- B. Open burning is not allowed in Fayette County except for agricultural operations.
- C. Where clearing is to be done, stumps shall be grubbed where embankments are less than 5 feet in height, where the profile indicates excavation, in all areas designated for the construction of other facilities and in borrow areas. In all other areas the stumps may be cut off even with the ground. In areas to be grubbed, all stumps and roots must be removed.
- D. In felling trees near tracks, structures and wire lines, necessary precaution must be exercised in order to prevent damage to wire lines, structures, the facilities of others, or obstruct tracks.
- E. No extra payment for clearing and grubbing shall be included in the lump sum bid.

Bid No. 21-2016 (2/16)

3.02 TREES

- A. Trees (3" caliper and larger) shall not be disturbed by construction without written permission from the OWNER, except in those areas to be cleared. Trees disturbed by construction shall be replaced by the CONTRACTOR with same size and type at no additional cost to the OWNER.

END OF SECTION

02110-2

SECTION 02140

DEWATERING

PART 1 GENERAL

1.01 WORK INCLUDED

- A. Furnish all labor and equipment required to dewater all excavations. Dewatering of all excavations shall be the responsibility of the CONTRACTOR, and no additional compensation will be allowed for same unless specifically included as a bid item.
- B. Leaking pipes and structures are to be anticipated on this project. For this reason, no additional payment will be made for dewatering associated with leakage from any existing facility.

1.02 RELATED WORK

- A. Earthwork is included in Section 02200.
- B. Crushed stone and DGA are included in Section 02235.

1.03 SUBMITTALS

None.

PART 2 PRODUCTS

None in this Section.

PART 3 EXECUTION

1.01 GENERAL

- A. Dewatering equipment shall be of adequate size and quantity to assure maintaining proper conditions for installing pipe, concrete, backfill or other material or structure in the excavation. Dewatering shall include proper removal of any and all liquid, regardless of source, from the excavation and the use of all practical means available to prevent surface runoff from entering any excavation.

END OF SECTION

SECTION 02200
EARTH AND ROCK WORK

PART 1 GENERAL

1.01 SCOPE OF WORK

- A. Extent of earthwork is indicated on the Drawings.
 - 1. Preparation of subgrade for tanks, basins, building slabs, walks and pavements is included as part of this work.
 - 2. Engineered fill course for support of building or basin slabs is included as part of this work.
 - 3. Backfilling of tanks, basins, basements, and trenches within building lines is included as part of this work.
- B. Excavation for Mechanical/Electrical Work
 - 1. Excavation and backfill required in conjunction with underground mechanical and electrical utilities, and buried mechanical and electrical appurtenances is included as work of this Section.

1.02 RELATED WORK

- A. Dewatering is included in Section 02140.
- B. Crushed Stone and DGA is included in Section 02235.
- C. Foundation Drainage is included in Section 02713.
- D. Pressure Pipe is included in Section 02610.
- E. Sodding and Seeding is included in Section 02930.

1.03 QUALITY ASSURANCE

- A. Perform excavation work in compliance with applicable requirements of governing authorities having jurisdiction.
- B. Employ, at CONTRACTOR'S expense, testing laboratory acceptable to the OWNER to perform soil testing and inspection service for quality control testing during earthwork operations.

1.04 SUBMITTALS

- A. Submit following reports directly to the ENGINEER from the testing services, with copy to CONTRACTOR:

Bid No. 21-2016 (2/16)

1. Test reports on borrow material.
2. Verification of each footing subgrade.
3. Field density test reports.
4. One optimum moisture-maximum density curve for each type of soil encountered.
5. Report of actual unconfined compressive strength and/or results of bearing tests on each strata tested.

1.05 JOB CONDITIONS

A. Site Information

1. Data on indicated subsurface conditions are not intended as representations or warranties of accuracy or continuity between soil borings. It is expressly understood that OWNER will not be responsible for interpretation or conclusions drawn therefrom by CONTRACTOR. Data are made available for convenience of CONTRACTOR.
2. Additional test borings and other exploratory operations may be made by CONTRACTOR at no cost to OWNER.

B. Existing Utilities

Prior to commencement of work, the CONTRACTOR shall locate existing underground utilities in areas of the work. If utilities are to remain in place, provide adequate means of protection during earthwork operations.

C. Use of Explosives

1. The CONTRACTOR (or any of his subcontractors) shall not bring explosives onto site or use in work without prior written permission from the OWNER. All activities involving explosives shall be in compliance with the rules and regulations of the Kentucky Department of Mines and Minerals, Division of Explosives and Blasting. CONTRACTOR is solely responsible for handling, storage, and use of explosive materials when their use is permitted.
2. In all blasting operations, the maximum peak particle velocity of the ground motion in any direction shall not exceed 2 inches per second at the immediate location of any dwelling house, public building, school, church, commercial or institutional building and the particle velocity at such location immediately after a period of 1 second following the peak particle velocity produced by any charge shall not exceed ½ inch per second.

D. Protection of Persons and Property

1. Barricade open excavations occurring as part of this work and post with warning lights.
2. Operate warning lights as recommended by authorities having jurisdiction.
3. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by earthwork operations.

PART 2 PRODUCTS

2.01 SOIL MATERIALS

A. Definitions

1. Satisfactory soil materials are defined as those complying with ASTM D2487-85 soil classification groups GW, GP, GM, SM, SW, SP, GC, SC, ML, and CL.
2. Unsatisfactory soil materials are defined as those complying with ASTM D2487-85 soil classification groups MH, CH, OL, OH and PT.
3. Subbase material: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, crushed slag, natural or crushed sand.
4. Drainage fill: Washed, evenly graded mixture of crushed stone, or crushed or uncrushed gravel, with 100 percent passing a 1-1/2 inch sieve and not more than 5 percent passing a No. 4 sieve.
5. Backfill and fill materials: Satisfactory soil materials free of debris, waste, frozen materials, vegetable, and other deleterious matter.
6. Engineered fill: (Refer to this Section, paragraph 3.07.)

PART 3 EXECUTION

3.01 STRIPPING AND TOPSOILING

- A. Before excavation and grading is commenced for buildings, structures or other work described hereinafter (except pipelines and manholes) or before material is removed from borrow pits, the material meeting the topsoil specification in Section 02930 of these Specifications shall be removed from the areas affected and stockpiled.
- B. When final grading is accomplished, particularly around buildings and other structures, the topsoil shall be spread evenly over the excavated area. Rough grading above excavated areas shall have been carried approximately 6 inches below finished grade (except solid rock, where it shall be carried 12 inches

below finished grade) and brought back up to grade with topsoil as set out herein.

3.02 EXCAVATION

A. Excavation includes excavation to subgrade elevations indicated including excavation of earth, rock, bricks, wood, cinders, and other debris. All excavation of materials in the lump sum portion of the work will be unclassified and no additional payment will be made regardless of type material encountered.

B. Differing Site Conditions

1. Refer to Section 00700, paragraph 17.

C. Excavation Classifications

1. The following classifications of excavation will be made when unanticipated material is encountered in work:
 - a. Earth excavation includes excavation of pavements and other obstructions visible on ground surface; underground structures, utilities, and other items indicated to be demolished and removed; together with earth and other materials encountered that are not classified as rock or unauthorized excavation.
 - b. Rock excavation in trenches and pits includes removal and disposal of materials and obstructions encountered which cannot be excavated with a 1.0 cubic yard (heaped) capacity, 42 inch wide bucket on track-mounted power excavator equivalent to Caterpillar Model 215, rated at not less than 90 Hp flywheel power and 30,000 pound drawbar pull. Trenches in excess of 10 feet in width and pits in excess of 30 feet in either length or width are classified as open excavation.
 - c. Rock excavation in open excavation includes removal and disposal of materials and obstructions encountered which cannot be dislodged and excavated with modern track-mounted, heavy-duty excavating equipment without drilling, blasting, or ripping. Rock excavation equipment is defined as Caterpillar Model 973 or No. 977K, or equivalent track-mounted loader, rated at not less than 170 Hp flywheel power and developing 40,000 pound break-out force (measured in accordance with SAE J732C).
 - (1) Typical of materials classified as rock are boulders ½ cubic yard or more in volume, solid rock, rock in ledges and hard cementitious aggregate deposits. Rock material encountered will be classified as rock excavation.

- (2) Intermittent drilling, blasting, or ripping performed to increase production and not necessary to permit excavation of material encountered will be classified as earth excavation.

D. Unauthorized excavation consists of removal of materials beyond subgrade elevations or dimensions without specific direction of ENGINEER. Unauthorized excavation, as well as remedial work directed by ENGINEER, shall be at CONTRACTOR's expense.

1. Under footings, foundation bases, or retaining walls, fill unauthorized excavation by extending indicated bottom elevation of footing or base to excavation bottom, without altering required top elevation. Lean concrete fill may be used to bring elevations to proper position, when acceptable to the ENGINEER.
2. Elsewhere, backfill and compact unauthorized excavations as specified for authorized excavations of same classification.

E. Additional Excavation

1. When excavation has reached required subgrade elevations, notify the ENGINEER who will make an inspection of conditions.
 - a. If unsuitable bearing materials are encountered at required subgrade elevations, carry excavations deeper and replace excavated material as directed in writing by the ENGINEER.
 - b. Removal of unsuitable material and its replacement as directed will be paid on basis of Contract conditions relative to changes in work.

F. Stability of Excavations

1. Slope sides of excavations to comply with codes and ordinances having jurisdiction. Shore and brace where sloping is not possible because of space restrictions or stability of material excavated.
2. Maintain sides and slopes of excavations in safe condition until completion of backfilling.

G. Shoring and Bracing

1. Provide materials for shoring and bracing, such as sheet piling, uprights, stringers, and cross-braces, in good serviceable condition.
2. Establish requirements for trench shoring and bracing to comply with codes and authorities having jurisdiction.

3. Maintain shoring and bracing in excavations regardless of time period excavations will be open. Carry down shoring and bracing as excavation progresses.
4. Provide permanent steel sheet piling or pressure creosoted timber sheet piling wherever subsequent removal of sheet piling might permit lateral movement of soil under adjacent structures. Cut off tops as required and leave permanently in place. In the event the OWNER directs the CONTRACTOR to leave shoring materials in place, the OWNER will reimburse the CONTRACTOR for the reasonable cost of leaving such materials in place.

H. Dewatering

1. Refer to Section 02140 for dewatering requirements.

I. Material Storage

1. Stockpile satisfactory excavated materials where directed, until required for backfill or fill. Place, grade, and shape stockpiles for proper drainage.
2. Dispose of excess soil material and waste materials as herein specified.

J. Excavation for Structures

1. Conform to elevations and dimensions shown within a tolerance of plus or minus 0.10 feet and extending a sufficient distance from footings and foundations to permit placing and removal of concrete formwork, installation of services, other construction, and for inspection.
2. In excavating for footings and foundations, take care not to disturb bottom of excavation. All loose material shall be removed from the excavation just before concrete reinforcement is placed. Trim bottoms to required lines and grades to leave solid base to receive other work.

K. Excavation for Pavements

1. Cut surface under pavements to comply with cross-sections, elevations, and grades as shown.

L. Trench Excavation

1. The CONTRACTOR shall include in his lump sum bid all trenching and backfill necessary for installation of all pipelines as planned and specified unless specific unit prices are set up for specific pipeline. Trenching shall include clearing and grubbing of all trash, weeds, briars, trees and stumps encountered in the trenching. The CONTRACTOR shall dispose of such material at no extra cost to the OWNER. Shrubs shall be removed, maintained and replanted in the same or adjacent location. Trenching also includes such items as railroad, street, road, sidewalk, pipe, and small creek crossings; cutting, moving or repairing damage to fences,

- posts, gates, and other surface structures regardless of whether shown on the Drawings.
2. All existing facilities shall be protected from danger or damage while pipelines are being constructed and backfilled, and from damage due to settlement of the backfill.
 3. In the event any existing structure is damaged, repair and restoration shall be made at once and backfill shall not be replaced until this is done. Restoration and repair shall be such that the damaged structure is equal to or better than its original condition and can serve its purpose as completely as before. All such restoration and repair shall be done without extra cost to the OWNER.
 4. Trenches must be dug to lines and grades shown on the Drawings. Hand trenching may be required in areas where machine trenching would result in undue damage to existing structures and facilities.
 5. Excavation shall be open trenches, except where otherwise shown on the Drawings, for tunneling, boring, or jacking under structures, railroad, sidewalks and roads.
 6. Sheeting and shoring of trenches shall be provided at the expense of the CONTRACTOR where necessary to protect life, property and the new or existing structures from damage or to maintain maximum permissible trench widths at top of pipe. All necessary materials, including, but not limited to, sheeting, sheet piling, trench jacks, braces, shores and stringers, shall be used to hold trench walls. Sheeting and shoring may be withdrawn as the trenches are being backfilled, after backfill has been tamped over top of the pipe at least 18 inches. If removal before backfill is completed to surface endangers adjacent structures, such as buildings, pipelines, street paving, and sidewalks, then the sheeting and shoring shall be left in place until such danger has passed, and then pulled if practical. Voids caused by sheeting withdrawal shall be backfilled and tamped. If not withdrawn, sheeting shall be cut off at least 18 inches below final surface grade, so there is no obstruction at the ground level. In the event the OWNER directs the CONTRACTOR to leave shoring materials in place, the OWNER will reimburse the CONTRACTOR for the reasonable cost of leaving such materials in place.
 7. Where subgrade of trench has insufficient stability to support the pipeline and hold it to its original grade, the ENGINEER may order stabilization by various means. Exclusive of dewatering normally required for construction, and instability caused by neglect of the CONTRACTOR, the necessary stabilization shall be paid for at unit prices established in the Contract. In the event no particular bid price is applicable, then the payment for stabilization will be negotiated.
 8. The location of the pipelines and their appurtenances as shown are those intended for the final construction. However, conditions may present themselves before construction on any line is started that would indicate

desirable changes in location. The OWNER reserves the right to make reasonable changes in line and structure locations without extra cost, except as may be determined by extra units of materials and construction actually involved. The OWNER is under no obligation to locate pipelines, so they may be excavated by machine.

9. Tunneling may be used at the CONTRACTOR'S option as an alternate to open-cut trenching, at no extra cost to the OWNER. The annular space between plates and excavation shall be either permanently placed pea gravel or sand, pumped grout (3 parts sand and 1 part Portland cement by volume) or other suitably installed material approved by the ENGINEER. Backfilling shall be kept close to the heading and completed after each day's work. Where grout is used for backfill, injection holes with threaded plugs shall be provided in liner plates at various levels and in sufficient number to effectively grout the void around the tunnel. A minimum of 3 grout holes shall be provided in each 8 feet of tunnel length. Grout shall be injected in the lower holes first, proceeding upward as the void is filled. Plugs shall be installed after each hole is filled and grout stops shall be provided behind plates as necessary to ensure complete filling of the void. In tunneling under buildings, the CONTRACTOR will be responsible for all damage resulting from his operations and methods of excavation and backfilling. Boring may also be used at the CONTRACTOR'S option as an alternate to tunneling or open-cut trenching, at no extra cost to the OWNER.
10. Dig trenches to the uniform width required for the particular item to be installed, sufficiently wide to provide ample working room. Provide 6 inch to 9 inch clearance on both sides of pipe or conduit.
 - a. Excavate trenches to depth indicated or required. Carry depth of trenches for piping to establish indicated flow lines and invert elevations. Keep bottoms of trenches sufficiently below finish grade to avoid freeze-ups.
 - b. Where rock is encountered, carry excavation 6 inches below required elevation and backfill with a 6-inch layer of crushed stone or gravel prior to installation of pipe.
 - c. For pipes or conduit 4 inches or smaller in nominal size, excavate to subbase depth indicated or, if not otherwise indicated, to 4 inches below bottom of work to be supported.
 - d. For pipes or conduit 6 inches or larger in nominal size, tanks, and other mechanical/electrical work indicated to receive subbase, excavate to subbase depth indicated or, if not otherwise indicated, to 6 inches below bottom of work to be supported.
 - e. Except as otherwise indicated, excavation for exterior water-bearing piping (water, steam, condensate, drainage) so top of piping is no less than 2 feet 6 inches below finish grade.

- f. Grade bottoms of trenches as indicated, notching under pipe bells to provide solid bearing for entire body of pipe.
- g. Backfill trenches with concrete where trench excavations pass within 18 inches of column or wall footings and which are carried below bottom of such footings, or which pass under wall footings. Place concrete to level of bottom of adjacent footing.
- h. Do not backfill trenches until tests and inspections have been made and backfilling authorized by the ENGINEER. Use care in backfilling to avoid damage or displacement of pipe systems.
- i. For piping or conduit less than 2 feet 6 inches below surface of roadways, furnish and install steel casing pipe, minimum wall thickness of 1/4", of sufficient diameter to carry the pipe or conduit to at least 2 feet beyond outside edge of pavement.

M. Cold Weather Protection

- 1. Protect excavation bottoms against freezing when atmospheric temperature is less than 35 degrees Fahrenheit (1 degree Celsius).

3.03 COMPACTION

A. General

- 1. Control soil compaction during construction providing minimum percentage of density specified for each area classification indicated below:
 - a. Percentage of maximum density requirements: Compact soil to not less than the following percentages of maximum density for soils which exhibit a well-defined moisture density relationship (cohesive soils) determined in accordance with ASTM D698; and not less than the following percentages of relative density, determined in accordance with ASTM D4253 and D4254, for soils which will not exhibit a well-defined moisture-density relationship (cohesionless soils).
 - b. Structures, building slabs and steps, pavements: Compact top 12 inches of subgrade and each layer of backfill or fill material at 95 percent standard proctor density at +2 percent to -2 percent optimum moisture content.
 - c. Lawn or unpaved areas: Compact top 6 inches of subgrade and each layer of backfill or fill material at 90 percent standard proctor density.
 - d. Walkways: Compact top 6 inches of subgrade and each layer of backfill or fill material at 95 percent standard proctor density at +2 percent to -2 percent optimum moisture content.

B. Moisture Control

1. Where subgrade or layer of soil material must be moisture conditioned before compaction, uniformly apply water to surface or subgrade, or layer of soil material, to prevent free water appearing on surface during or subsequent to compaction operations.
2. Remove and replace, or scarify and air dry, soil material that is too wet to permit compaction to specified density.
3. Soil material that has been removed because it is too wet to permit compaction may be stockpiled or spread and allowed to dry. Assist drying by discing, harrowing, or pulverizing until moisture content is reduced to a satisfactory value.

3.04 BACKFILL AND FILL

A. General

1. Place acceptable soil material in layers to required subgrade elevations, for each area classification listed below. Backfill material shall be no larger than the specified depth of the layer to be placed and/or compacted.
 - a. In excavations, use satisfactory excavated or borrow material.
 - b. Under grassed areas, use satisfactory excavated or borrow material.
 - c. Under walks and pavements, use subbase material, or satisfactory excavated or borrow material, or combination of both.
 - d. Under steps, use subbase material.
 - e. Under building slabs, use subbase material for a minimum depth of 6 inches.

B. Backfill excavations as promptly as work permits, but not until completion of the following:

1. Acceptance of construction below finish grade including, where applicable, dampproofing, waterproofing, and perimeter insulation.
2. Inspection, testing, approval, and recording locations of underground utilities.
3. Removal of concrete formwork.

4. Removal of shoring and bracing, and backfilling of voids with satisfactory materials. Cut off temporary sheet piling driven below bottom of structures and remove in manner to prevent settlement of the structure or utilities, or leave in place if required.
5. Removal of trash and debris.
6. Permanent or temporary horizontal bracing is in place on horizontally supported walls.

C. Ground Surface Preparation

1. Remove vegetation, debris, unsatisfactory soil materials, obstructions, and deleterious materials from ground surface prior to placement of fills. Plow, strip, or break up sloped surfaces steeper than 1 vertical to 4 horizontal so that fill material will bond with existing surface.
2. When existing ground surface has a density less than that specified under "Compaction" for particular area classification, break up ground surface, pulverize, moisture condition to optimum moisture content, and compact to required depth and percentage of maximum density.

D. Placement and Compaction

1. Place backfill and fill materials in layers not more than 8 inches in loose depth for material compacted by heavy compaction equipment, and not more than 4 inches in loose depth for material compacted by hand-operated tampers. Crushed stone shall be installed in accordance with Section 02235.
2. Before compaction, add moisture or aerate each layer as necessary to provide optimum moisture content. Compact each layer to required percentage of maximum dry density or relative dry density for each area classification. Do not place backfill or fill material on surfaces that are muddy, frozen, or contain frost or ice.
3. Place backfill and fill materials evenly adjacent to structures, piping, or conduit to required elevations. Take care to prevent wedging action of backfill against structures or displacement of piping or conduit by carrying material uniformly around structure, piping, or conduit to approximately same elevation in each lift.

E. Backfilling Trenches

1. Refer to Section 02610 or Section 02700 as appropriate for trench backfill requirements.

Bid No. 21-2016 (2/16)

3.05 GRADING

A. General

1. Uniformly grade areas within limits of grading under this Section, including adjacent transition areas. Smooth finished surface within specified tolerances, compact with uniform levels or slopes between points where elevations are indicated, or between such points and existing grades.

END OF SECTION

02200-12

SECTION 02235

CRUSHED STONE AND DENSE GRADED AGGREGATE (DGA)

PART 1 GENERAL

1.01 SCOPE OF WORK

- A. Furnish and install crushed stone aggregates and DGA as indicated on the Drawings and/or required in the Specifications for such uses as surfaces and/or bases of roads, parking areas and walkways; temporary and permanent traffic bound surfacing over trenches; permanent traffic bound roadway surface maintenance; replacement of unsuitable material; and other miscellaneous applications required in the work.
- B. Various sizes, types and quality of crushed stone aggregates are specified in this Section depending on applicability which may be specified in detail in other sections of these Specifications.
- C. The ENGINEER may require the use of crushed stone aggregates for purposes other than those specified in this or other Specification sections if such use is advisable in his opinion. Payment for crushed stone aggregate shall be by negotiation unless agreed pricing has been previously established.

1.02 RELATED WORK

- A. Dewatering is included in Section 02140.
- B. Earthwork is included in Section 02200.

1.03 SUBMITTALS

- A. Testing Service shall submit required test reports directly to the ENGINEER with copy to CONTRACTOR.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Crushed stone aggregate shall meet the applicable requirements for the intended use in accordance with Section 805 of the Kentucky Transportation Cabinet, Department of Highways, Standard Specifications for Road and Bridge Construction.
- B. Unless otherwise referred to on the Drawings or in these Specifications, crushed stone aggregate shall be graded size No. 57 according to the table below.
- C. When referred to on the Drawings or in these Specifications, dense graded aggregate (DGA) shall have a sand equivalent value of not less than 25 and shall be graded according to the table below.

D. Coarse aggregate gradations referred to by number size on the Drawings or in these Specifications shall conform to the following table (as copied from the above Kentucky Transportation Cabinet Specifications, Table 805.07, 1994 Edition):

TABLE I - SIZES OF COARSE AGGREGATES - KENTUCKY

Size	Max. Size Square Openings (1)	AMOUNTS FINER THAN EACH LABORATORY SIEVE (SQUARE OPENINGS) PERCENTAGE BY WEIGHT																		
		100 (4)	90 (3 1/2)	75 (3)	63 (2 1/2)	50 (2)	37.5 (1-1/2)	25 (1)	19 (3/4)	12.5 (1/2)	9.5 (3/8)	4.75 (No. 4)	2.36 (No. 8)	2 (No. 10)	1.18 (No. 16)	600 (3)	425 (3)	150(3)	75 (3) (No. 200)	
1	90 (3 1/2)	100	90-100		25-60		0-15		0-5											
2	63 (2 1/2)			100	90-100	35-70	0-15		0-5											
23	63 (2 1/2)			100		40-90		0-15		0-5										
3	50 (2)				100	90-100	35-70	0-15		0-5										
357	50 (2)				100	95-100		35-70		10-30		0-5								
4	37.5 (1-1/2)					100	90-100	20-55	0-15		0-5									
467	37.5 (1-1/2)					100	95-100		35-70		10-30	0-5								
5	25 (1)					100	90-100	20-55	0-10	0-5										
57	25 (1)					100	95-100		25-60		0-10	0-5								
610	25 (1)					100	85-100		40-75		15-40									
67	19 (3/4)							100	90-100		20-55	0-10	0-5							
68	19 (3/4)							100	90-100		30-65	5-25	0-10		0-5					
710	19 (3/4)							100	80-100		30-75	0-30								
78	12.5 (1/2)							100	90-100	40-75	5-25	0-10		0-5						
8	9.5 (3/8)								100	85-100	10-30	0-10		0-5						
9-M	9.5 (3/8)								100	75-100	0-25	0-5								
10	4.75 (No. 4)									100	85-100							10-30		
11	4.75 (No. 4)									100	40-90	10-40						0-5		
DGA(2)	19 (3/4)							100	70-100		50-80	30-65				10-40			2-10	
GRAVEL BASE(2)	37.5 (1-1/2)					100					25-65						6-30	5-20		
CSB(2)	50 (2)				100		90-100		60-95		30-70	15-55				5-20			0-8	

(1) Nominal size in mm (inches), unless otherwise shown
 (2) Gradation performed by wet sieve KM 64-420
 (3) micrometers

E. Testing

1. Unless otherwise required in this Section, the ENGINEER shall determine the tests required for crushed stone aggregates according to Section 805. The CONTRACTOR shall be responsible, initially and periodically at no cost to the OWNER, to deliver materials proposed for use or being used in the work to a testing laboratory selected by the OWNER. This provision shall apply to any other aggregate tests required in this Section.
2. The OWNER shall be responsible to pay the laboratory testing costs. However, once a material has been tested and accepted for use, the CONTRACTOR shall be responsible throughout the job to use materials which are equal in all respects and from the same source as that accepted material delivered to the testing laboratory.

3. The CONTRACTOR shall pay for additional tests ordered by the ENGINEER after acceptance of tested materials when such tests show the quality of materials has become deficient or when the CONTRACTOR requests a change of material supplier and/or source.
4. The ENGINEER shall request tests on Form HKB DE-16 "Requisition for Material and Design Mix Tests."

PART 3 EXECUTION

3.01 INSTALLATION

A. Compacted Crushed Stone Aggregate

1. Crushed stone shall be placed in uniform layers not greater than 6 inches deep and shaped by power equipment to required lines, grades, cross connections, and depths. No minimum compacted density, method of compaction, or compaction equipment is required since a nominal amount of compaction effort with vibration can establish the desired intergranular locking of the aggregate under controlled placement depth. Acceptable compaction can be achieved with pneumatic-tired and tracked equipment and rollers.
2. All compaction operations shall be performed to the satisfaction of the ENGINEER.
3. Crushed stone shall be placed in those areas as shown on the Drawings and as may be directed by the ENGINEER.

B. Compacted Dense Graded Aggregate (DGA)

1. Dense graded aggregate shall be plant mixed with water, transported in such a manner as to deliver the mix to the project without loss or segregation, spread, and compacted to produce a density throughout not less than 84 percent of solid volume. Minimum dry density for compacted limestone DGA shall be 139 pounds per cubic foot when S.G. of limestone is 2.65.
2. Density tests shall be required in such number as determined by the ENGINEER. Density tests shall be made by the sand cone method or by nuclear gauges. The CONTRACTOR shall furnish all necessary labor, equipment and materials for making the density tests under observations of the ENGINEER.
3. In the event compacted material does not meet the required density of an area, the CONTRACTOR shall either continue compaction efforts or rework the entire area until the required density is obtained. If material has to be removed and reworked, the ENGINEER shall determine if removed material can be remixed and used again for fill.

Bid No. 21-2016 (2/16)

5. All compacted DGA fill shall be included in the CONTRACTOR'S lump sum bid unless otherwise indicated on the Drawings.

END OF SECTION

02235-4

SECTION 02326

STEEL COVER PIPE

PART 1 GENERAL

1.01 SCOPE OF WORK

- A. Steel cover pipe shall be furnished and installed as shown on the Drawings and specified herein.

1.02 RELATED WORK

- A. Pressure pipe is specified in Section 02610.

PART 2 PRODUCTS

2.01 STEEL COVER PIPE

- A. Steel cover or jack pipe shall be plain end steel pipe with minimum yield strength of 35,000 psi and tensile strength of 60,000 psi per API-5L Grade B material. The steel pipe supplied shall be manufactured by the seamless, electric-weld, submerged arc weld or gas metal-arc weld process as specified in API-5L. Certification of 35,000 psi minimum yield strength shall be furnished by the supplier through the CONTRACTOR to the ENGINEER in sufficient copies before pipe is shipped to job to permit the ENGINEER to retain 3 copies.
- B. Used pipe shall be acceptable if it meets the minimum requirements for size, thickness and strength for new pipe. Supplier shall furnish through the CONTRACTOR to the ENGINEER 3 copies of certification of test results of strength tests conducted on the used pipe prior to shipment to job site. Used pipe with excessive corrosion and pitting present shall not be supplied.
- C. The inside diameter of steel cover pipe shall be at least 2 inches greater than the largest outside diameter of the carrier pipe, joints or couplings, except for carrier pipe 6 inches or greater in diameter under railroads, the difference shall be 4 inches instead of 2 inches.
- D. Cover pipe shall have a **minimum** wall thickness as shown in the following table:

Nominal Diameter Inches	Nominal Thickness Inches	Nominal Diameter Inches	Nominal Thickness Inches
Under 10	0.188	24	0.438
10 & 12	0.250	26	0.438
14 & 16	0.281	28 & 30	0.500
18	0.312	32	0.500
20	0.344	34 & 36	0.562
22	0.375	38 & 42	0.562

PART 3 EXECUTION

3.01 TUNNELING, BORING OR JACKING

- A. Boring or jacking as specified herein will be allowed at locations other than those noted on the Drawings, where advantageous to lay pipe under streets, driveways, and sidewalks, without their monolithic structure being destroyed.
- B. Should the CONTRACTOR elect and receive permission to tunnel or bore, other than at locations designated on the Drawings or required by the ENGINEER to be tunneled or bored, the entire compensation therefor shall be the same as the unit prices bid for installation in open trench, including paving replacement, but not including bore or tunnel unit prices.
- C. At locations where tunneling or boring or jacking is called for on the Drawings, in addition to the unit prices for permanent tunnel, tunnel liner, temporary tunnel, boring or jacking and/or cover pipe, payment will be made for furnishing and laying sewer lines inside the tunnel or cover pipe. No payment will be made for separate trench and backfill unit price items where permanent tunnel, tunnel liner, temporary tunnel, boring or jacking and/or cover pipe unit prices are paid.
- D. Boring or jacking under highways, railroads, sidewalks, pipelines, etc., shall be done at the locations shown on the Drawings. It shall be performed by mechanical means and accurate vertical and horizontal alignment must be maintained. When shown on the Drawings, cover pipe shall be used and shall be installed inside bored holes concurrently with boring, or jacking.

3.02 STEEL COVER PIPE INSTALLATION

- A. Steel cover pipe shall be of the size and wall thickness as shown on the Drawings.
- B. When cover pipe is jacked, concurrent with boring, all joints shall be solidly welded. The weld shall be such that the joint shall be of such strength to withstand the forces exerted from the boring and jacking operation as well as the vertical loading imposed on the pipe after installation. The weld shall also be such that it provides a smooth, nonobstructing joint in the interior of the pipe which will allow easy installation of the carrier pipe without hanging or abrasion to the carrier pipe upon installation.
- C. When cover pipe is installed in open trench or permanent tunnel, it shall be bedded and backfilled per Specifications applying to sewer pipe in such locations. When cover pipe is installed in temporary tunnel, it shall be laid accurately to alignment of proposed sewer and at an elevation below sewer necessary to support it at the planned elevation. Bedding and backfill for cover pipe in temporary tunnel shall be per Specifications for sewer in temporary tunnel.

- D. Cover pipe in open trench, permanent tunnel and temporary tunnel shall be joined in such manner that they will not be moved out of alignment or grade and that will prevent backfill material from entering joint. Where cover pipes are shown on the Drawings to be equipped with vent pipes, vents shall be installed as shown on the Drawings with cost of same included in the price bid for the cover pipe unless otherwise specified.

3.03 CARRIER PIPE IN COVER PIPE INSTALLATION

A. Pipeline Spacers

1. Pipes installed inside cover pipes shall be centered throughout the length of cover pipe. Centering shall be accomplished by the installation of bolt on style spacers with a 2-piece solid shell made from T-304 stainless steel of a minimum 14 gauge thickness. The shell shall be lined with a ribbed PVC sheet of a 0.090 inch thickness that overlaps the edges. Runners, made from UHMW polymer, shall be attached to the pipe in such a manner as to prevent the dislodgement of the spacers as the carrier pipe is pulled or pushed through the cover pipe. Risers shall be made from T-304 stainless steel of a minimum 14 gauge thickness and shall be attached to the shell by MIG welding. All welds shall be fully passivated. All fasteners shall be made from T-304 stainless steel.
2. Spacers shall be of such dimensions to provide 1) full supportive load capacity of the pipe and contents; 2) of such thickness to allow installation and/or removal of the pipe; and 3) to allow no greater than 1/2-inch movement of the carrier pipe within the cover pipe after the carrier pipe is installed.
3. Spacers shall be located immediately behind each bell and at a maximum spacing distance as shown below unless a lesser maximum spacing distance is recommended by the pipe manufacturer:

<u>Pipeline Diameter (in.)</u>	<u>Maximum Spacing (ft.)</u>
2 - 2-1/2	4
3 - 8	7
10 - 26	10
28	9
30	8
32	7
34	6
36 - 38	5.5
40 - 44	5
46 - 48	4

The materials and spacing to be used shall be accepted by the ENGINEER prior to installation. The pipeline spacers shall be manufactured by Cascade Waterworks Manufacturing Co., of Yorkville, Illinois, Pipeline Seal and Insulator, Inc., of Houston, Texas, or equal. Installation shall be in accordance with manufacturer's recommendations.

B. End Seals for Carrier Pipe

1. Upon completion of installation of the carrier pipe, the annular space at the ends of the cover pipe shall be sealed to prevent the entrance of groundwater, silt, etc., into the cover pipe. The seal shall be a manufactured product specially made for this purpose. The seal shall be Link Seal, Model "C" or "L," as manufactured by the Thunderline Corporation, or equal.
2. The device (Model "C" or "L") shall have composite pressure plates and modular seals to be corrosion resistant EPDM suitable for use in water, direct ground burial, and atmospheric conditions. In areas where hydrocarbon resistant is specified, the seals shall be of nitrile and rated for the application (Model OS-316). All nuts and bolts for all models shall be 316 stainless steel (ANSI Type 316 per ASTM F695-95, 85,000 psi average tensile strength).
3. Seal sizes shall be per manufacturer's recommendations for each size of cover pipe and installed per manufacturer's recommendations to provide a watertight seal.

END OF SECTION

SECTION 02610

WATER AND SEWAGE FORCE MAIN PIPE

PART 1 GENERAL

1.01 SUMMARY

- A. For Cover Pipe and Boring and/or Jacking see Section 02326.
- B. All pipe, fittings, and jointing materials shall be of one manufacturer unless different types are shown on the Drawings or otherwise accepted by the ENGINEER.

1.02 SUBMITTALS

A. General

- 1. Prior to the shipment of any water and/or sewage force main piping to the project site, the CONTRACTOR shall submit to the ENGINEER a bill of materials, shop drawings, and descriptive literature for all piping, in the number of copies listed in Section 00700 (00710) of these Specifications.

B. Plant and Site Piping

- 1. Submit shop drawings of all interior and exterior piping.
- 2. Submit testing and certifications for interior and exterior piping.

C. Water Main and Sewage Force Main Projects

- 1. Shop drawings for line work are not required unless project contains pumping station, valve vault piping or similar items.
- 2. Submit descriptive literature for all piping.
- 3. Submit testing and certifications for all piping.

PART 2 PRODUCTS

2.01 MATERIALS-WATER MAIN AND SEWAGE FORCE MAIN PIPE

A. Polyethylene Pipe for Water Mains and Force Mains

- 1. Pipe
 - a. General
 - (1) Polyethylene pipe and fittings shall comply with the requirements of ASTM D 1248, D 1505, D 1693, D 1928, D 2657, D 3035, D 2837 and D 2321.

b. Resins

- (1) Only virgin polyethylene resins classified as Type III, Category 5, Grade P34 per ASTM D 3035 with densities of 0.955 p/cc maximum and melt index of 0.15 g/10 minutes maximum shall be used in the process of making the pipe. The resin shall contain antioxidants and be stabilized with carbon black.

c. Design

- (1) The pipe shall have a long-term strength rating of 1,600 psi or more and be resistant to environmental stress cracking per procedure C of ASTM D 1928 for not less than 200 hours. The maximum allowable deflection is 5 percent with the pipe installed in accordance with these Specifications, using backfill material at 130 pounds per cubic foot, H-20 live load plus 50 percent impact but no internal pressure. The live load and impact may be disregarded in the calculations for trench conditions with 8 feet or more cover. Operating pressures are shown on the Drawings. Hydrostatic loading shall be considered when the pipe is to be installed below a permanent water table or body of water.

d. Wall Thickness Calculations

- (1) The pipe manufacturer shall furnish calculations to support the pipe wall thickness for these various conditions for the ENGINEER'S review/acceptance before the materials are sent to the job site.

e. Quality

- (1) No cracks, holes, foreign material, blisters or other deleterious faults are permitted in the polyethylene pipe. It shall be homogeneous throughout including the heat fused joint. Polyethylene pipe will not be installed containing gouges or cuts that penetrate more than 10 percent of the wall thickness.

f. Water Stops

- (1) The pipe manufacturer shall furnish a water-stop assembly for use with the pipe where the pipe passes through a structure wall so as to provide a watertight seal. The assembly shall be attached to the pipe with non-corroding materials.

g. Marking

- (1) Each length of polyethylene pipe shall contain the manufacturer's brand name, pipe size and other data to enable an accurate tracing of the raw material source. Polyethylene pipe will not be installed containing gouges or cuts that penetrate more than 10 percent of the wall thickness.

2. Joints

a. Fusion

- (1) Polyethylene pipe shall be joined by the heat fusion welding process. Welding equipment may be either gas fired or electric as the CONTRACTOR may select. The welding equipment must be capable of attaining the temperature recommended by the manufacturer for the particular polyethylene extrusion used on the project.
- (2) The fusion equipment shall have hydraulic controls and gauges for monitoring fusion pressures. Also, an engine powered facing unit to trim the irregularities of the pipe ends shall be provided. The heated and thermostatically controlled plate shall contain a temperature gauge for monitoring the heat temperature throughout the fusion process.

b. Flange Adapters

- (1) Threaded or solvent weld joints and connections are not permitted. Flange adapters as manufactured by the pipe supplier shall be used, butt-fused to the pipe and connected to other pipe material using a rubber gasket for sealing.

PART 3 EXECUTION

3.01 TRENCH EXCAVATION-WATER AND SEWAGE FORCE MAINS

A. General

1. Trenching shall include all clearing and grubbing, including all weeds, briars, trees and stumps encountered in the trenching, regardless of size. The CONTRACTOR shall dispose of any such material by burning, burial or hauling away or as noted on the Drawings, at no extra cost to the OWNER. Ornamental shrubs, hedges and small trees (3 inches in diameter or less) shall be removed, protected and replanted, at no extra cost to the OWNER.
2. Trenching also includes such items as railroad, street, road, sidewalk, pipe and small creek crossings; cutting, moving or repairing damage to

fences, poles or gates and other surface structures, regardless of whether shown on the Drawings. The CONTRACTOR shall protect existing facilities against danger or damage while pipeline is being constructed and backfilled or from damage due to settlement of the backfill.

3. Materials encountered in excavation will be divided into 2 classes only: solid rock excavation and other materials. Solid rock excavation is defined as material requiring the use of specialty equipment for removal, such as "hoe ramming," or the use of explosive materials for breakage prior to removal. Other materials shall include earth, loose rock, street or road surfacing and base concrete, and boulders less than 1/3 cubic yard in one piece.
4. In case of "unclassified excavation," as designated in the Drawings and/or Specifications, the price bid shall include earth, solid rock, roots, street or road surfacing and base concrete and boulders.
5. In case of "classified excavation," as designated in the Drawings and/or Specifications, the CONTRACTOR will be paid an additional cost for the removal of solid rock over that bid for other materials.
6. All excavation shall be open trenches, except where the Drawings call for tunneling, boring or jacking under structures, railroads, sidewalks, roads or highways.

B. Trees and Shrubs

1. Where pipelines run through wooded terrain, cutting of trees within limits of maximum permissible trench widths, as set forth in this article, will be permitted. However, cutting of additional trees on sides of trench to accommodate operating of trenching machine will not be permitted. The CONTRACTOR shall obtain specific permission of the OWNER before cutting any tree larger than 4 inches in diameter.

C. Highways, Streets and Railroads

1. Construction equipment injurious to paving encountered shall not be used. Curbs, sidewalks, and other structures shall be protected by the CONTRACTOR from damage by his construction equipment.
2. Where trenching is cut through paving which does not crumble on edges, trench edge shall be cut to at least 2 inches deep to straight and neat edges, before excavation is started, and care taken to preserve the edge to facilitate neat repaving.
3. The CONTRACTOR shall so coordinate his work as to produce a minimum of interference with normal traffic on highways and streets. He may, with the approval of the governing agency, close a street to traffic for such length of time considered necessary, provided persons occupying property abutting the street have an alternate route of access to the property which is suitable for their needs during the time of closure. It

shall be the responsibility of the CONTRACTOR to give 24 hours advance notice to fire and police departments and to occupants of a street which will be closed, in a manner approved by the governing body.

4. The CONTRACTOR shall maintain road crossings in a passable condition for traffic until the final acceptance of the work, being paid only by unit price for crushed rock used, within limitations as hereinafter specified.
5. The amount of crushed stone placed shall be paid for at the unit price per ton up to the maximum limits of 225 pounds per linear foot of trench over which it is placed for pipe sizes through 16 inches, 300 pounds per linear foot for pipe sizes 18 inches through 24 inches and 400 pounds per linear foot for sizes 27 inches through 48 inches. The ENGINEER shall have control of thickness and width to be placed and paid for, and may order changes in depth and width as conditions dictate. No payment will be made for crushed rock surfacing required as a result of unnecessarily wide trenches, omission of sheeting and shoring, or damage by the CONTRACTOR'S equipment, or for maintenance of surface level.
6. Railroad and Highway Department requirements in regard to trenching, tunneling, boring and jacking shall take precedence over the foregoing general specifications and the tunneling and boring or jacking specifications, where they are involved. Where work is within railroad right-of-way, Railroad Protective Insurance shall be carried by the CONTRACTOR in the amounts required by the Railroad Company.
7. The insurance policy shall name the railroad as the insured and the original policy shall be delivered to the railroad after submitting same to the OWNER for review. The cost of flagmen required by the railroad and highway departments shall be paid by the CONTRACTOR.
8. Uneven surfaces or humps in the ground encountered and high driveways and road crossings shall be dug through to such depth that pipe may be laid to a reasonably even grade and have minimum cover at the low places. Such places requiring extra depths shall be included in the bid and no extra payment will be made for such extra depths required, which are evident from an examination of the ground before bidding, as required for 1 foot cover over valve nuts, or are indicated on the Drawings.

D. Existing Utilities

1. The CONTRACTOR shall determine, as far as possible in advance, the location of all existing sewer, culvert, drain, water, electric, telephone conduits, and gas pipes, and other subsurface structures and avoid disturbing same in opening his trenches. In case of sewer, water and gas services and other facilities easily damaged by machine trenching, same shall be uncovered without damage ahead of trenching machine and left intact or removed without permanent damage ahead of trenching and restored immediately after trenching machine has passed, without extra cost to the OWNER. The CONTRACTOR shall protect such existing

facilities, including power and telephone poles and guy wires, against danger or damage while pipeline is being constructed and backfilled, or from damage due to settlement of his backfill. It shall be the responsibility of the CONTRACTOR to inform the customers of utilities of disruption of any utility service as soon as it is known that it has been or will be cut off.

2. The CONTRACTOR shall, at all times during trenching operations, carry a stock of pipe and fittings likely to be needed for replacement of pipelines to facilitate immediate repair.

E. Pipelines in Same Trench

1. Pipelines, force mains, and sewers laid in same trench shall, in all cases, be bedded on original earth, or other specified bedding materials, regardless of divergence in their elevations, unless otherwise specified. They shall never be laid in unsupported backfill or one above the other. The CONTRACTOR shall receive full trenching and backfilling unit prices for each pipeline, force main, and sewer so laid, the same as if laid in widely separated trenches.

F. Location of Proposed Pipelines

1. The location of pipelines and their appurtenances as shown are those intended for the final construction. However, conditions may present themselves before construction on any line is started that would indicate desirable changes in location. Also, development of property traversed may require location changes. In such cases, the OWNER reserves the right to make reasonable changes in line and structure locations without extra cost, except as may be determined by the application of the unit prices bid to the quantities actually involved. The OWNER is under no obligation to locate pipelines so that they may be excavated by machine.

G. Trench Requirements

1. All trenches must be dug neatly to lines and grades.
2. The opening of more than 500 feet of trench ahead of pipe laying and more than 500 feet of open ditch left behind pipe laying, before backfilling, will not be permitted, except upon written consent of the OWNER. No trench shall be left open or work stopped on same for a considerable length of time. In case of objectionable delay trench shall be refilled according to backfill specifications.
3. Where subgrade of trench has insufficient stability to support the pipeline and hold it to its original grade, the ENGINEER may order stabilization by various means. Exclusive of dewatering normally required for construction and instability caused by neglect of the CONTRACTOR, it shall be paid for at unit prices set up in the Contract, such as extra excavation, crushed rock for pipe bedding, concrete cradle or piling.

4. Excavation for pipe laying must be made of sufficient width to allow for proper jointing and alignment of the pipe, but not greater than the maximums permitted in the following table:

MAXIMUM TRENCH WIDTH AT TOP OF PIPE

<u>Nominal Pipe Size</u> (Ins.)	<u>Trench Width</u> (Ins.)	<u>Nominal Pipe Size</u> (Ins.)	<u>Trench Width</u> (Ins.)
4	28	20	44
6	30	24	48
8	32	30	54
10	34	36	60
12	36	42	66
14	38	48	72
16	40	54	78
18	42		

5. Trenches in earth or rock shall be dug as shown on the Drawings and be sufficiently deep to insure a 30 inch or 36 inch minimum cover over water lines and force mains, as noted on the Drawings. Depths of trenching shall also be adequate for at least 1 foot minimum cover over valve nuts. In order to eliminate the necessity for digging bell holes into the trench subgrade by hand and to insure an earth cushion under the pipe for uniform bearing, trench depth shall be the cover requirement plus outside diameter of barrel of pipe plus the required bedding cushion. The cushion construction requirement shall also apply to tunnels.
6. Wherever it is deemed necessary by the ENGINEER to lay the pipes to an extra depth exceeding the depths required by the Drawings and Specifications and not apparent from unevenness of ground, the CONTRACTOR will be paid for such excavation under extra excavation in earth at the price bid per cubic yard, computed on the basis of maximum trench widths in the preceding table. In unclassified excavation contracts the same width limitations will apply.
7. Trench line stations and locations of accessories will be set ahead of the trenching. These will be set at least each 100 feet of pipeline. Trenches must be dug true to alignment of stakes. Alignment of trenches or pipes in trench must not be changed to pass around obstacles such as poles, fences and other evident obstructions without the permission of the ENGINEER. Lines will be laid out to avoid obstacles as far as possible, contingent with maintenance of alignment necessary to finding pipeline in the future and avoiding obstruction to future utilities.

H. Damage to Existing Structures

1. Hand trenching is required, at no extra payment, where undue damage would be caused to existing structures and facilities by machine trenching.

2. In case of damage to any existing structures, repair and restoration shall be made at once and backfill shall not be replaced until this is done. In all cases, restoration and repair shall be such that the damaged structure will be in as good condition and serve its purpose as completely as before, and such restoration and repair shall be done without extra charge, except as set forth under the applicable provisions of the General and Special Conditions. Where there is the possibility of damage to existing utility lines by trenching machine, the CONTRACTOR shall make hand search excavation ahead of machine trenching, to uncover same, at no extra cost to the OWNER.

I. Excavation Unclassified

1. Excavation for pipelines shall be unclassified and the cost of all excavation of whatever nature and state, including solid rock, shall be included in the CONTRACTOR'S unit price bid for furnishing, trenching, laying and backfilling the pipe.
2. Excavation for structures such as manholes, pump stations, and vaults is likewise unclassified and the cost of all excavation of whatever nature and state, including solid rock, shall be included in the CONTRACTOR'S lump sum or unit price bid, as the case may be.

J. Dewatering of Trenches

1. Dewatering of trenches shall be considered a part of trenching, at no extra cost to the OWNER. Dewatering of trenches shall include groundwater and storm or sanitary sewage. Suitable pumping and other dewatering equipment is to be provided by the CONTRACTOR, to insure the installation of the pipeline structure in a dewatered trench and under the proper conditions. Dewatering shall include all practical means available for prevention of surface runoff into trenches and scouring against newly laid pipe.
2. Piles of excavated materials shall be trenched or temporarily piped to prevent, as far as practical, blockage of drainage ditches and gutters, and water carriage of excavated materials over street and highway surfaces.

3.02 LAYING WATER AND SEWAGE FORCE MAINS

A. General

1. Inspection of Materials
 - a. All pipe, fittings and accessories shall be subject to an inspection by the OWNER at the job site. Any damaged materials shall be repaired or replaced to the satisfaction of the OWNER. Should repairs to the piping materials be necessary, then same shall be made in the presence of the ENGINEER using proven methods prescribed by the pipe manufacturer.

- b. The OWNER'S inspection of materials shall in no way relieve the CONTRACTOR of his responsibility.

2. Laying Requirements

- a. Water and sewage force main pipe shall be laid to lines, cover or grades shown on the Drawings.
- b. Pipes must be swabbed out before lowering into trench. In the case of pipelines 4 inch through 20 inch, a swab must also be dragged through the pipe after it is in place. Larger size pipe shall be visually inspected for cleanliness and proper jointing.
- c. The points insisted upon in the laying of pipe will be: Proper alignment, evenness of width and depth of joints, perfection in jointing, and care of the pipe in handling.
- d. Precautions must be taken to prevent flotation of the pipe should water enter the trench prior to putting the pipeline into operation.
- e. In wet, yielding and mucky locations where pipe is in danger of sinking below grade or floating out of grade or alignment, or where the backfill materials are of such a fluid nature that such movements of the pipe might take place during the placing of the backfill, the pipe must be weighted or secured permanently in place by such means as will prove effective. If crushed rock fill beneath the pipe is necessary for stability, it will be paid for at the unit price bid per ton of such material in place except in cases where instability is caused by neglect of the CONTRACTOR.
- f. Whenever pipe laying is stopped, the end of the pipe shall be securely plugged with the manufacturer's standard plug held in place by bracing and/or blocking.
- g. Elbows, plugs, dead end valves, and tees shall be firmly blocked, as shown on the Drawings, to prevent internal pressure from springing the pipe from the intended alignment, with permanent materials solidly placed without covering pipe joints. Restrained type pipe joints may be substituted for thrust blocks with the ENGINEER'S permission. Pipe shall be free of all structures, other than manholes, vaults or planned entries into other structures.
- h. No pipe shall be laid resting on solid rock, blocking or other unyielding objects. Jointing before placing in the trench and subsequent lowering of more than one section jointed together may be allowed, subject to the ENGINEER'S permission.
- i. For PVC and polyethylene pipe, there shall be installed with the pipe #12 AWG insulated wire for the entire length of the pipeline. The wire shall be installed on top of the 12-inch initial backfill and

weighted at locations along the wire sufficient to prevent dislodgement during the backfilling process. The wire shall be accessible at valve boxes or at locator stations along the route of the pipeline, as shown on the Drawings.

- j. Concrete line markers shall be installed at property lines or at bends in the pipeline. Markers may be long markers or short markers as shown on the Drawings or as called for in these Specifications.
- k. Fiberglass line markers shall be installed at valve locations or at locations as shown on the Drawings. Fiberglass markers shall be Carsonite Utility Marker, Style No. 375, or approved equal. Markers shall be equipped with the OWNER'S standard logo.

3. Installing Water Pipe in Cover Pipe

- a. Installation of water pipe in cover pipe is covered in Section 02326 of these specifications.

B. Laying Plastic Pipe

1. Bedding and Backfill

- a. The pipe shall be bedded in 4 inches minimum depth (for pipe sizes through 16 inches) of "loose soil" or "select material" meeting the requirements of Class II or III of ASTM D 2321. For pipe sizes greater than 16 inches in diameter, the pipe bedding shall be a minimum depth of one-fourth the pipe diameter or 6 inches minimum.
- b. Similar material shall be used for haunching up to the spring line of the pipe and it shall be worked under the haunch of the pipe to provide adequate side support. The same material shall then be hand placed to a point 12 inches above the top of the pipe.
- c. After the placement of each lift of the Class II or III bedding, haunching and initial backfill material, the material shall be compacted to 85 percent and/or 90 percent Standard Proctor Density, respectively.
- d. The remaining backfill, except for the top 12 inches which shall contain no rock over 1-1/2 inch diameter nor pockets of crushed rock, may be excavated material containing no rock over 8 inches in any dimension. Larger rock will be allowed in wide trenches where side slopes are low enough to prevent rock from dropping over pipeline. If additional earth is required, it must be obtained and placed by the CONTRACTOR. Filling with rock and earth shall proceed simultaneously, in order that all voids may be filled with earth.

- e. In trenches in solid rock or where flowing water is present, crushed stone bedding and backfill to 12 inches above the top of the pipe shall be substituted for the select material. Kentucky Department of Highways No. 9 stone shall be used for pipe up to 16 inches in diameter.
- f. If select material is not available from the trench excavation, or if the CONTRACTOR so desires, he may use crushed stone bedding and backfill to a point 12 inches above the top of the pipe at no extra cost to the OWNER.
- g. Sufficient space, limited to a maximum of 2 feet length, shall be left out of the bedding to facilitate proper jointing of the pipe.
- h. No pipe shall be laid resting on solid rock, blocking, or other unyielding objects. Jointing before placing in the trench and subsequent lowering of more than one section may be allowed subject to the ENGINEER'S permission.

2. Installation of Polyethylene Pressure Pipe

- a. Polyethylene pipe for water lines or force mains shall be joined using tools and equipment specifically manufactured for use with polyethylene pipe. Heat fusion temperature, heating time and cooling time shall be per the pipe manufacturer's requirements. Pouring of water on completed joints to speed cooling will not be allowed.
- b. The pipe shall be snaked into the trench, employing the natural snaking tendency of the pipe. All short radius bends shall be made with fittings rather than bending the pipe. The pipe will be rejected if it contains kinks and gouges or gouges/cuts penetrating to a depth of 10 percent of the wall thickness.
- c. Sufficient copies of the pipe manufacturer's instructions for installing the pipe and accessories shall be furnished the ENGINEER by the CONTRACTOR to permit the ENGINEER to retain 3 copies. A copy is to be available at the job site at all time.
- d. Because of the high coefficient of expansion of polyethylene, the pipe shall not be attached to rigid structures at the ends until at least 48 hours have elapsed after backfilling and the pipe temperature has had an opportunity to stabilize.

F. Installation of Water Service Accessories

1. Air Valves and Corporation Stops

- a. The location of air valve assemblies, while being noted on the Drawings, could possibly be shifted in actual construction. For this reason, the same statements relative to the methods of installation

of meters and water service connections apply to the installation of air valve assemblies. Air valve assembly boxes shall be installed in the same manner as water meter boxes except that the box will be located slightly off center of the air valve, in order to give better access to the stopcock between the valve and water main.

- b. Corporation stops, as shown on the Drawings, are required between the water main and the meter, and between the main and the air valve assembly.

G. Blocking of Pipe at Bends and Ends

1. Horizontal Bends

- a. Concrete backing and/or blocking required at bends in the horizontal plane shall be accomplished per detail on the Drawings. The square footage of blocking area shall be obtained from Tables "A" and "B" through the following procedure:

Step No. 1 - From Table "A," select type soil and bearing area factor for particular fitting to be blocked.

Step No. 2 - From Table "B," select multiplier to be used for the size pipe being blocked and its test pressure.

Step No. 3 - Calculate actual bearing area required by multiplying bearing area factor from Table "A" by multiplier from Table "B" (e.g. - 16 inch tee with 250 psi test pressure in sandy clay - $9.42 \times 1.78 = 16.7$ S.F. of bearing area required). Bearing area shall in no case be less than the minimum shown in Table "B."

TABLE "A"

Type Soil	Soil Bearing Pressure (PSF)	Bearing Area Factor for Degree of Bend (Square Feet)				
		90°	Plug/Tee	45°	22 1/2°	11 1/4°
Sandy Clay	3,000	13.33	9.42	7.21	3.68	1.85
Hard Clay	6,000	6.66	4.71	3.61	1.84	0.92
Shale	12,000	3.33	2.36	1.80	0.92	0.46
Solid Rock	16,000	2.50	1.77	1.35	0.69	0.35

TABLE "B"

Pipe Dia. (In.)	Min. Bearing Area (S.F.)	Multiplier for Pipe Test Pressure (TP)						
		(TP) 350 psi	(TP) 300 psi	(TP) 250 psi	(TP) 200 psi	(TP) 150 psi	(TP) 100 psi	(TP) 50 psi
4	1.0	0.16	0.13	0.11	0.09	0.07	0.04	0.02
6	1.0	0.35	0.30	0.25	0.20	0.15	0.10	0.05
8	1.0	0.62	0.53	0.44	0.36	0.27	0.18	0.09
10	1.0	0.97	0.83	0.69	0.56	0.42	0.28	0.14
12	1.3	1.40	1.20	1.00	0.80	0.60	0.40	0.20
14	1.5	1.91	1.63	1.36	1.09	0.82	0.54	0.27
16	1.8	2.49	2.13	1.78	1.42	1.07	0.71	0.36
18	2.3	3.15	2.70	2.25	1.80	1.35	0.90	0.45
20	2.5	3.89	3.33	2.78	2.22	1.67	1.11	0.56
24	3.6	5.60	4.80	4.00	3.20	2.40	1.60	0.80
30	5.2	8.75	7.50	6.25	5.00	3.75	2.50	1.25
36	7.0	12.60	10.80	9.00	7.20	5.40	3.60	1.80
42	9.1	17.15	14.70	12.25	9.80	7.35	4.90	2.45
48	11.4	22.40	19.20	16.00	12.80	9.60	6.40	3.20
54	13.5	28.35	24.30	20.25	16.20	12.15	8.10	4.05
60	16.0	35.00	30.00	25.00	20.00	15.00	10.00	5.00

- b. Consideration will be given to the use of restrained type mechanical joint pipe and fittings in lieu of concrete blocking. Use of the restrained joint pipe and fittings is subject to review and acceptance by the ENGINEER of the locking-method and adequacy of design for pressures involved.

2. Vertical Bends

- a. The use of vertical bends in lieu of extra depth trenching shall be subject to permission by the ENGINEER.

- b. Where the CONTRACTOR elects to use vertical bends, or where vertical bends are called for on the Drawings, the CONTRACTOR shall submit the blocking design, including calculations, to the ENGINEER for review and acceptance. Anchorages shall be designed to resist thrusts caused by the internal test pressure in the pipe. Protection against corrosion shall be inherent in the design.

I. Supplemental Backfilling Information

1. General

- a. Excavated materials from trenches, tunnels, and structure excavation in excess of quantity required for trench backfill or site regrade, shall be disposed of by the CONTRACTOR. It shall be the responsibility of the CONTRACTOR to obtain location or permits for its disposal. The price bid for trench excavation and backfill, or site excavation and regrade, shall include the cost of disposition of excess excavated materials, as set forth herein, with no additional compensation being allowed for hauling.
- b. For water line and sewage force main contracts where sod is destroyed in areas maintained equivalent to residence yards, it shall be replaced on slightly ridged backfill on trench, and where destroyed in areas adjacent to the trench, it shall be replaced by the CONTRACTOR with fresh sod, all of which will be paid for at a unit price bid per foot of pipeline. The timing of resodding shall be controlled by the ENGINEER. Ground shall be prepared and fertilized as herewith specified for seeded areas. In small patches, supplying of 3 inches of topsoil and raking may be substituted for disking.
- c. For plant or site based contracts, sodding shall be placed to the extent shown on the Drawings. Refer to Section 02930 of these Specifications for detailed instructions for the placement of sod. The cost for sodding of site based areas shall be included in the lump sum bid for the project.
- d. Where pastures, thin grass or cover crops are destroyed by trenching, laying, backfilling, or tunneling operations, surface shall be prepared by disking, fertilizing, and seeding, as specified in Section 02930. Seeding and fertilizing shall be included in the price for trenching and backfilling. The timing of this operation shall be controlled by the ENGINEER. Requirements of the Department of Highways for reseeding shall take precedence over these Specifications where they are involved.
- e. No extra charge shall be made for backfilling of any kind, except as specified. Backfilling shall be included as a part of the price for trenching. No extra charge shall be made for supplying outside materials for backfill except where fills above existing ground are

necessary and payment is designated on Drawings or in Specifications. If backfilling of the trench or surface restoration is not properly completed, a proportionate part of the unit price for trenching shall be retained from payment estimates.

- f. Before completion of the Contract, all backfills shall be reshaped, holes filled, and surplus materials hauled away and all permanent walks, street, driveways, and highway paving and sod replacement (if such surface replacement items are included in the Contract) and reseeding performed.
- g. Backfill material must be uniformly ridged over trench, and excess hauled away. Ridged backfill shall be confined to the width of the trench and not allowed to overlap onto firm original earth, and its height shall not be in excess of needs for replacement of settlement of backfill.
- h. All rock, including crushed rock or gravel from construction, must be removed from yards and fields. Streets and walks shall be broomed to remove all earth and loose rock immediately following backfilling.

2. Special Requirements

- a. In case of street, highway, railroad, sidewalk and driveway crossings or within any roadway paving, or about manholes, valve and meter boxes located in such paving, the following backfill material and procedure is required.
- b. The pipe shall be bedded in 4 inches minimum depth (for pipe sizes through 16 inches) of crushed rock meeting the requirements of the Kentucky Department of Highways standard size No. 9. For pipe sizes greater than 16 inches in diameter, the pipe bedding shall be a minimum depth of 1/4 the pipe diameter and be of the material and gradation specified previously.
- c. Similar material shall be used for haunching up to the spring line of the pipe, and it shall be worked under the haunch of the pipe to provide adequate side support. The crushed rock shall then be hand placed to a point 12 inches above the top of the pipe.
- d. After the above bedding and selected backfill have been placed, fill trench to within 6 inches of the surface with Kentucky Department of Highways No. 57 crushed stone, uniformly distributed, or other gradation acceptable to the ENGINEER. In order to accommodate compacted temporary surfacing it may be necessary to bulkhead or otherwise confine the stone fill at the open end of the trench.
- e. Temporary surfacing of street, highway, railroad, sidewalk and driveway crossings, or within any roadway paving, or about manholes, valve and meter boxes located in such paving, shall

consist of 6 inches compacted dense graded aggregate as specified under Section 02235 for temporary walkway or road surfacing, placed and compacted in the trench. Compaction shall be accomplished by methods which shall be sufficient to confine stone to the trench under normal traffic. Backfills shall be maintained easily passable to traffic at original paving level until acceptance of project or replacement of paving or sidewalks.

- f. Railroad Company and Department of Highways requirements in regard to backfilling will take precedence over the above general specifications where they are involved.

J. Cut-Ins, Tie-Ins, and Cutting and Plugging

1. The OWNER shall not be responsible for extra costs of cut-ins, tie-ins, cutting and plugging, due to water not being entirely cut off by the existing water main valves.
2. A cut-in is defined as the removal of one section of existing pipeline (2 cuts of pipe) and insertion of one or more new pipeline connections therein.
3. A tie-in is defined as the removal of an existing plug or cap and the connecting of the new pipeline into the existing pipeline or fitting or valve at the joint opened by such removal.
4. A cutting and plugging is defined as the cutting and installation of a plug in an existing line.

3.03 FIELD QUALITY CONTROL

A. Testing Water and Sewage Force Main Piping for Leakage

1. The CONTRACTOR will be required to test all pipelines and appurtenances with water. The maximum test pressure, measured at the lowest elevation of the pipeline being tested, shall be the pressure class of the pipe unless a specific test pressure is shown on the Drawings.
2. Prior to testing, the line shall be filled with water and any entrapped air in the line removed. This may be accomplished at a service tap for water service or air release valve. In any case, the CONTRACTOR shall be responsible for removal of air from the system at no additional cost to the OWNER.
3. When the line or section being tested is pumped up to the required pressure, it shall be valved off from the pump and a pressure gauge placed in the line. The pressure drop in the line, if any, shall be noted. If no pressure drop is noted in 4 hours, the ENGINEER, at his discretion, may accept the line or section as being tested, or he may require the test run the full 24 hours.

4. At the end of the 24 hour test period, the pressure shall be recorded. If there is a drop in pressure, the CONTRACTOR will be required to pump the section being tested up to initial test pressure and maintain that pressure for 24 hours, measuring the amount of water required to accomplish this. The line will not be accepted until the leakage shall prove to be less than 10 gallons per inch diameter per mile of pipe per 24 hours. The 24 hour test shall be charted by timed pressure recorder.
5. Should there be leakage over the allowable amount, the CONTRACTOR will be required to locate and repair the leaks and retest the section.
6. If the leakage of a section of pipeline being tested is below the allowable amount, but a leak is obvious, in the opinion of the ENGINEER, due to water at the surface of the ground, or any other means of determining a leak, the CONTRACTOR will be required to repair those leaks.
7. The CONTRACTOR shall furnish meter and suction tank, pipe test plugs, and bypass piping, and make all connections for conducting the above tests. The pumping equipment used shall be centrifugal pump, or other pumping equipment which will not place shock pressures on the pipeline. Power plunger or positive displacement pumps will not be permitted for use on closed pipe system for any purpose.
8. Inspection of pipe laying shall in no way relieve the CONTRACTOR of the responsibility for passing tests or correcting poor workmanship.

3.04 BASIS OF PAYMENT

A. Excavation and Backfilling

1. Trenching, Laying, and Backfilling Pipelines
 - a. Lump Sum Contracts
 - (1) The CONTRACTOR'S lump sum bid shall include all costs for trenching, laying and backfilling pipelines.
2. Solid Rock Excavation
 - a. Unclassified Excavation
 - (1) Excavation shall be unclassified and the cost of all excavation of whatever nature and state, including solid rock, shall be included in the CONTRACTOR'S unit price bid for each item of construction requiring excavation or included in the lump sum bid for such type contracts.
3. Search and Extra Depth Trench Excavation
 - a. "Search" trench excavation shall be the actual measured excavation within limits as acceptable to the ENGINEER.

- b. "Extra Depth" trench excavation shall be the calculated yardage below the lowest point of excavation which would normally have been required for construction.
- c. Trench width limitations for either condition shall be as listed in the following table:

For 6" Pipe 2'-6"	For 16" Pipe 2'-11"	For 36" Pipe 5'-6"
For 8" Pipe 2'-9"	For 18" Pipe 3'-2"	For 42" Pipe 6'-0"
For 10" Pipe 2'-9"	For 20" Pipe 3'-5"	For 48" Pipe 6'-6"
For 12" Pipe 2'-9"	For 24" Pipe 3'-8"	For 54" Pipe 7'-0"
For 14" Pipe 2'-9"	For 30" Pipe 4'-4"	

- d. The work of uncovering and backfilling required for locating existing sewers, water lines and other existing facilities for avoidance in location of proposed pipelines where such uncovering and backfilling is not within trench for improvements, shall be paid for at a price per cubic yard for such excavation actually removed and backfilled under item for "Search or Extra Depth Trench Excavation." Such payment does not include uncovering existing utility lines for their protection during or after trenching operations for the proposed pipeline.
- e. Where pipelines, force mains and sewers are laid in the same trench, the CONTRACTOR shall receive full trenching and backfill unit prices for each pipeline, force main and sewer so laid, the same as if laid in widely separated trenches.

4. Mechanical Tamping

- a. Mechanical tamping is defined as backfill placed and compacted by power driven mechanical equipment to a greater density than can be achieved by natural settlement or hand tamping methods. Mechanical tamping will be required when ordered by the ENGINEER with payment by the cubic yard so compacted. Measurement, but not actual extent of the mechanical tamping, shall be limited by the numerical maximum allowable trench width (for each size pipe) as shown in the table listed under "Search and Extra Depth Trench." Payment for mechanical tamping shall not include the specified bedding, haunching, or initial backfill required above and below the top of pipe.

B. Tunneling, Boring or Jacking

1. Boring or Jacking

- a. In unit price Contracts, usable holes either bored or jacked shall be paid for per linear foot of hole actually bored or jacked, according to the diameter of the hole required, measured along the centerline from the point of entrance on one side to the point of exit on the other side. When cover pipe is installed inside the bore, boring or jacking and cover pipe shall be paid per linear foot based on the length of the cover pipe installed, according to the diameter of the cover pipe required.

C. Trench and Pipe Stabilization

1. Extra Excavation

- a. Extra excavation required for trench or pipe stabilization shall be paid by the cubic yard so excavated under the item "Search and/or Extra Depth Trench Excavation" based on the limitations for that item.

2. Crushed Stone for Trench Stabilization

- a. Crushed stone ordered by the ENGINEER for trench stabilization shall be as specified in Section 02235 of these Specifications and paid by the ton so placed.

3. Crushed Stone for Pipe Bedding

- a. Additional crushed stone bedding ordered by the ENGINEER for pipe stabilization shall be as specified in Section 02235 of these Specifications and paid by the ton so placed.

4. Plain or Reinforced Concrete Arch

- a. Plain or reinforced concrete arch called for on the Drawings and/or ordered by the ENGINEER shall be paid for by the linear foot of pipeline upon which it is placed. The Form of Proposal will indicate which method is to be used.

5. Plain or Reinforced Concrete Cradle

- a. Plain or reinforced concrete cradle called for on the Drawings and/or ordered by the ENGINEER shall be paid for by the linear foot so placed.

D. Water Lines or Sewage Force Mains

1. Unit Price Contracts

a. Water Lines or Sewage Force Mains

- (1) Payment for furnishing, trenching, bedding, laying, and backfilling water lines or force mains shall be included in the unit price bid per linear foot of pipe laid, including length of fittings and valves, unless same are included in lump sum portions or assemblies noted on the Drawings. However, payments will not be made for branch lengths of fittings within 2.5 feet of edge of main trench. The extra cost of trenching in difficult locations, such as stream, railroad, and highway crossings, if not covered in other contract unit prices, shall be included in unit price for furnishing, trenching, bedding, laying, and backfilling the pipe.
- (2) All blowoff or vent branches will be measured as pipe from center of connecting tee to end of pipe.
- (3) In the case of unit price contracts, unless otherwise stated in the Special Conditions, ductile iron fittings, laid outside lump sum assemblies, will be paid for by the pound of body castings, without joint accessories, at the weights listed in ANSI/AWWA C110/A21.10 or ANSI/AWWA C153/A21.53 in the case of ductile iron compact fittings.

2. Lump Sum Contracts

- a. All work shall be included in the CONTRACTOR'S lump sum bid.

E. Gas Lines

1. Lump Sum Contracts

- a. All work shall be included in the CONTRACTOR'S lump sum bid.

F. Excess Materials

1. The unit prices for trench excavation, tunneling and backfill shall include the cost of disposition of excess excavated materials.

G. Valves

1. The unit price bid for the installation of valves shall include valve boxes, the cost of the concrete collar required around the valve boxes and extension stems if required.

H. Testing and Purging

1. The unit price bid for installing pressure lines shall include cleaning, purging, and testing the line.

I. Blocking of Bends and End of Pipe

1. The payment for blocking of bends and ends of pipes shall be included in the price bid for furnishing and laying the pipe.

J. Disinfection and Dechlorination

1. The required disinfection of pipelines followed by disposal of the chlorinated water used in the disinfection process shall be included in the price bid for furnishing and laying the pipe.

K. Tracing Wire or Tape

1. The cost of tracing wire or tape installed with nonmetallic pipe shall be included in the price bid for furnishing and installing the pipe.

END OF SECTION

SECTION 02930
SODDING AND SEEDING

PART 1 GENERAL

1.01 SCOPE OF WORK

- A. Provide all labor, materials, equipment and services required to perform sodding and seeding as shown on the Contract Drawings and as specified herein.
- B. All areas disturbed by construction operations shall receive a protective cover of vegetation. The work shall consist of preparing the area for treatment, furnishing and placing soil amendments, fertilizer, sod, seed, inoculants, mulch and plantings as specified in the designated areas.

1.02 RELATED WORK

- A. Special requirements for materials and equipment are given in Sections 00700 (00710).
- B. Special sequence or schedule requirements (if any) are specified in Section 01010 - Summary of Work.

1.03 QUALIFICATIONS

- A. The work shall be done by a provider who is experienced, reputable, and qualified in the tasks required.

1.04 SUBMITTALS

- A. Shop Drawings and other items needed to establish compliance with the Drawings and these Specifications shall be submitted to the ENGINEER in accordance with Section 00700 (00710).
- B. Where fertilizer is furnished from bulk storage, the CONTRACTOR shall furnish a supplier's certification of analysis and weight. When required by the Contract, a representative sample of the fertilizer shall be furnished the OWNER for chemical analysis.

1.05 WARRANTY

- A. Refer to Division 0 and 1 for warranty requirements.

PART 2 PRODUCTS

2.01 SOD

- A. The sod to be used shall be Kentucky Bluegrass comparatively free from weeds or heavy root structure, cut in strips of 10 inches to 12 inches wide, 18 inches to 24 inches long, with a thickness of 1-1/2 inches to 2 inches.

2.02 SEED

- A. All seed shall conform to the current rules and regulations of the state where it is being used and from the latest crop available. It shall meet or exceed the standards for purity and germination listed herein.
- B. Seed shall be labeled in accordance with the state laws and the U.S. Department of Agriculture Rules and Regulations under the Federal Seed Act in effect on the date of invitations for bids. Bag tag figures will be evidence of purity and germination. No seed will be accepted with a date of test of more than 9 months prior to the date of delivery to the site.
- C. The seed for use on this project shall be of the type as listed below with the listed germination and purity qualifications.

<u>Species</u>	<u>% Purity</u>	<u>% Germination</u>
Tall fescue (KY-31) (<u>Festuca arundinacea</u>) Ryegrass	98.5	80
(<u>Lolium multiflorum</u>)	98.0	90
Oats (<u>Avena sativa</u>)	98.0	90
Rye, grain (<u>Secale cereale</u>)	97.0	85
Redtop (<u>Agrostis alba</u>)	90.0	80
Ky. Bluegrass (<u>Poa pratensis</u>)	81.0	70

2.03 FERTILIZER

- A. Unless otherwise specified the fertilizer shall be a commercial grade fertilizer or as specified herein. The fertilizer shall meet the standard for grade and quality specified by state law.

2.04 INOCULANTS

- A. The inoculant for treating legume seeds shall be a pure culture of nitrogen-fixing bacteria prepared specifically for the species and shall not be used later than the date indicated on the container or as otherwise specified. A mixing medium, as recommended by the manufacturer, shall be used to bond the inoculant to the seed. Two times the amount of the inoculant recommended by the manufacturer shall be used, except when seed is applied by use of hydraulic seeder, in which case 4 times the amount of inoculant recommended by the manufacturer shall be used. Seed shall be sown within 24 hours of treatment and shall not remain in the hydraulic seeder longer than 4 hours.

2.05 SOIL AMENDMENTS

- A. Lime shall consist of standard ground agricultural limestone, or equal. Standard ground agricultural limestone is defined as ground limestone meeting current requirements of the State Department of Agriculture. Agricultural lime or other needed soil amendments will be uniformly applied at the rate specified herein.

2.06 ASPHALT EMULSION

- A. Asphalt emulsion shall conform to the requirements of ASTM D 977-80, "Emulsified Asphalt." The emulsified asphalt may be rapid, medium, or slow cure materials.

2.07 STRAW MULCH MATERIALS

- A. Straw mulch materials shall consist of wheat, oat, or rye straw, hay, grass clippings cut from any native grasses or other plants acceptable to the ENGINEER. The mulch material shall be air dry, reasonably light in color, and shall not be musty, moldy, caked, or otherwise of low quality. The use of mulch that contains noxious weeds will not be permitted. The CONTRACTOR shall provide a method satisfactory to the ENGINEER for determining weight of mulch furnished.

2.08 OTHER MULCH MATERIALS

- A. Mulching materials, such as wood cellulose fiber mulch, emulsion type, synthetic fiber mulch, netting, mesh, and other mulching materials that may be required for specialized locations and conditions, when specified, must be accompanied by the manufacturer's recommendations for methods of application.

PART 3 EXECUTION

3.01 EXTENT

A. Lump Sum Contracts

1. Sodding

- a. All sodded areas within the construction site steeper than 1 foot vertical to 4 feet horizontal, and berms less than 4 feet wide at all structures shall be sodded, unless otherwise shown on the Drawings or herein specified.

2. Seeding

- a. Except for areas occupied by structures, roadways, walkways, and sodded areas specified above, the entire area disturbed by construction operations shall be seeded.

B. Unit Price Contracts

1. Sodding

- a. Where sod is destroyed in areas maintained equivalent to residence yards, it shall be replaced on slightly ridged backfill on trench, and where destroyed in areas adjacent to the trench, it shall be replaced by the CONTRACTOR with fresh sod. Sodding will

be required only on those Contracts where specifically shown on the Drawings or called for in the Specifications or Form of Proposal.

2. Seeding

- a. Where lawns, pastures, thin grass or cover crops are destroyed by trenching, laying, backfilling, or tunneling operations, surface shall be prepared by disking, fertilizing and seeding. Seeding, fertilizing, and mulching shall be included in the price for trenching and backfilling. The timing of this operation shall be controlled by the ENGINEER. Requirements of the Department of Highways for reseeding shall take precedence over these Specifications where they are involved.
- b. When the construction project is located on privately owned property on easements acquired by the OWNER and the individual landowner requires the cover grass to be the same as present at the beginning of construction, the CONTRACTOR shall supply the seed required by the landowner. Seeding and fertilizing in such instances, shall be at the rate as recommended by the seed producer with soil preparation and mulching as stated herein.
- c. When the construction project encroaches within the rights-of-way of the Department of Highways, the seed mixture, application rate and method of mulching shall be as required by the Department of Highways.

3. CONTRACTOR'S Options

- a. Where surface grasses and cover are similar in nature throughout the length of the project, the CONTRACTOR may provide seed of one type or mixture for the entire project provided there are no objections by individual landowners involved and with permission of the OWNER and ENGINEER. In such cases, the seed type and/or mixture shall be that specified for lawn areas. Pasture and/or cover crop mixtures shall not be used for lawn application for any reason.
- b. When construction facilities or construction operations are located on or encroach on privately owned properties, the CONTRACTOR may, at his election, negotiate with the individual landowners for restoration of the surface. This negotiation and settlement may be for materials or labor or both as agreeable to the individual property owner. In such cases, the CONTRACTOR shall obtain from the individual landowner a "Release of Claims" releasing the OWNER from any further liability for surface restoration, a copy of which shall be provided for the OWNER and ENGINEER. This option shall apply to surface restoration only. The CONTRACTOR shall be responsible for cleanup and regrading work and for any settlement of the trench or graded area within the one year guarantee period.

3.02 SOIL PREPARATION

- A. All areas to be seeded or sodded shall be thoroughly cleaned, removing all debris of whatever nature. After the area has been cleaned, the soil for seeding and sodding shall be prepared as follows:
 - 1. Loosen the soil to a depth of not less than 4 inches.
 - 2. Work the soil until it is in good condition, raking with hand rake to complete the soil preparation and make final finished grade.
 - 3. Broadcast 15 pounds of 8-8-8 or better fertilizer on each 1,000 square feet of area (for sodded areas only).
 - 4. Rake area to receive sod, to spread fertilizer and work into soil.
 - 5. On areas to be seeded, the raking in of fertilizer may be done concurrently with raking in of seed as hereinafter specified.

3.03 SODDING

- A. The timing of resodding shall be controlled by the ENGINEER. Ground shall be prepared and fertilized as previously specified under Article 3.02 of this Specification Section. In small patches, supplying of 3 inches of topsoil and raking may be substituted for disking.
- B. The strips of sod are to be laid so the joints will be broken. After the sod has been laid, it is to be watered thoroughly then rolled with a roller weighing 300 to 400 pounds, supplemented by hand tamping of sections inaccessible by roller.
- C. After the sod has been put down, as described above, each piece is to have a minimum of 2 stakes to hold it in place, the stakes to be 1/2-inch square, 10 inches long, and driven into the ground with 2 inches of the stake left above the sod.
- D. Sod shall be kept moist by watering for at least one month or until the Contract is completed and the facilities accepted by the OWNER for operation.

3.04 SEEDING

- A. Temporary Cover (All Areas)
 - 1. This item shall consist of seeding a temporary cover of grass, or grass and small grain, on areas disturbed on the construction site which will not be redisturbed within a 60 day period. The determination of the area to be temporarily seeded and the time of seeding shall be controlled by the ENGINEER.

2. The seed mixtures to be used for temporary cover will be governed by the time of year the seeding is accomplished. The mixtures and time of seeding shall be as follows:
 - a. Time of Seeding - 2/15 to 6/1
 - (1) Rye 1-1/2 bushels and ryegrass 25 pounds per acre; or tall fescue 30 pounds and ryegrass 20 pounds per acre.
 - b. Time of Seeding - 6/2 to 8/15
 - (1) Tall fescue 30 pounds and ryegrass 20 pounds per acre; or, spring oats 2 bushels and ryegrass 30 pounds per acre.
 - c. Time of Seeding - 8/16 to 2/14
 - (1) Rye 2 bushels and ryegrass 20 pounds per acre; or, tall fescue 30 pounds and ryegrass 20 pounds per acre.
 - d. Lime will not be required for temporary seeding.
 - e. Fertilize at the rate of 400 pounds per acre of 10-10-10 fertilizer, or equivalent, broadcast uniformly on the area to be seeded.
 - f. All seed shall be broadcast evenly over the area to be seeded and cultipacked or otherwise pressed into the soil. Seed and fertilizer may be mixed together and applied after the seed bed has been prepared.
 - g. Mulch for temporary seeding will not be required except on those areas, in the ENGINEER'S opinion, too steep to hold the seed without protective cover.

B. Seeding (Permanent Cover)

1. This item consists of seeding all areas disturbed during construction. All grading and/or filling of rills and gullies to a cross section acceptable to the ENGINEER shall be included in the seed bed preparation.
 - a. Pastures and Cover Crops
 - (1) All areas to be seeded shall be seeded with 50 pounds of tall fescue (KY-31) per acre, subject to the provisions hereinbefore stated in this Specification group.
 - (2) Prepare seed bed as specified in Article 3.02 of this Specification Section unless instructed otherwise by the ENGINEER. Apply 2 tons of lime per acre.

- (3) No mulch will be required except when seeding is done during the period October 16 through January 31, or May 2 through July 31, tall fescue straw shall be used at the rate of 2 tons per acre.

3.05 MULCHING

- A. Mulch materials, meeting the requirements of Part 2 of this Specification Section, shall be applied at the rate of 2 tons per acre.
- B. The mulch shall be stabilized by running a "weighted" disk harrow with disks set straight, over the area on the contour, after the mulch has been applied, so as to imbed or press a part of the straw into the soil sufficiently to hold it in place. On earth embankments or areas too steep for use of mechanized equipment, the mulch shall be held in place by using small stakes and twine or other method acceptable to the ENGINEER. The blown-on bituminous-treated straw mulch method of placing the mulch, as specified in Section 212.06.03, Method 2 of the Standard Specifications for Road and Bridge Construction of the Kentucky Transportation Cabinet Department of Highways, will be an acceptable placing method.
- C. Mesh, netting or other special protective cover shall be at locations as shown on the Drawings and shall be installed according to the manufacturer's recommendations.

END OF SECTION

SECTION 15101
VALVES FOR SEWAGE SYSTEMS

PART 1 GENERAL

1.01 SUMMARY OF WORK

- A. Furnish and install the gate valves, mud valves, telescopic sludge valves, check valves, shear gates, tide gates, sluice gates, flow control valves, and air release/air vacuum valves as shown on the Drawings and as specified herein.

1.02 RELATED WORK

- A. Piping specifications are included in Division 2 and Division 15.
- B. Equipment specifications are included in Division 11.

1.03 REFERENCES

- A. Where referenced specifications (ASTM, ACI, PCI, ETC.), are mentioned, these standards are deemed to be the minimum standard of quality of materials or methods to apply to this project.

1.04 SUBMITTALS

- A. Shop drawings and operation and maintenance instructions shall be submitted in accordance with Section 00700 (00710).
- B. The supplier shall provide with the shop drawing submittal a detailed listing of all valves supplied giving their location, size, end connections, type operator and assigned tag number which identifies their specific point of application.

1.05 QUALITY ASSURANCE

- A. The manufacturer shall have a demonstrated record of producing quality valve products.
- B. The ENGINEER shall be furnished two certified copies of test reports of all required tests of valves including but not limited to leakage, hydrostatic, proof of design and materials of construction.

1.06 SPECIFIC STANDARD REQUIREMENTS

- A. All valves shall open by turning counterclockwise.
- B. Valve actuators shall be subject to adjustment in the field to allow proper access for operation.
- C. All valve bodies shall be cast iron or ductile iron. No steel body valves are allowed unless specifically noted on the Drawings.

- D. Unless otherwise specified, the piping material and type of joints to which the valve is to be connected are shown on the Drawings. Where non-standard end connections are required, they will be called for and/or detailed on the Drawings.
- E. All underground valves shall be mechanical joint ends unless otherwise noted on the Drawings.
- F. All valves located in vaults, buildings or other structures shall have flanged ends unless otherwise noted on the Drawings.

PART 2 PRODUCTS

2.01 RESILIENT SEAT GATE VALVES AND ACCESSORIES

- A. Unless otherwise noted in these Specifications or on the Drawings, all gate valves shall meet the requirements of ANSI/AWWA Specification C509-94. All future reference to section and paragraph numbers will be those of ANSI/AWWA C509-94.
- B. All materials used in the fabrication of valves and operators under this specification, shall conform to the requirements of Section 2 - Materials, except that carbon steel castings are not acceptable.
- C. Cast iron or ductile iron valve bodies shall conform to the requirements of Section 4, paragraph 4.3.1 thru 4.3.3.
- D. Valve stems shall be in accordance with the requirements of Section 4.6, paragraph 4.7.1 thru 4.7.7 except that carbon steel shafts are not acceptable.
- E. Valve stem seals shall be O-rings in accordance with Section 4, paragraph 4.8.2 and subparagraph 4.8.2.1. Materials shall be in accordance with paragraph 4.8.3, except that cast steel and fabricated steel disc are not acceptable.
- F. Valve seats shall be in accordance with Section 4, paragraph 4.16, except that seats applied to the body are not acceptable.
- G. Valve gasket shall be of corrosion resistant materials.
- H. Gaskets shall be in accordance with Section 4.15 or they may be of Buna-N or equal materials.
- I. Valve Operators
 - 1. The valves shall be furnished with the type operators as shown on the Drawings.
 - 2. All underground resilient-seated gate valves shall be NRS and housed in cast iron or PVC valve boxes. Valve boxes shall be of the telescope type, without screw, and of suitable size for covering valve gland and bonnet, and with lengths necessary for each location. On valves which have nuts deeper than 30 inches below tops of valve boxes, valves shall be provided

with extension stems with operating nuts not greater than 12 inches below tops of valve box caps.

3. Unless otherwise shown on the Drawings, all housed resilient-seated gate valves shall be O S & Y or sliding stem, and in basins they shall be of the following types:
 - a. With non-rising extension stem, the valves shall be O S & Y with an O S & Y coupling, nut and key handwheel or stand operated.
4. Wrench Nuts and Handwheels
 - a. Wrench nuts and handwheels shall be in accordance with Section 4.11 and subparagraphs 4.11.1 through 4.11.5, except that all valve whether NRS or O S & Y shall open by turning counterclockwise.

J. Protection

1. Exterior
 - a. Exterior painting of the valves shall be in accordance with Section 2.2.7.1.
2. Interior
 - a. The interior of the valve shall be prepared and painted in accordance with AWWA C550-90. The coating may be a fusion bonded epoxy in 8 to 10 mil thickness or it may be a 2-part thermosetting epoxy having a coating thickness of not less than 4 mils. After application, the interior coating shall be visually examined and holiday tested in accordance with AWWA C550-90, Section 4.2, and the coating thickness measured in accordance with Section 4.2.2, AWWA C550-90.

2.02 FLOW CONTROL VALVES

- A. The flow control pinch valves for pump discharges shall provide simplicity of construction, unobstructed flow pattern, positive shutoff, good abrasion resistance, and good throttling control.
- B. Valves shall have cast iron bodies, with Class 125 pound flanges.
- C. Valves shall be furnished with full port neoprene sleeves. Provide a spare sleeve for each different size valve installed.

2.03 AIR RELEASE/AIR VACUUM VALVES

- A. Automatic air release/air vacuum/combination valves, specifically manufactured for use on wastewater systems, shall be installed at or near the high points of the sewage force main at locations shown on the Drawings or as directed by the ENGINEER.

- B. The air release valve shall have an elongated body of cast iron construction and shall be designed to operate while under pressure to allow entrained air and sewage gases in a sewage force main to escape through the air release orifice. Venting through the orifice shall be accomplished with a needle valve mounted on a compound lever mechanism fitted with a long rod and stainless steel float. The float shall hang inside the valve body, slightly above the inlet, thereby maintaining an air gap between the valve control mechanism and the wastewater in the bottom of the valve housing.
- C. The air vacuum valve shall be of the same body construction as the air release valve. The air vacuum valve shall incorporate one upper and one lower stainless steel float, connected by a common stainless steel float guide, maintaining an air gap between the bottom float and top shut-off float. The air gap shall retard waste solids from fouling or clogging the top shut-off float.
- D. The air release/air vacuum valve assembly shall be equipped with a shut-off valve located between the valve and force main as shown on the standard details of the Drawings. The air release/air vacuum valve shall also be equipped with a 1-inch blow-off valve and quick connect couplings with 6 feet of hose to permit backflushing of the air release/air vacuum valve without the need to disassemble same.
- E. The automatic air release/air vacuum/combination valves furnished for use on this Project shall be either APCO Sewage Air Release/Air Vacuum/Combination Valves as manufactured by Valve and Primer Corporation or Val-Matic as manufactured by the Val-Matic Valve and Manufacturing Corporation, or equal.

PART 3 EXECUTION

3.01 INSTALLATION

- A. All valves and appurtenances shall be installed in the locations shown, true to alignment and rigidly supported. Any damage to the valves shall be repaired before they are installed.
- B. After installation, all valves and appurtenances shall be tested by the CONTRACTOR at least 1 hour at the working pressure corresponding to the class of pipe, unless a different test pressure is specified. If any joint proves to be defective, it shall be repaired.
- C. All materials shall be carefully inspected for defects in workmanship and materials; all debris and foreign material cleaned out of valve openings, etc.; all operating mechanisms operated to check their proper functioning, and all nuts and bolts checked for tightness. Valves and other equipment which do not operate easily, or are otherwise defective, shall be repaired or replaced at no additional cost to the OWNER.
- D. All exposed bolts and nuts shall be cadmium plated unless otherwise specified. All exposed bolts and nuts shall be heavily coated with 2 coats of bituminous paint suitable for the application.

3.02 PAINTING

- A. Unless otherwise specified with the specific type valve in Part 2 of this specification, interior surfaces of all valves, the exterior surfaces of buried valves and miscellaneous piping appurtenances shall be given a shop finish of an asphalt varnish conforming to Federal Specification TT-V51e for Varnish Asphalt, or equal.
- B. The exterior surface of various parts of valves, operators, floorstands and miscellaneous piping shall be thoroughly cleaned of all scale, dirt, grease, or other foreign matter and thereafter one shop coat of an approved rust-inhibitive primer.
- C. Ferrous surfaces obviously not to be painted shall be given a shop coat of grease or other suitable rust-resistant coating.
- D. Field paint, if required, is included under Division 9 and/or specified on the Drawings.

3.03 INSPECTION AND TESTING

- A. All valves shall be factory tested to withstand working pressure as stated and certified test results shall be provided the ENGINEER.
- B. The various pipelines in which the valves and appurtenances are to be installed are specified to be field tested by the CONTRACTOR. During these tests any defective valve or appurtenance shall be adjusted, removed and replaced, or otherwise made acceptable to the ENGINEER.
- C. Various regulating valves or other appurtenances shall be tested to demonstrate their conformance with the specified operational capabilities and any deficiencies shall be corrected or the device replaced or otherwise made acceptable to the ENGINEER.

END OF SECTION
