



ADDENDUM #1

RFP Number: #27-2022

Date: May 4, 2022

Subject: Professional Engineering Services Town Branch 5 Sub Drainage Area

Address inquiries to:
Brian Marcum
brianm@lexingtonky.gov

TO ALL PROSPECTIVE SUBMITTERS:

Please be advised of the following clarifications to the above referenced RFP:

Question: Will LFUCG's field contractor(s) be responsible for performing manhole inspections or dye testing in the project area?

Answer:

LFUCG's contractor is capable of executing dye testing but not Manhole Assessment Certification Program (MACP) complaint manhole inspections. Proposers recommending MACP level inspections must provide their own staff for that work.

Todd Slatin, Director
Division of Central Purchasing

All other terms and conditions of the RFP and specifications are unchanged. This letter should be signed, attached to and become a part of your submittal.

COMPANY NAME: _____

ADDRESS: _____

SIGNATURE OF BIDDER: _____

