



340 S. Broadway
Lexington, Kentucky 40508
859.233.2103
www.engrservices.com

Offices Across the US and Worldwide

December 01, 2015

Hillard Newman, PE
LFUCG
Division of Engineering
101 E. Vine Street
4th Floor
Lexington, KY 40507

RE: Certification of Doe Run Trail (Recreation Drive) Street Construction ~
Athens-Boonesbrough Minor Subdivision

Dear Hillard,

I hereby certify to the best of my knowledge and belief that Doe Run Trail (Recreation Drive) was constructed to the requirements of the LFUCG Division of Engineering Manuals.

I base this certification on being on site during the construction of the road and the testing providing by CSI, LLC.

The road design used for the road construction was 1" Bituminous Asphalt Surface, 9" Bituminous Asphalt Base and 6" DGA. Tensar was used to stabilize the soft areas in the new road construction and the existing pavement was under cut a minimum of 2 feet and No.2 crushed stone placed the entire length of the existing street reconstruction.

If you have any questions please call.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Fred Eastridge', is written over a light blue horizontal line.

Fred Eastridge, PE, PLS